


Operator
Telephone
Fax
e-Mail

Баня / Summary



Height of Room: 2.560 m, Mounting Height: 2.560 m, Maintenance factor: 0.80

Values in Lux, Scale 1:52

Surface	ρ [%]	E_{av} [lx]	E_{min} [lx]	E_{max} [lx]	u_0
Workplane	/	199	99	258	0.500
Floor	30	199	101	258	0.509
Ceiling	70	71	39	100	0.548
Walls (4)	50	149	47	525	/

Workplane:

Height: 0.000 m
Grid: 64 x 64 Points
Boundary Zone: 0.000 m

Illuminance Quotient (according to LG7): Walls / Working Plane: 0.744, Ceiling / Working Plane: 0.356.

Luminaire Parts List

No.	Pieces	Designation (Correction Factor)	Φ (Luminaire) [lm]	Φ (Lamps) [lm]	P [W]
1	4	2R CAPRI R/S 24W LED Downlight (1.000)	1919	1920	24.0
Total:			7678	7680	96.0

Specific connected load: $5.33 \text{ W/m}^2 = 2.68 \text{ W/m}^2/100 \text{ lx}$ (Ground area: 18.00 m^2)