


Operator
Telephone
Fax
e-Mail

Многофункционална спортна зала-тренировки-Клас III / Summary



Height of Room: 4.720 m, Mounting Height: 4.720 m, Maintenance factor: 0.80

Values in Lux, Scale 1:186

Surface	ρ [%]	E_{av} [lx]	E_{min} [lx]	E_{max} [lx]	$u0$
Workplane	/	328	193	398	0.589
Floor	20	328	187	397	0.570
Ceiling	70	81	76	110	0.935
Walls (4)	50	207	95	334	/

Workplane:

Height: 0.000 m
Grid: 64 x 64 Points
Boundary Zone: 0.000 m

UGR

Left Wall 21
Lower Wall 21
(CIE, SHR = 1.00.)

Lengthways-

21
21

Across

22
21

to luminaire axis

Illuminance Quotient (according to LG7): Walls / Working Plane: 0.628, Ceiling / Working Plane: 0.246.

Luminaire Parts List

No.	Pieces	Designation (Correction Factor)	Φ (Luminaire) [lm]	Φ (Lamps) [lm]	P [W]
1	42	2R Ltd LED panel Capri 45W Q 600/600 (1.000)	3996	4000	45.0
Total:			167825	Total: 168000	1890.0

Specific connected load: $5.60 \text{ W/m}^2 = 1.71 \text{ W/m}^2/100 \text{ lx}$ (Ground area: 337.41 m^2)