


Operator  
Telephone  
Fax  
e-Mail

**Sklad / Summary**

Height of Room: 2.800 m, Mounting Height: 2.800 m, Maintenance factor: 0.80

Values in Lux, Scale 1:27

Surface	$\rho$ [%]	$E_{av}$ [lx]	$E_{min}$ [lx]	$E_{max}$ [lx]	$u_0$
Workplane	/	107	78	135	0.726
Floor	10	107	78	135	0.726
Ceiling	50	27	20	35	0.754
Walls (4)	30	91	24	256	/

**Workplane:**

Height: 0.000 m  
Grid: 16 x 16 Points  
Boundary Zone: 0.000 m

Illuminance Quotient (according to LG7): Walls / Working Plane: 0.843, Ceiling / Working Plane: 0.249.

**Luminaire Parts List**

No.	Pieces	Designation (Correction Factor)	$\Phi$ (Luminaire) [lm]	$\Phi$ (Lamps) [lm]	P [W]
1	1	2R Ltd Diego M 4x18W VG IP44 Fluorescent Luminaires Recessed Mounted (1.000)	2946	5400	91.0
Total:			2946	5400	91.0

Specific connected load:  $15.76 \text{ W/m}^2 = 14.71 \text{ W/m}^2/100 \text{ lx}$  (Ground area:  $5.77 \text{ m}^2$ )