

	chap.	kind of type test		kind of document	number of document
d)	6.101	Verification of making and breaking capacities	contactor fuse combination	Test report	1174.2080772.751
			make-proof earthing switch	Test report	1174.2080772.750
e)	6.102	Mechanical operation tests	disconnecter	Test report	U4471/006
			make-proof earthing switch	Test report	U4471/006
			withdrawable part	Test report	U4471/007
			interlocks	Test report	U4471/007
f)	6.7	Verification of the protection (IP coding)		Test report	U4462/033
g)	6.104	Tests on non-metallic partitions and shutters		—	n.a.
h)	6.103	Pressure withstand test of gas-filled compartments		—	n.a.
i)	6.8	Tightness tests		—	n.a.
j)	6.106	Internal arcing tests (classification IAC)	busbar compartment	Test report	1174.2080772.497
			switching device compartment	Test report	U4467/028
			connection compartment	Test report	1174.2080772.726
k)	6.9	Electromagnetic compatibility tests (EMC)		Test report	NX/ET/001, 08-E002305-BM-A01

The above mentioned switchgear complies with the standards that are quoted in the particular test documents.

This summary may contain test documents that refer to switchgear with different technical ratings. These test documents are also valid for the above mentioned object.

This summary represents the current status of the NXAIR type test documentation.

**Frankfurt am Main, 10 November 2011**

**Siemens Aktiengesellschaft**



Thomas Lange



Dieter Zweng

**Siemens AG**  
Infrastructure and Cities Sector; Management: Roland Busch  
Low and Medium Voltage Division; Management: Ralf Christian  
Medium Voltage; Management: Wolfgang Heuring

Mozartstr. 31c  
91052 Erlangen  
Germany

Tel: +49 (9131) 7 0

Siemens Aktiengesellschaft; Chairman of the Supervisory Board: Gerhard Cromme  
Managing Board: Peter Loescher, Chairman, President and Chief Executive Officer; Roland Busch, Brigitte Ederer, Klaus Helmrich, Joe Kaeser  
Barbara Kux, Hermann Requardt, Siegfried Russwurm, Peter Y. Solmssen, Michael Suess  
Registered offices: Berlin and Munich, Germany; Commercial registries: Berlin Charlottenburg, HRB 12300, Munich, HRB 6884  
WEEE-Reg.-No. DE 23891322



ВЯРНО С  
ОРИГИНАЛА

# MANAGEMENT SYSTEM CERTIFICATE

Certificate No.: 134372-2013-ANSO-GER-DAKKS  
 Place and date: Essen, 01.10.2014

Valid: 01.10.2014 - 06.01.2017

Initial date: 1995 (ISO 14001)  
 1997 (ISO 14001)  
 2008 (BS OHSAS 18001)

This is to certify that the management system of  
**Siemens AG**  
**Division Energy Management**  
**Medium Voltage & Systems EM MS**  
 Mozartstr. 31c, 91052 Erlangen - Germany  
 and the sites as mentioned in the Appendix accompanying this Certificate

has been found to conform to management system standard:  
**ISO 9001:2008**  
**ISO 14001:2004**  
**BS OHSAS 18001:2007**

This certificate is valid for the following scope:  
**Development, Production and Sales of**  
**Medium Voltage Switchgear, Circuit Breakers and Components up to 52 kV,**  
**Low Voltage Switchboards and Busbar Systems; Planning and Execution of**  
**Turnkey Power Supply Systems**

Place and date: Essen, 01.10.2014

For the Accredited Unit:  
 DNV GL Business Assurance Zertifizierung  
 und Umweltgutachter GmbH

**DAKKS**  
 Deutsche  
 Akkreditierungsstelle  
 D-ZM-18453-01-00

*Thomas Beck*  
 Thomas Beck  
 Technical Manager

This certificate replaces the issue of 07.01.2014.

Lack of fulfillment of conditions as set out in the Certification Agreement may render this Certificate invalid.  
 ACCREDITED UNIT: DNV GL Business Assurance Zertifizierung und Umweltgutachter GmbH, Schwanenpfad 14, 43229 Essen, Germany.  
 Tel.: +49 201 7238 222, www.dnvgl.de/assurance



## Appendix to Certificate

Locations included in the certification are as follows:

Site Name	Site Address	Site Scope
Siemens AG Division Energy Management Medium Voltage & Systems EM MS	Mozartstr. 31c D-91052 Erlangen	Sales of Medium Voltage Switchgear, Circuit Breakers and Components up to 52 kV, Low Voltage Switchboards and Busbar Systems; Planning and Execution of Turnkey Power Supply Systems
Siemens AG Division Energy Management Medium Voltage & Systems EM MS	Carl-Benz-Str. 22 D-60386 Frankfurt	Development of Gas and Air Insulated Medium Voltage Switchgear up to 52 kV, Production of Gas Insulated Medium Voltage Switchgear up to 52 kV
Siemens AG Division Energy Management Medium Voltage & Systems EM MS	Nonnendammallee 104 D-13629 Berlin	Development and Production of Medium Voltage Switchgear, Circuit Breakers and Components up to 52 kV
Siemens AG Division Energy Management Medium Voltage & Systems EM MS	Südstr. 74 D-04178 Leipzig	Sales, Development, Production and Service of Low Voltage Switchboards
Siemens AG Division Energy Management Medium Voltage & Systems EM MS	Frohnhoferstr. 103-107 D-50827 Köln	Sales, Development and Production of Busbar Systems
Siemens, s.r.o. o.z. Busbar Trunking Systems	Nádražní 30 CZ-78965 Mohelnice	Development and Production of Busbar Systems

Lack of fulfillment of conditions as set out in the Certification Agreement may render this Certificate invalid.  
 ACCREDITED UNIT: DNV GL Business Assurance Zertifizierung und Umweltgutachter GmbH, Schwanenpfad 14, 43229 Essen, Germany.  
 Tel.: +49 201 7238 222, www.dnvgl.de/assurance



**Professional Translation Ltd.**

Представителни Транслации ООД  
14, Ала Бун 44-46, ет. 3  
1506 София, БЪЛГАРИЯ  
www.proftrans.com  
+359 2 6 339 2 6  
Т: +359 236 334 116  
Ф: +359 236 334 116

Превод от английски език

DNV-GL

## СЕРТИФИКАТ ЗА СИСТЕМА ЗА УПРАВЛЕНИЕ

Сертификат №: 154373-2013-AHSO-GER-DAKKS  
Начална дата: 1995 (ISO 9001)  
1997 (ISO 14001)  
2008 (BS OHSAS 18001)  
Валиден до: 01.10.2014 г. - 08.01.2017 г.

С настоящото се удостоверява, че за системата за управление на

**Сименс АД**  
**Отделение „Енергийно управление“**  
**Средно напрежение и системи EM MS**

ул. Моларт 31с, 91052 Ерланген – Германия  
и обектите, споменати в Приложенията, придружаващо този Сертификат  
е установено, че съответства на стандарта за системи за управление:

**ISO 9001:2008**  
**ISO 14001:2004**  
**BS OHSAS 18001:2007**

Този сертификат е валиден за следния обхват:

Разработка, производство и продажби на  
разпределителни уредби, прекъсвачи и компоненти средно напрежение до 62 kV,  
разпределителни табла и шинни системи ниско напрежение; планиране и изпълнение  
на системи за електрозахранване „до ключ“

Място и дата: Бонн, 01.10.2014 г.  
**DAKKS**  
Deutsche  
Akkreditierungsstelle  
D-ZM-18452-01-00  
Любис – не се чете!  
Томас Бек  
Телефонен директор

Настоящото е удостоверение, издадено в Споразумението за сертификация, което да направи този Сертификат валиден.  
АНРЕДИТИРАНО ЗЕМС DNV GL Business Assurance Zertifizierung und Umweltzertifizierung GmbH, Шверинербоф 14, 43329 Бонн, Германия.  
Тел.: +49 201 7286 222. [www.dnvgl.de/363360208](http://www.dnvgl.de/363360208)

ВЯРНО  
РИГИНАЛА



*[Handwritten signature]*

DNV-GL

Сертификат №: 154373-2013-AHSO-GER-DAKKS  
Място и дата: Бонн, 01.10.2014 г.

## Приложение към Сертификат

Местата, включени в сертификацията, са следните:

Име на обекта	Адрес на обекта	Обхват на обекта
Сименс АД Отделение „Енергийно управление“ Средно напрежение и системи EM MS	ул. Моларт 31с 91052 Ерланген Германия	Продажби на разпределителни уредби, прекъсвачи и компоненти средно напрежение до 52 kV, разпределителни табла и шинни системи ниско напрежение; планиране и изпълнение на системи за електрозахранване „до ключ“
Сименс АД Отделение „Енергийно управление“ Средно напрежение и системи EM MS	ул. Карл Бенц 22 60386 Франкфурт Германия	Разработка на газове и въздушно изолирани разпределителни уредби средно напрежение до 52 kV, производство на газове изолирани разпределителни уредби средно напрежение до 52 kV
Сименс АД Отделение „Енергийно управление“ Средно напрежение и системи EM MS	Нонендамалее 104 13629 Берлин Германия	Разработка и производство на разпределителни уредби, прекъсвачи и компоненти средно напрежение до 52 kV
Сименс АД Отделение „Енергийно управление“ Средно напрежение и системи EM MS	Зюдштрассе 74 04178 Дайлциг Германия	Продажби, разработка, производство и обслужване на разпределителни табла ниско напрежение
Сименс АД Отделение „Енергийно управление“ Средно напрежение и системи EM MS	Фронхофштрассе 103-107 50827 Кюлн Германия	Продажби, разработка и производство на шинни системи
Сименс ООД Завод за шинни магистрални системи*	Надразни 30 78985 Мохелвиле Чехия	Разработка и производство на шинни системи

Настоящото е удостоверение, издадено в Споразумението за сертификация, което да направи този Сертификат валиден.  
АНРЕДИТИРАНО ЗЕМС DNV GL Business Assurance Zertifizierung und Umweltzertifizierung GmbH, Шверинербоф 14, 43329 Бонн, Германия.  
Тел.: +49 201 7286 222. [www.dnvgl.de/363360208](http://www.dnvgl.de/363360208)

Подписаният Теодор Пламенов Иванов удостоверява верността на извършения от мен превод от английски на български език на приложението Документ – Сертификат за система за управление.  
Преводът се състои от 2 (две) страници.

*[Handwritten signature]*





THE INTERNATIONAL CERTIFICATION NETWORK

# CERTIFICATE

**IQNet and  
TSE**

hereby certify that the organization  
**SIEMENS SAN. VE TIC. A.Ş.**

**MERKEZ: KARTAL YERLEŞKESİ YAKAKIÇ CADDESİ NO:111  
34870 KARTAL-İSTANBUL**

**ŞUBE: GEBZE YERLEŞKESİ GEBZE ORGANİZE SANAYİ BÖLGESİ 1000.CAD. NO:1004  
41480 GEBZE- İSTANBUL / TÜRKİYE**

has implemented and maintains an  
**ENVIRONMENTAL MANAGEMENT SYSTEM**  
which fulfills the requirements of the following standard

**TS EN ISO 14001:2004**

Scope of the certificate is given in annex.

Date of Revision: 09-10-2014

Date of Certificate: 09-10-2014

Valid Until: 09-10-2017

Registration Number : TR-ÇY-027-05/98


**Michael Drechsel  
President of IQNet**

**Hakan DENİZ  
Istanbul Certification Director**

**ВЕРНО С  
ОРИГИНАЛА**

3414:02:314:10092577

IQNet Partners\*  
ANZOR Spain ANZOR Certification France AIB-Vitrolles International Diplôme ANCC-SICIL-Medio ANCCB Portugal  
CSIQ Italy CQC China CQM China CQS Czech Republic Cve Cert Canada FQS Holding GmbH Germany DS Denmark  
FQIV Brazil FONDORCINA Venissia IONITEC Colombia IURC Mexico INMCIPTI Tunisia  
Inspecta Certification Finland IRAM Argentina JQA Japan KPO Korea MUREC Greece MEST Hungary Krcalin AS Norway  
NSU Ireland TQSC Poland Quality Assurance RR Russia SHI Israel SRI Slovenia SIBUM QAS International Malaysia  
SGS Switzerland SBAC Romania TEST SI Petersburg Russia TSE Turkey TUQS Serbia

\*List of IQNet partners is valid at the time of issue of this certificate. Updated information is available under [www.iqnet-certification.com](http://www.iqnet-certification.com)

THE INTERNATIONAL CERTIFICATION NETWORK

Annex to IQNET Certificate Number :TR-ÇY-027-05/98

Name and Address of the certified organization

**SIEMENS SAN. VE TIC. A.Ş.**

**MERKEZ: KARTAL YERLEŞKESİ YAKAKIÇ CADDESİ NO:111  
34870 KARTAL-İSTANBUL**

**ŞUBE: GEBZE YERLEŞKESİ GEBZE ORGANİZE SANAYİ BÖLGESİ 1000.CAD. NO:1004 41480 GEBZE-  
İSTANBUL / TÜRKİYE**

**Scope of the Certificate**

**DESIGN, PRODUCTION, SALES AND AFTER SALES  
SERVICES OF**

**. ELECTRICAL AND ELECTRONICAL PRODUCTS AND SOLUTIONS**



This annex is only valid in connection with the above-mentioned certificate

3414:02:314:10092577  **TURKISH STANDARDS INSTITUTION** 



THE INTERNATIONAL CERTIFICATION NETWORK

# CERTIFICATE

IQNet and  
TSE

hereby certify that the organization

**SIEMENS SAN. VE TİC. A.Ş.**

MERKEZ: KARTAL YERLEŞKESİ YAKAKIÇ CADDESİ NO:111  
34870 KARTAL-İSTANBUL

ŞUBE: GEBZE YERLEŞKESİ GEBZE ORGANİZE SANAYİ BÖLGESİ 1000.CAD. NO:1004  
41480 GEBZE- KOCAELİ / TÜRKİYE

has implemented and maintains an

**OCCUPATIONAL HEALTH AND SAFETY MANAGEMENT SYSTEM**

which fulfills the requirements of the following standard

**TS 18001:2008**



Scope of the certificate is given in annex.

Date of Revision: 21-11-2012

Date of Certificate: 21-11-2012

Valid Until: 21-11-2015

Registration Number : TR-OY-096-09/05



*Michael Drechsel*

Michael Drechsel  
President of IQNet

*Mesut DÖRÜ*

Mesut DÖRÜ  
Vice System Certification Center

*[Signature]*

IQNet Türkiye\*  
AFNOR Spain, AFNOR Certification France, AIB, Vinçotte International Belgium, ANCS-SRCS, AENOR, AFNOR Portugal, CIBQ Italy, CQC China, CQH China, CQS Czech Republic, Cn Cert, Certevis, DQS Holding GmbH Germany, DQ Denmark, PCV Brazil, FONDRIEMMA Venezuela, KOUITEC Colombia, IMC Mexico, IIRIBORJ Tunisia  
Empacta Certification Poland, IRAM Argentina, JQA Japan, KPO Korea, KURETC, China, MIST Hungary, Nemko AS Norway, NSAI Ireland, PCB, Poland Quality Austria, BR, Russia, SII, Israel, BQ, Slovakia, SIBRA, USA International Malaysia, SQS Switzerland, SHAC, Slovenia, TSEST St. Petersburg, Austria, TSE Turkey, TÜQS Serbia.

\*The list of IQNet partners is valid at the date of issue of this certificate. Updated information is available under [www.iqnet-certification.com](http://www.iqnet-certification.com).



THE INTERNATIONAL CERTIFICATION NETWORK

Annex to IQNET Certificate Number :TR-OY-096-09/05

Name and Address of the certified organization

**SIEMENS SAN. VE TİC. A.Ş.**

MERKEZ: KARTAL YERLEŞKESİ YAKAKIÇ CADDESİ NO:111  
34870 KARTAL-İSTANBUL

ŞUBE: GEBZE YERLEŞKESİ GEBZE ORGANİZE SANAYİ BÖLGESİ 1000.CAD.  
NO:1004 41480 GEBZE- KOCAELİ / TÜRKİYE

Scope of the Certificate

DESIGN, PRODUCTION, SALES AND AFTER SALES SERVICES OF  
- ELECTRICAL AND ELECTRICAL PRODUCTS AND SOLUTIONS

*af 12*



This annex is only valid in connection with the above-mentioned certificate

TURKISH STANDARDS INSTITUTION

TSE

**İŞ SAĞLIĞI ve GÜVENLİĞİ YÖNETİM SİSTEMİ BELGESİ**  
**OCCUPATIONAL HEALTH AND SAFETY MANAGEMENT SYSTEM CERTIFICATE**



TÜRK STANDARLARI ENSTİTÜSÜ  
 bu belge ile

SIEMENS SAN. VE TİC. A.Ş.  
 MERKEZ: KARTAL YERLEŞKESİ YAKACIK CADDESİ NO:111  
 34870 KARTAL-İSTANBUL  
 ŞUBE: GEBZE YERLEŞKESİ GEBZE ORGANİZE SANAYİ BÖLGESİ  
 1000.CAD. NO:1004 41480 GEBZE-  
 KOCAELİ / TÜRKİYE

kuruluşunun TS 18001:2008 şartlarına uygun bir İŞ SAĞLIĞI ve  
 GÜVENLİĞİ YÖNETİM SİSTEMİNE sahip olduğunu onaylar.

Belge kapsamı Ek'te verilmiştir

Sistem Belgelendirme ve Komiteler Müdürü  
 System Certification and Committees Director

*Mustafa ÖLÇER*  
 Mustafa ÖLÇER

**TSE**  
**İSG-OHSAS**  
**TS 18001**

**TÜRK STANDARLARI ENSTİTÜSÜ**  
**TURKISH STANDARDS INSTITUTION**

Sistem Belgelendirme Merkezi Başkanı V.  
 Vice System Certification Center

*Mehmet DURU*  
 Mehmet DURU

Bu belge, Türk Standartları Enstitüsü'nün kuruluşu hakkındaki 132 sayılı kanun uyarınca verilmiştir.  
 This certificate is issued in accordance with the Law No. 132 establishing Turkish Standards Institution.

TURKISH STANDARDS INSTITUTION  
 hereby certifies that the organization

SIEMENS SAN. VE TİC. A.Ş.  
 MERKEZ: KARTAL YERLEŞKESİ YAKACIK CADDESİ NO:111  
 34870 KARTAL-İSTANBUL  
 ŞUBE: GEBZE YERLEŞKESİ GEBZE ORGANİZE SANAYİ BÖLGESİ  
 1000.CAD. NO:1004 41480 GEBZE-  
 KOCAELİ/TÜRKİYE

has an OCCUPATIONAL HEALTH and SAFETY  
 MANAGEMENT SYSTEM which fulfills the requirements  
 of the TS 18001:2008

Scope of the certificate is given in annex

Belge No /Certificate No OY-096-09/05
Belge Tarihi / Date of Certificate 21.11.2012
Geçerlilik Tarihi / Valid Until 21.11.2015
Revizyon Tarihi / Date of Revision 21.11.2012

Bu belge belgelendirme şartlarına uygunluk sağlandığı  
 sürece geçerlidir. This certificate is valid provided that  
 compliance with the certification requirement is maintained.

TSE

**İŞ SAĞLIĞI ve GÜVENLİĞİ YÖNETİM SİSTEMİ BELGESİ**  
**OCCUPATIONAL HEALTH AND SAFETY MANAGEMENT SYSTEM CERTIFICATE**



**EK / ANNEX**

Belge No / Certificate No: OY-096-09/05

Belgeli Kuruluş Adı, Adresi

Name and Address of the certified organization

**Belge Kapsamı:**  
 TS 18001:2008

- ELEKTRİK VE ELEKTRONİK ÜRÜN VE ÇÖZÜMLERİNİN

TASARIM, ÜRETİM, SATIŞ VE SATIŞ SONRASI HİZMETLERİ  
 SUNUMU



Belge Tarihi / Date of Certificate: 21/11/2012

SIEMENS SAN. VE TİC. A.Ş.  
 MERKEZ: KARTAL YERLEŞKESİ YAKACIK CADDESİ NO:111  
 34870 KARTAL-İSTANBUL  
 ŞUBE: GEBZE YERLEŞKESİ GEBZE ORGANİZE SANAYİ BÖLGESİ  
 1000.CAD. NO:1004 41480 GEBZE-  
 KOCAELİ / TÜRKİYE

**Scope of the Certificate:**  
 TS 18001:2008

DESIGN, PRODUCTION, SALES AND AFTER SALES  
 SERVICES OF

- ELECTRICAL AND ELECTRONICAL PRODUCTS AND  
 SOLUTIONS



**ВЯРНО С**

**АЛФА ИМПАНИЈА**



# KALİTE YÖNETİM SİSTEMİ BELGESİ

## QUALITY MANAGEMENT SYSTEM CERTIFICATE

Partner of



**TÜRK STANDARDLARI ENSTİTÜSÜ**  
bu belge ile

SIEMENS SAN. VE TİC. A.Ş.  
MERKEZ: KARTAL YERLEŞKESİ YAKACIK CADDESİ NO:111  
34870 KARTAL-İSTANBUL  
ŞUBE: GEBZE YERLEŞKESİ GEBZE ORGANİZE SANAYİ BÖLGESİ  
1000.CAD. NO:1004 41480 GEBZE-  
KOCAELİ/ TÜRKİYE

Kuruluşunun TS EN ISO 9001:2008 şartlarına uygun bir KALİTE  
YÖNETİM SİSTEMİNE sahip olduğunu onaylar.

Belge kapsamı Ek'te verilmiştir



ВЕРНО С  
ПРИНАЛА



**TURKISH STANDARDS INSTITUTION**  
hereby certifies that the organization

SIEMENS SAN. VE TIC. A.Ş.  
MERKEZ: KARTAL YERLEŞKESİ YAKACIK CADDESİ NO:111  
34870 KARTAL-İSTANBUL  
ŞUBE: GEBZE YERLEŞKESİ GEBZE ORGANİZE SANAYİ BÖLGESİ  
1000.CAD. NO:1004 41480 GEBZE-  
KOCAELİ/TÜRKİYE

has a **QUALITY MANAGEMENT SYSTEM** which fulfills  
the requirements of the **TS EN ISO 9001:2008**

Scope of the certificate is given in annex

## TÜRK STANDARDLARI ENSTİTÜSÜ

### TURKISH STANDARDS INSTITUTION

Sistem Belgelendirme Müdürü  
System Certification Director

*Mustafa Ölçer*  
Mustafa ÖLÇER

Personel ve Sistem Belgelendirme Merkezi Başkanı  
Head of Personnel and System Certification Center

*Ayhan Kırbaş*  
Ayhan KIRBAŞ

Belge No /Certificate No	KY-001-03/KG-91/09-R
Belge Tarihi / Date of Certificate	01.06.2012
Gecerlilik Tarihi / Valid Until	01.06.2015
Revizyon Tarihi / Date of Revision	01.06.2012

Türk Standardları Enstitüsü Türk Akreditasyon Kurumu TÜRKAK tarafından akredite edilmiştir.  
Turkish Standards Institution, has been accredited by the Turkish Accreditation Agency TÜRKAK.

Bu belge belgelendirme şartlarına uygunluk sağlandığı  
sürece geçerlidir. This certificate is valid provided that  
conformance with the certification requirement is maintained.

# KALİTE YÖNETİM SİSTEMİ BELGESİ

## QUALITY MANAGEMENT SYSTEM CERTIFICATE

IEK / ANNEX

Partner of



THE INTERNET NATIONAL CERTIFICATION NETWORK



Kalite Yönetim Sistemi  
TS EN ISO 9001:2008  
AB-00023YS

Belge No / Certificate No: KY-001-03/K.G-91/09-R

Belgeli Kuruluş Adı, Adresi

Name and Address of the certified organization

SIEMENS SAN. VE TIC. A.Ş.  
MERKEZ: KARTAL YERLEŞKESİ YAKACIK CADDESİ NO:111  
34870 KARTAL-İSTANBUL  
ŞUBE: GERZE YERLEŞKESİ GERZE ORGANİZE SANAYİ BÖLGESİ  
1000.CAD. NO:1004 41480 GERZE-  
KOCAELİ / TÜRKİYE

Belge Tarihi / Date of Certificate: 01/06/2012



Belge Kapsamı:

TS EN ISO 9001:2008


- ENDÜSTRİYEL OTOMASYON, BİNA TEKNOLOJİLERİ, MOTOR VE SÜRÜCÜ TEKNOLOJİLERİ
- ENERJİ ÜRETİMİ, İLETİMİ VE DAĞITIMI
- ENERJİ, SU, GAZ SİSTEMLERİ "SCADA" VE OTOMASYON UYGULAMARI İÇİN ORJİN ÇÖZÜM VE SİSTEMLERİNİN TASARIMI, ÜRETİMİ, MÜHENDİSLİK, PROJE YÖNETİMİ, DEĞEREYELME, SATIŞ VE SATIŞ SONRASI SERVİS HİZMETLERİ

Scope of the Certificate:

TS EN ISO 9001:2008

DELIVERY OF  
DESIGN, PRODUCTION, ENGINEERING, PROJECT  
MANAGEMENT COMMISSIONING SALES AND AFTER  
SALES SERVICES OF


PRODUCTS, SOLUTIONS AND SYSTEMS FOR  
- INDUSTRIAL AUTOMATION BUILDING  
TECHNOLOGIES AND DRIVES TECHNOLOGIES  
- POWER GENERATION, TRANSMISSION AND  
DISTRIBUTION  
"SCADA" AND AUTOMATION APPLICATIONS FOR  
ENERGY, WATER AND GAS SYSTEMS



# THYROTRONIC rectifier range for stationary back up power supply

**General**

The protection of electrical load against power failure is often carried out by battery backed up DC power supplies, providing electrical energy to important loads during mains supply, as well as during mains failure.



Excellent Technology, Efficiency and Quality.

**BENNING**  
World Class Power Solutions

Fig. 1: Thyrotronic

Battery backed up DC power supplies have, over several decades proved extremely reliable and very economical power supplies.

The reliability of a battery backed up DC power supply is defined by the quality of the battery used, as well as the reliable operation of the rectifier.

The Thyrotronic rectifier range (see picture 1) developed by BENNING is especially qualified for use as battery backed up power supplies and feature very high reliability and a comprehensive monitoring concept.

Thyrotronic rectifiers are operating with a controlled output characteristic (03-characteristic line in accordance with DIN 41773).

The output voltage is kept constant to the set value with a permissible deviation of  $\pm 0.5\%$  within a load range between 0% and 100% of the unit current.

Mains voltage fluctuations of  $\pm 10\%$  and mains frequency fluctuations of  $\pm 5\%$  will be controlled automatically.

As an energy storage mainly closed or vented lead acid batteries are used. Nickel-cadmium batteries are used in extreme ambient conditions.

**Range of applications**

- Power plants
- substations
- Railway equipment
- Offshore projects
- Oil and gas pipeline systems
- hospitals



**Rectifiers**  
for stationary battery systems  
Standard thyristor-controlled rectifiers  
THYROTRONIC Line



*[Handwritten signature]*

## Type table THYROTRONIC rectifier range for multi-purpose use

Nom. voltage [V]	No. of cells Pb	No. of cells NiCd	Output Current [A]	Type	Main voltage [V]	Current constancy [%]	Cabinet type	Weight [kg]	
24	12	20	20	E 230 G 24 / 20	8VWup-T06	230	4.6	WZ 755	30
24	12	20	40	E 230 G 24 / 40	8VWup-T06	230	9.2	WZ 755	40
24	12	20	60	E 230 G 24 / 60	8VWup-T06	230	13.8	UC 1566	60
24	12	20	80	E 230 G 24 / 80	8VWup-T06	230	17.8	UC 1566	75
24	12	20	100	E 230 G 24 / 100	8VWup-T06	230	22.4	UC 1566	100
24	12	20	125	E 230 G 24 / 125	8VWup-T06	230	28.0	UC 1566	120
24	12	20	150	E 230 G 24 / 150	8VWup-T06	230	34.5	UC 1566	150
24	12	20	175	E 230 G 24 / 175	8VWup-T06	230	40.5	UC 1566	180
24	12	20	200	E 230 G 24 / 200	8VWup-T06	230	47.0	UC 1566	200
24	12	20	250	E 230 G 24 / 250	8VWup-T06	230	58.8	UC 1866	250
24	12	20	300	E 230 G 24 / 300	8VWup-T06	230	71.4	UC 1866	300
24	12	20	400	E 230 G 24 / 400	8VWup-T06	230	95.2	PSJ 1596	510
48	24	40	10	E 230 G 48 / 10	8VWup-T06	230	4.6	WZ 755	30
48	24	40	20	E 230 G 48 / 20	8VWup-T06	230	9.2	WZ 755	40
48	24	40	30	E 230 G 48 / 30	8VWup-T06	230	13.8	UC 1566	60
48	24	40	40	E 230 G 48 / 40	8VWup-T06	230	18.4	UC 1566	75
48	24	40	50	E 230 G 48 / 50	8VWup-T06	230	23.0	UC 1566	100
48	24	40	60	E 230 G 48 / 60	8VWup-T06	230	27.6	UC 1566	120
48	24	40	80	E 230 G 48 / 80	8VWup-T06	230	36.8	UC 1566	150
48	24	40	100	E 230 G 48 / 100	8VWup-T06	230	45.0	UC 1566	180
48	24	40	125	E 230 G 48 / 125	8VWup-T06	230	56.3	UC 1566	200
48	24	40	150	E 230 G 48 / 150	8VWup-T06	230	67.5	UC 1566	250
48	24	40	175	E 230 G 48 / 175	8VWup-T06	230	80.8	UC 1566	300
48	24	40	200	E 230 G 48 / 200	8VWup-T06	230	94.1	UC 1566	400
48	24	40	250	E 230 G 48 / 250	8VWup-T06	230	117.5	UC 1866	500
48	24	40	300	E 230 G 48 / 300	8VWup-T06	230	141.0	UC 1866	600
48	24	40	400	E 230 G 48 / 400	8VWup-T06	230	187.4	PSJ 1896	800
60	30	50	10	E 230 G 60 / 10	8VWup-T06	230	5.1	WZ 755	30
60	30	50	20	E 230 G 60 / 20	8VWup-T06	230	10.3	WZ 755	40
60	30	50	30	E 230 G 60 / 30	8VWup-T06	230	15.4	UC 1566	60
60	30	50	40	E 230 G 60 / 40	8VWup-T06	230	20.6	UC 1566	75
60	30	50	50	E 230 G 60 / 50	8VWup-T06	230	25.8	UC 1566	100
60	30	50	60	E 230 G 60 / 60	8VWup-T06	230	31.0	UC 1566	120
60	30	50	80	E 230 G 60 / 80	8VWup-T06	230	41.4	UC 1566	150
60	30	50	100	E 230 G 60 / 100	8VWup-T06	230	51.8	UC 1566	180
60	30	50	125	E 230 G 60 / 125	8VWup-T06	230	64.7	UC 1566	200
60	30	50	150	E 230 G 60 / 150	8VWup-T06	230	77.6	UC 1566	250
60	30	50	200	E 230 G 60 / 200	8VWup-T06	230	103.5	UC 1566	300
60	30	50	250	E 230 G 60 / 250	8VWup-T06	230	129.4	UC 1866	400
60	30	50	300	E 230 G 60 / 300	8VWup-T06	230	155.3	UC 1866	500
60	30	50	400	E 230 G 60 / 400	8VWup-T06	230	207.1	PSJ 1896	670
108	54	90	5	E 230 G 108 / 5	8VWup-T06	230	4.0	WZ 755	30
108	54	90	10	E 230 G 108 / 10	8VWup-T06	230	8.0	UC 1566	40
108	54	90	15	E 230 G 108 / 15	8VWup-T06	230	12.0	UC 1566	60
108	54	90	20	E 230 G 108 / 20	8VWup-T06	230	16.0	UC 1566	75
108	54	90	25	E 230 G 108 / 25	8VWup-T06	230	20.0	UC 1566	100
108	54	90	30	E 230 G 108 / 30	8VWup-T06	230	24.0	UC 1566	120
108	54	90	40	E 230 G 108 / 40	8VWup-T06	230	32.0	UC 1566	150
108	54	90	50	E 230 G 108 / 50	8VWup-T06	230	40.0	UC 1566	180
108	54	90	60	E 230 G 108 / 60	8VWup-T06	230	48.0	UC 1566	200
108	54	90	80	E 230 G 108 / 80	8VWup-T06	230	64.0	UC 1566	250
108	54	90	100	E 230 G 108 / 100	8VWup-T06	230	80.0	UC 1566	300
108	54	90	125	E 230 G 108 / 125	8VWup-T06	230	96.0	UC 1566	400
108	54	90	150	E 230 G 108 / 150	8VWup-T06	230	112.0	UC 1566	500
108	54	90	200	E 230 G 108 / 200	8VWup-T06	230	149.3	UC 1866	670
108	54	90	300	E 230 G 108 / 300	8VWup-T06	230	224.0	PSJ 1896	1050
108	54	90	400	E 230 G 108 / 400	8VWup-T06	230	298.7	PSJ 2288	1500
216	108	180	5	E 230 G 216 / 5	8VWup-T06	230	9.4	WZ 755	40
216	108	180	10	E 230 G 216 / 10	8VWup-T06	230	18.8	UC 1566	60
216	108	180	15	E 230 G 216 / 15	8VWup-T06	230	28.2	UC 1566	75
216	108	180	20	E 230 G 216 / 20	8VWup-T06	230	37.6	UC 1566	100
216	108	180	25	E 230 G 216 / 25	8VWup-T06	230	47.0	UC 1566	120
216	108	180	30	E 230 G 216 / 30	8VWup-T06	230	56.4	UC 1566	150
216	108	180	40	E 230 G 216 / 40	8VWup-T06	230	75.2	UC 1566	200
216	108	180	50	E 230 G 216 / 50	8VWup-T06	230	94.0	UC 1566	250
216	108	180	60	E 230 G 216 / 60	8VWup-T06	230	112.8	UC 1566	300
216	108	180	80	E 230 G 216 / 80	8VWup-T06	230	150.4	UC 1566	400
216	108	180	100	E 230 G 216 / 100	8VWup-T06	230	188.0	UC 1566	500
216	108	180	125	E 230 G 216 / 125	8VWup-T06	230	235.0	UC 1866	670
216	108	180	150	E 230 G 216 / 150	8VWup-T06	230	282.0	UC 1866	800
216	108	180	200	E 230 G 216 / 200	8VWup-T06	230	376.0	PSJ 2288	1050
216	108	180	300	E 230 G 216 / 300	8VWup-T06	230	564.0	PSJ 2288	1500
216	108	180	400	E 230 G 216 / 400	8VWup-T06	230	752.0	PSJ 2288	2000

Other types on request.

## THYROTRONIC rectifier range for multi-purpose use

### Operation

Lead-acid and nickel-cadmium batteries achieve optimum service life when remaining on float, in a charged condition. The charger floats the battery in a charged state and also supplies the load with power. In the event of mains power failure the battery will then supply the load its required power. This is called "parallel operation" (see fig. 2).

With substantially discharged batteries, the rectifier unit at first operates in the I-branch of the U-characteristic line, whereby the charging current for the batteries results from the difference between the nominal current of the rectifier unit and the load current.

When the set output voltage of the rectifier unit (U-branch) has been reached, the unit is changed to constant voltage charging (see fig. 3).

Switching the charge characteristic, from float charging (e.g. 2.23 V/cell with lead-acid batteries) to boost charging (2.4 V/cell with lead-acid batteries) gives an accelerated recharge which can be manual, dependent on voltage or dependent on charge and time.

After the battery has been fully charged, a small charge current flows (approx. 0.3 mA to 1 mA per 1 Ah) to balance the internal losses of the battery.

The required autonomy is taken into consideration for calculating the battery size. The standby times vary depending on type of load and mains conditions.




Fig. 2: Standby parallel operation

Typical values: Depending on type of load and mains conditions

- 10 - 30 minutes - for EDP-systems
- 1 - 3 hours - energy supply - process control - rail way - hospitals
- 2 - 10 hours - telecommunication systems - oil and gas industry




Fig. 3: Charging characteristic for lead-acid batteries in accordance with IEC 41773

safe, reliable, powerful

Rectifier series Thyrotronic

The Thyrotronic series consists mainly of a thyristor-controlled power unit and a microprocessor-controlled monitoring and control unit.

The following main components are included:

- mains input with contactor
- mains transformer with separate windings
- fully controlled 6 pulse three phase bridge with semi conductor protection fuse (working primarily as battery inverse polarity protection)
- smoothing chokes and capacitor bank to reduce ripple
- control unit with digital setpoint setting
- digital monitoring
- display and operation unit with graphical LCD display on the front door (see picture 5)
- NF fuses loaded battery circuit breaker
- 2 pol NF load circuit breaker to be populated with fuses or links for load circuit.

Functions of the signalling and monitoring unit:

In the rectifiers of the Thyrotronic range a very large monitoring concept with the following functions is included as standard:

Mains monitoring

In case of a mains failure, an electronic regulator block is inhibited and the LED and the "mains failure relay" will be activated. If the mains voltage returns the unit is automatically switched on after a set time.

Charger output monitoring

The charger output monitoring is a current-dependent low voltage monitoring and monitors the IU-characteristic of the rectifier unit.

If the charger output falls below a set value of 2.1 V/cell and the output current falls below 90% of the rated current the alarm will activate and block the unit fault. The corresponding LED and the common relay will be activated.

High voltage monitoring

If the output voltage rises too high (value is adjustable due to an internal or external interference, over 20 mV), the impulses blocking will be activated and the output voltage will be set to zero.

This high voltage monitoring works as dynamic monitoring with an automatic start of the monitoring activities 4 times within a period of 30 seconds. The pulse counter will be disconnected, the LED "high voltage" and common relay will be activated.

Low battery voltage

If the battery voltage falls below a set value, e.g. 1.8 V/cell (value adjustable) during discharge in a case of mains failure, the alarm "low battery voltage" will appear. LED and common alarm will be activated.

Battery circuit test

The battery circuit of the power supply system is tested cyclically every 24 hours. For this, the rectifier output voltage is dropped down to 1.9 V/cell for a period of 5 seconds. As a result, the battery is discharged. At the same time, the battery voltage is checked. If the battery voltage drops above 1.9 V/cell, the battery circuit has no fault. If it falls below the limiting value, a "battery circuit fault" will be indicated and the LED as well as the common fault signalling relay will be activated. - Caution! - It is not intended that this test should replace battery circuit monitoring!

Battery availability test

During the battery availability test the rectifier output voltage will be dropped and the battery will be discharged as is the case during the battery circuit test. The battery will be discharged down to an adjustable minimum voltage limit during an adjustable time. These limits depend on the proportional battery capacity withdrawn during the discharge and can be taken from the discharging curves of the connected battery.

If, during the availability test, the values fall below the adjusted limits, the message "battery test negative" will be indicated by the corresponding LED and the common fault signalling relay.

After the test the rectifier automatically switches back to boost charge or floating charge.

Earth fault monitoring

The earth fault monitoring function monitors the impedance resistance of the DC-output to earth. Plus and minus are measured and monitored alternately. If the insulation resistance falls below the adjusted value (adjustable from 100 kOhm to 1 MOhm), this will be indicated by the LEDs and the common alarm.

PI Compensation

With PI Compensation it is possible to monitor the voltage drop on the cable between rectifier and battery. The length of cable length and cross-sections are taken into account.

Programmable float/boost-charge change over  
If the battery voltage (measured by means of an internal or external interference) falls below a set value, the unit will automatically be switched over to boost charge.

After the boost charge voltage (current) limitation has been reached and after decreasing to < 90%, a time delay will be activated. Upon expiry of the set time (set by LED) the unit will automatically be switched back to float charge.

The automatic charging can be switched off so that only a manual switch-over via the plastic roll key board on the front panel is possible. Switching back to float charge can be done manually as well. If this is not done, the controller will switch back as in the case of automatic charging.

The switch-over to boost bridge can be blocked by an external contact or a fused bridge on the controller.

Equalise charge stage

It is possible to switch to an equalise charge stage via a switch on the front panel. Here the voltage limitation will be abolished and the nominal unit current will be reduced to 20% (adjustable from 20-30). An equalise and commissioning charge follows with an I-characteristic up to the final charge voltage of the battery.

After switching to equalise charge, a timer automatically switches back to the float charge on expiry of the set time (16 hours to 72 hours).

Using an external contact or a fused bridge at the regulator, the equalise charge can be blocked and a switch over to the I-characteristic can be prevented.

Load sharing in parallel operation

Due to an internal bus connection between several rectifiers an active load sharing of  $\pm 10\%$  is possible.






Fig. 4: Thyrotronic interior view

Display and operation unit (see picture 5)

The display and operation unit (mounted on the front door of the Thyrotronic) features a graphical LCD display to indicate the status and the measurements in plain text, as well as 17 LEDs controlled by the monitoring and control unit.



The 4 LEDs integrated in the display above the push buttons are linked to fixed functions. Two spare LEDs can be linked to any external monitoring units.



LED Test / Reset



# THYBROTRONIC technical data


### Technical data

<b>Mains input</b>	(VAC) 230 ± 10 % 1-phase 3x400 ± 10 % 3-phase
<b>Input voltage</b>	(A) see type table
<b>Input current</b>	(Hz) 50 ± 5 %
<b>Frequency</b>	-0.03 at nominal mains voltage and float charging
<b>Power factor</b>	
<b>Rectifier output</b>	
<b>Output voltage</b>	(VDC) 24, 48, 60, 110, 125, 220
<b>Output current</b>	(A) see type table
<b>Output current adjustment range</b>	(%) 50 - 100 rectifier current limit 0 - 50 (battery charging current limit)
<b>Current accuracy</b>	(%) ± 2
<b>Characteristic</b>	■ in acc. (DIN 1177) ○ float and boost
<b>Boost voltage</b>	(VDC) 2.4 lead acid battery 1.55 NiCd battery
<b>Pilot voltage</b>	(VDC) 2.25 lead acid battery 1.40 NiCd battery
<b>Equalize voltage</b>	(VDC) 2.7 lead acid battery 1.7 NiCd battery
<b>Output Voltage adjustment range</b>	(%) ± 5 with reduced current
<b>Voltage accuracy</b>	(%) < 0.5
<b>Ripple</b>	(%) < 5 rms off without battery
<b>Efficiency</b>	(%) 85 - 94 % type dependent

<b>General data</b>	EN 61000-6-2, EN 61000-6-3
<b>EMC</b>	
<b>Rel. humidity</b>	(%) < 95 non condensing
<b>Audible noise</b>	(dB A) - 65 measured at 1m distance and half rectifier height
<b>Installation height</b>	(m) max. 1000 above sea level (m) max. 2000 above sea level with decrease to 92 % nominal
<b>Cooling</b>	natural convection
<b>Ambient temperature</b>	(°C) 0 - 40 with 100 % I nominal 0 - 50 with 88 % I nominal
<b>Storage temperature</b>	(°C) - 20 to +70
<b>Cabinet protection</b>	IP 20 IEC60529
<b>Cabinet</b>	Steel frame four standing cabinet, front door with double bit lock
<b>Paint finish</b>	RAL 7035
<b>Wet free alarm</b>	structured powder coating
<b>Options</b>	mains failure battery voltage low common alarm
<b>Interfaces</b>	M100 Bus Profibus additional relaycontacts
<b>Higher IP protection</b>	
<b>Counteracts</b>	
<b>Analogue measuring instruments</b>	
<b>Additional monitoring components</b>	

Cabinet type table	Dimensions (mm)		
	H	W	D
WIZ 755	758	534	470
PSJ 1564	1500	600	400
UC/PSJ 1566	1500	600	600
UC/PSJ 1866	1800	600	600
PSJ 1896	1800	900	600
PSJ 2288	2200	800	800
PSJ 221208	2200	1200	800

WIZ - wall mounted cabinet  
PSJ - floor standing cabinet  
UC/PSJ - floor standing cabinet



**BENNING worldwide**

**Austria**  
Benning GmbH  
Elektronik und Elektronik  
Edmund-Klinger-Str. 9  
34723 ST. ANTON-IM-RODERM  
Tel.: +43 (0) 22 42/3 24 16-0  
Tel.: +43 (0) 22 42/3 24 23  
E-mail: info@benning.at

**Belarus**  
ООО БЕННИНГ  
d. Belomorskaya, 51-25  
22025, MESTI, REPUBLIC BELARUS  
Tel.: +375 (0) 1 62 97 47 82  
Tel.: +375 (0) 1 62 97 33 77  
E-mail: info@benning.by

**Belgium**  
Benning Belgium  
Power Electronics  
Kortrijksesteenweg 47  
1740 TERBIELEN  
Tel.: +32 (0) 5 82 87 85  
Tel.: +32 (0) 5 82 87 89  
E-mail: info@benning.be

**Canada**  
Benning Power Electronics Sp. z o.o.  
Koncambina 30  
05-503 GLOSOW  
Tel.: +48 (0) 22 77 57 84 53  
Tel.: +48 (0) 22 77 57 84 52  
E-mail: benning@benning.pl

**China**  
P. R. China  
Benning Power Electronics (Shanghai) Co., Ltd.  
Tongzhou Industrial Development Zone  
1-8 Bulei Street  
101113 BEIJING  
Tel.: +86 (0) 10 61 56 85 88  
Tel.: +86 (0) 10 61 50 62 00  
E-mail: info@benning.cn

**Czech Republic**  
Benning CZ s.r.o.  
Závodní ul. 894  
253 06 KOLÍN  
Pobytí (Boskovice)  
Tel.: +420 (3) 26 72 10 03  
Tel.: +420 (3) 26 72 25 33  
E-mail: info@benning.cz

**France**  
Benning France  
Commissariat de Benning  
41, avenue Winston Churchill  
8.P. 418  
27404 LOUVERNS CEDEX  
Tel.: +33 (0) 2 32 25 23 94  
Tel.: +33 (0) 2 32 25 13 85  
E-mail: info@benning.fr

**Germany**  
Benning Elektronik und Elektronik  
GmbH & Co. KG  
Factory E, Mönsterstr. 135-137  
Factory E, Robert-Bosch-Str. 20  
46397 BOCHUM  
Tel.: +49 (0) 28 77 93 0  
Tel.: +49 (0) 28 77 93 397  
E-mail: info@benning.de

**Greece**  
Benning Power Electronics (UK) Ltd.  
Oakley House  
Empire Way  
Barnsley  
S70 4JW  
Tel.: +44 (0) 114 9 71 15 08  
Tel.: +44 (0) 114 9 71 15 08  
E-mail: info@benning.com

**Hungary**  
Benning Kft.  
Power Electronics  
Rákosd út 145  
2541 LÁBATLAK  
Tel.: +36 (0) 33 50 70 00  
Tel.: +36 (0) 33 50 75 01  
E-mail: benning@med.hu

**Italy**  
Benning Conversione di Energia S.r.l.  
Via 2 Giugno 1946, 8/B  
40037 CASALECCHIO DI RENZO (BO)  
Tel.: +39 051 75 88 00  
Tel.: +39 051 75 88 55  
E-mail: info@benningitalia.com

**Netherlands**  
Benning NL  
Power Electronics  
Kortrijksesteenweg 47  
1740 TERBIELEN  
Tel.: +31 (0) 30 16 24 60 10  
Tel.: +31 (0) 30 16 24 60 20  
E-mail: info@benning.nl

**Poland**  
Benning Power Electronics Sp. z o.o.  
Koncambina 30  
05-503 GLOSOW  
Tel.: +48 (0) 22 77 57 84 53  
Tel.: +48 (0) 22 77 57 84 52  
E-mail: benning@benning.pl

**P. R. China**  
Benning Power Electronics (Shanghai) Co., Ltd.  
Tongzhou Industrial Development Zone  
1-8 Bulei Street  
101113 BEIJING  
Tel.: +86 (0) 10 61 56 85 88  
Tel.: +86 (0) 10 61 50 62 00  
E-mail: info@benning.cn

**Russian Federation**  
Benning Power Electronics  
3 Sim'y Sverdlyha str.  
03148 KYIV  
Tel.: +380 (0) 44 75 01 46 45  
Tel.: +380 (0) 44 75 01 49  
E-mail: info@benning.ua

**USA**  
Benning Power Electronics, Inc.  
12201 Riverwood Drive  
IRVING, TEXAS 75061  
Tel.: +1 214 533 14 44  
Tel.: +1 214 533 13 85  
E-mail: sales@benning.us

**Sweden**  
Benning Sweden AB  
Box 881, Högskoleväg. 3B  
19159 SÖLLENTUNA  
Tel.: +46 (0) 8 76 23 95 00  
Tel.: +46 (0) 8 76 97 72  
E-mail: power@benning.se

**Switzerland**  
Benning Power Electronics GmbH  
Industriestrasse 6  
8305 OBERLINDEN  
Tel.: +41 (0) 44 8 05 75 75  
Tel.: +41 (0) 44 8 05 75 60  
E-mail: info@benning.ch

**Turkey**  
Benning GmbH Turkey Liaison Office  
19 Mayıs Mh. Kurşun Sokak No:16/A  
34738 KURTULUŞ  
Ankara / TÜRKİYE  
Tel.: +90 (0) 312 16 44 57 14 7  
Tel.: +90 (0) 312 16 44 57 14 7  
E-mail: b.diler@benning.com.tr

**Ukraine**  
Benning Power Electronics  
3 Sim'y Sverdlyha str.  
03148 KYIV  
Tel.: +380 (0) 44 75 01 46 45  
Tel.: +380 (0) 44 75 01 49  
E-mail: info@benning.ua

**UK**  
Benning Power Electronics, Inc.  
12201 Riverwood Drive  
IRVING, TEXAS 75061  
Tel.: +1 214 533 14 44  
Tel.: +1 214 533 13 85  
E-mail: sales@benning.us

**Slovenia**  
Benning Slovenija, s.r.o.  
Kobalnikova 17  
SI 100 BRATISLAVA  
Tel.: +421 (0) 2 14 45 99 42  
Tel.: +421 (0) 2 14 45 90 05  
E-mail: benning@benning.si

www.benninguk.com • www.benning.us  
www.benning.de



# MCU 2500 Monitoring and Control System for Telecoms and Industry

**Monitoring and Control System MCU 2500**  
The quantity of IT and telecommunication equipment with related AC and DC power systems has increased dramatically during recent decades.

To handle this rapid growth whilst maintaining system reliability in the face of operation and service cost cutting, power monitoring and control solutions are required. BENNING's microprocessor based monitoring and control system MCU 2500 offers a user friendly and flexible solution for the integration of AC and DC power systems into a network management system. A great number of MCU 2500 systems are already operating in telecommunication and industrial power systems all over the world.




Fig. 1. modular recitifier with MCU 2500



### MCU 2500 Features

- Flexible and modular monitoring and control system for AC and DC power solutions
- Front panel with graphic display and keypad for local operation, RS 232 interface for PC connection
- Remote monitoring and control via modem, Ethernet, WEB or SNMP
- The analysis of critical system parameters and alarm events allows quick and efficient service and maintenance activities
- Local and remote battery management optimises the availability and service life of system batteries
- Free configuration of alarm relays
- Digital inputs for monitoring of external site equipment (air-conditioning etc.)
- Integrated data logger stores up to 131070 events
- Messages are date and time stamped

The MCU 2500 provides local monitoring and control of power systems via a keypad and LCD or remote operation via modem, Ethernet or TCP/IP--WEB-adaptor.

Local operation of the MCU 2500 is available via the front door mounted monitoring and operation panel with LCD and push buttons. Local operation is also possible from a standard PC using the Windows-based BENNING monitor/service software.

Password protection guards against unauthorized access.

The capabilities of the MCU 2500 with remote monitoring and control and real-time feedback of critical system parameters and alarm events, helps to cut service and maintenance costs as service engineers can resolve problems on site quicker and more efficiently.

# BENNING

World Class Power Solutions

Eliminating Technology, Efficiency and Quality



Remote Monitoring System

## Modular Design allows flexible Solutions and easy Maintenance


The modular design of the MCU 2500

The MCU 2500 consists of the following modules:

**1 Base module**

The base module (the heart of the complete MCU system) is connected to the power modules (rectifiers, inverters or DC converters), the measurement and monitoring modules, the operation and monitoring panel and the LED monitoring card.

Interface components for remote operation such as TCP/IP, Adapter, modem or PC are also connected to the base module. The standard base module contains a data logger which can store up to 131070 measurements (current, voltage, and temperature) or alarm/event logs with time and date stamp.




**2 Monitoring and operation panel with LCD display, 4 push buttons and 4 LED's**

The front door mounted monitoring and operation panel enables local operation of the power system via either the keyboard and LCD or from a standard PC equipped with the BENNING service software.

An RS 232 C cable connects the PC to the RS 232 interface of the MCU 2500 base module.

**3 LED monitoring card**

The LED monitoring card is mounted on the front door and contains 13 configurable LED's to indicate additional alarms or other events.



**3 LED monitoring card**

**Measurement and monitoring modules**

The following DIN rail mountable modules extend the functionality of the base module.

To optimise the length of measurement cables the mounting position of the measurement modules should be near the measurement points.

**4 RELI0-module**

The RELI0-module is available in two versions:

- Version 1 with 4 volt-free relay contacts and 8 digital inputs
- Version 2 with 2 volt-free relay contacts, 8 digital inputs and 2 powered outputs

The powered outputs are designed to operate low power contactors (maximum 80 V).

**5 TUI0-module**

The TUI0-module incorporates 4 analogue inputs to measure:

- 1 DC voltage (0 up to 320 V DC), 2 DC current (0 up to 110 mA), 1 Temperature (-30°C up to 80°C).

Accuracy of all measurements: ±1%.

## Extended Functionality with external Monitoring and Measurement Modules

**6 BATT5 module**

The BATT5 module provides battery symmetry testing. With five measurement inputs the BATT5 module can test 5 x 12 V battery blocks (60 V battery) or 4 x 12 V battery blocks (48 V battery). Mid point measurement of single 48 V or 60 V batteries is also possible. A special BATT5 module is available for 110V or 220V batteries. (see page 7, fig. A and B)

**7 MAC module**

The MAC module measures the AC phase voltages of a single phase, two phase or three phase AC mains.

**8 SAT-relay module**

The SAT-relay module contains 8 volt-free relay contacts.


**9 SAT-Measurement module**

This module can have 5 different voltage, current or temperature measurement inputs (ie. 3 current, 1 voltage and 1 temperature input).


**10 Digital SAT input module**

This module has 24 configurable digital inputs (24V).

**DC-Power Supply**



**2 Monitoring and operation panel**



**1 Base module**

**4 RELI0-module**

**5 TUI0-module**

**6 BATT5 module**

**7 MAC module**




## MCU 2500 features Comprehensive and Clear Monitoring Functions

### Remote operation and monitoring of power systems


To ensure real time feed back of critical system parameters and alarm events, DC or AC power systems need to have power full and intelligent remote monitoring solutions. The advanced monitoring and management system MCU 2500 ensures quick and efficient service and preventive maintenance. Battery availability testing detects battery problems at an early stage and can help avoid a battery or system break down. The analysis of critical power system alarms helps to optimize service activities and saves cost.

### The following solutions are available for remote monitoring and operation

1. Modem operation using standard - or ISDN telephone line  
Connection of the power system to the public telephone network is achieved via an analog or digital high-speed-modem. Modems are available from BENNING.
2. Operation via serial Ethernet adapter  
for connection to a computer network.
3. Operation with TCP/IP-Web adapter  
allows Internet communication or SNMP-traps.



## Global Remote Monitoring via HTTP and TCP/IP Server



### Remote monitoring and control center

The universal remote communication capabilities of the MCU 2500 are the basis for the operation of the technical monitoring and control center at BENNING.

The control center monitors customer locations 24h a day and 365 days a year. Besides BENNING power systems the MCU 2500 allows the remote monitoring of customer products like air conditioning equipment or fire alarm systems.

The engineering staff at BENNING's remote monitoring center analyse all incoming messages and alarms regarding relevant customer locations and manage all necessary service activities. Repair times depend on the fault status-system critical or non-critical. System critical problems should be resolved as quickly as possible, typically 4 to 6 hours after the critical alarm was identified by the control center.

## Comprehensive Battery Management Maximises Service Life and System Availability

The most important measurement, operation and alarm events of the MCU 2500  
When used with a battery assisted power supply system, the MCU 2500 provides the following measurement, status and alarm information.

**Measurements:**

- System output voltage
- System output current
- System temperature
- Load current
- Max load power
- Battery charge voltage
- Battery current
- Battery temperature
- Battery test information






Fig. 2. Monitoring and control unit

**Battery monitoring 110 V - 220 V:**  
This battery monitor incorporates 3 inputs. Two of them are used to enable a battery mid point measurement. This battery monitoring module can also operate as fuse monitoring. (Fig. A and B)



### BENNING worldwide

- Austria**  
Benning GmbH  
Elektrotechnik und Elektronik  
Eduard-Mayer-Str. 9  
3423 ST. ANRHA-WIRGERN  
Tel.: +43 (0) 22 42/3 24 16-0  
Tel.: +43 (0) 22 42/3 24 23  
E-mail: info@benning.at
- Belarus**  
ООО БЕЛВЭТ  
д. Міннава, 51-25  
ЗАКЛ. ВЭС1, РЕПУБЛІКА БЕЛАРУСЬ  
Тэл.: +375 (0) 182/97 47 82  
Факс: +375 (0) 182/93 33 77  
E-mail: info@benning.belarus
- Belgium**  
Benning Belgium  
Power Electronics  
Z. Z. Eschenschacht 16  
1740 TERHAT  
Tel.: +32 (0) 2/5 82 87 65  
Tel.: +32 (0) 2/5 82 87 69  
E-mail: info@benning.be
- Croatia**  
Benning Zagreb d.o.o.  
Trpinjska 61  
10000 ZAGREB  
Tel.: +385 (0) 1/6 31 22 80  
Tel.: +385 (0) 1/6 31 22 89  
E-mail: info@benning.hr
- Czech Republic**  
Benning CR s.r.o.  
Záhradní ul. 894  
250 06 KUSOVAROVSKÝ  
(Praha - Břevnov)  
Tel.: +420 227 72 23 33  
E-mail: info@benning.cz
- France**  
Benning  
conversion G Energie  
43, avenue Winston Churchill  
B.P. 418  
27404 LOUVERNS CEDEX  
Tel.: +33 (0) 2/32 25 23 94  
Tel.: +33 (0) 2/32 25 13 95  
E-mail: info@benning.fr
- Germany**  
Benning Elektrotechnik und Elektronik  
GmbH & Co. KG  
Factory 1: Mühlentw. 135-137  
Factory 2: Robert-Roach-Str. 20  
48397 BUCHHOLT  
Tel.: +49 (0) 28 71/183-0  
Tel.: +49 (0) 28 71/19 32 97  
E-mail: info@benning.de
- Great-Britain**  
Benning Power Electronics (UK) Ltd.  
Galley House  
Hopwood Lane  
Fleethamstead  
BEDFORDSHIRE  
RG 40 4TW  
Tel.: +44 (0) 118/9 73 15 08  
Tel.: +44 (0) 118/9 73 15 08  
E-mail: info@benning.uk.com
- Hungary**  
Benning Ltd.  
Power Electronics  
Pálaföldi út 145  
2041 LAZAROVÁ  
Tel.: +36 (0) 33/50 78 00  
Tel.: +36 (0) 33/50 78 01  
E-mail: benning@net.hu
- Italy**  
Benning Conversion G Energie S.L.L.  
Via G. Cesare 1948, 68  
40053 CASALECCHIO (REMO) (BO)  
Tel.: +39 (0) 51/75 88 00  
Tel.: +39 (0) 51/6 16 78 53  
E-mail: info@benningitalia.com
- Netherlands**  
Benning NV  
Power Electronics  
Peppelkade 42  
3972 AK HOUTEN  
Tel.: +31 (0) 30/8 34 60 20  
E-mail: info@benning.nl
- Poland**  
Benning Power Electronics Sp. z o.o.  
Korczakowa 30  
05-500 BŁYSZCZÓW  
Tel.: +48 (0) 22/75 74 53  
Tel.: +48 (0) 22/75 74 52  
E-mail: benning@benning.pl
- P.R. China**  
Benning Power Electronics (Beijing) Co., Ltd.  
Yongshou Industrial Development Zone  
30148 XINYI  
Tel.: +86 (0) 10/51 50 14 05  
Tel.: +86 (0) 10/51 56 85 83  
E-mail: info@benning.cn
- Russian Federation**  
Benning Power Electronics, Inc.  
1220 Presidential Drive  
HOCHAMUSON, TEXAS 75081  
Tel.: +1214/53 14 44  
Tel.: +1214/53 13 55  
E-mail: sales@benning.us
- Spain**  
Benning Power Electronics S.L.  
RS, Doki Lane 10  
405-00  
SINGAPORE 328216  
Tel.: +65 788 44 31 33  
Tel.: +65 788 44 32 78  
E-mail: sales@benning.com.sg
- South East Asia**  
Benning Power Electronics Pte Ltd  
RS, Doki Lane 10  
405-00  
SINGAPORE 328216  
Tel.: +65 788 44 31 33  
Tel.: +65 788 44 32 78  
E-mail: sales@benning.com.sg
- Sweden**  
Benning Comercio de Energia S.A.  
P.O. Box 100, Santa Catalina 2  
PA 101  
98070 IBERPASE (MADRID)  
Tel.: +34 91/6 04 81 10  
Tel.: +34 91/6 04 81 02  
E-mail: benning@benning.es
- Switzerland**  
Benning Power Electronics GmbH  
Industriestrasse 6  
8305 DRELLIMON  
Tel.: +41 (0) 41/8 05 75 75  
Tel.: +41 (0) 41/8 05 75 80  
E-mail: info@benning.ch
- Ukraine**  
Benning Power Electronics  
S. Chornobyl'skiy str.  
03148 KYIV  
Tel.: +380 (0) 44/5 01 40 45  
Tel.: +380 (0) 44/2 71 57 49  
E-mail: info@benning.ua
- U.S.A.**  
Benning Power Electronics, Inc.  
1220 Presidential Drive  
HOCHAMUSON, TEXAS 75081  
Tel.: +1214/53 14 44  
Tel.: +1214/53 13 55  
E-mail: sales@benning.us

www.benning.de



**BENNING**






BENNING WORLD CLASS POWER SOLUTIONS

# THYROTRONIC - СЕРИЯ ВЫПРЯМИТЕЛЕЙ для систем гарантированного электроснабжения со стационарными аккумуляторными батареями

## Общие

Защита потребителей электроэнергии от аварий электроснабжения часто осуществляется переходом на питание от резервной аккумуляторной батареи, при этом ответственные потребители снабжаются электрической энергией постоянного напряжения как при наличии напряжения сети так и при его аварии.

Excellent Technology, Efficiency and Quality



## Выпрямители

серии THYROTRONIC для систем гарантированного электроснабжения со стационарными аккумуляторными батареями

## Общие

Защита потребителей электроэнергии от аварий электроснабжения часто осуществляется переходом на питание от резервной аккумуляторной батареи, при этом ответственные потребители снабжаются электрической энергией постоянного напряжения как при наличии напряжения сети так и при его аварии.




Рис.1 Внешний вид выпрямителя Thyrotronic

Системы гарантированного электроснабжения постоянного тока с параллельным резервированием стационарными аккумуляторными батареями используются на протяжении последних десятилетий и зарекомендовали себя как высоко надежные и оправданное по экономическим затратам резервное электроснабжение.

Нужность систем гарантированного электроснабжения постоянного тока с использованием параллельного резервирования стационарными аккумуляторными батареями определяется как качеством аккумуляторной батареи так и безопасной работой выпрямителя.

Серия выпрямителей Thyrotronic, разработанная компанией Вейпинг (см. Рис. 1), предназначена для построения систем гарантированного электроснабжения постоянного тока с параллельным резервированием стационарными аккумуляторными батареями и предладегт, наряду с высокой надежностью, всестороннюю опциональную мониторинга и контроль.

Выпрямители серии Thyrotronic работают в соответствии с регулируемой электронной образцов характеристикой выходного постоянного напряжения (ИУ-характеристика в соответствии с DIN41773), (см. Рис. 3).

Нестабильность выходного напряжения составляет  $\pm 0,5\%$  при изменении потребляемого тока нагрузки от 0% до 100%.

Допустимый диапазон отклонений напряжения сети  $\pm 10\%$ , частоты  $\pm 5\%$ . Как резервный источник электроэнергии используются преимущественно стационарные протитварованные или малобатареивые свинцово-кислотные батареи. Нисель-кадмиевые щелочные батареи рекомендуются использовать при экстремальных условиях окружающей среды.

## Область применения систем

- электрические станции
- трансформаторные подстанции
- железнодорожный транспорт
- транспортное, переработка нефти и газа
- аэропорты
- больницы и лечебные заведения

## ТИПОВАЯ ТАБЛИЦА СЕРВИИ TNUOTRONIC Выпрямители для многоцелевого применения

Выходная мощность, Вт	Минимум	Максимум	Выходная частота, кГц	Тем. устройства	Входное напряжение, В	Выходное ток, А	Тем. шифра	Вес, кг	
									В
24	12	20	20	E 230 G 24 / 20	ВНУТР-10G	230	4,5	WZ 755	30
24	12	20	40	E 230 G 24 / 40	ВНУТР-10G	230	9,2	WZ 755	40
24	12	20	60	E 230 G 24 / 60	ВНУТР-10G	230	13,5	UC 1566	60
24	12	20	80	E 230 G 24 / 80	ВНУТР-10G	230	17,8	UC 1566	75
24	12	20	100	0 400 G 24 / 100	ВНУТР-10G	3 400	5,5	UC 1566	150
24	12	20	125	0 400 G 24 / 125	ВНУТР-10G	3 400	6,6	UC 1566	200
24	12	20	160	0 400 G 24 / 160	ВНУТР-10G	3 400	8,7	UC 1566	240
24	12	20	200	0 400 G 24 / 200	ВНУТР-10G	3 400	10,8	UC 1566	280
24	12	20	300	0 400 G 24 / 300	ВНУТР-10G	3 400	19,0	UC 1866	400
24	12	20	400	0 400 G 24 / 400	ВНУТР-10G	3 400	24,3	PSJ 1936	510
48	24	40	10	E 230 G 48 / 10	ВНУТР-10G	230	4,6	WZ 755	30
48	24	40	20	E 230 G 48 / 20	ВНУТР-10G	230	9,1	WZ 755	40
48	24	40	30	E 230 G 48 / 30	ВНУТР-10G	230	12,3	UC 1566	60
48	24	40	40	E 230 G 48 / 40	ВНУТР-10G	230	16,3	UC 1566	75
48	24	40	50	0 400 G 48 / 50	ВНУТР-10G	3 400	5,8	UC 1566	145
48	24	40	60	0 400 G 48 / 60	ВНУТР-10G	3 400	6,8	UC 1566	180
48	24	40	80	0 400 G 48 / 80	ВНУТР-10G	3 400	8,7	UC 1566	220
48	24	40	100	0 400 G 48 / 100	ВНУТР-10G	3 400	10,8	UC 1566	270
48	24	40	125	0 400 G 48 / 125	ВНУТР-10G	3 400	13,1	UC 1566	340
48	24	40	160	0 400 G 48 / 160	ВНУТР-10G	3 400	17,1	UC 1866	400
48	24	40	200	0 400 G 48 / 200	ВНУТР-10G	3 400	21,9	UC 1866	400
48	24	40	300	0 400 G 48 / 300	ВНУТР-10G	3 400	37,0	UC 1866	500
48	24	40	400	0 400 G 48 / 400	ВНУТР-10G	3 400	44,0	PSJ 1836	600
60	30	50	10	E 230 G 60 / 10	ВНУТР-10G	230	5,1	WZ 755	30
60	30	50	20	E 230 G 60 / 20	ВНУТР-10G	230	10,1	WZ 755	40
60	30	50	30	E 230 G 60 / 30	ВНУТР-10G	230	14,5	UC 1566	60
60	30	50	40	E 230 G 60 / 40	ВНУТР-10G	230	20,4	UC 1566	75
60	30	50	50	0 400 G 60 / 50	ВНУТР-10G	3 400	6,8	UC 1566	150
60	30	50	60	0 400 G 60 / 60	ВНУТР-10G	3 400	8,1	UC 1566	220
60	30	50	80	0 400 G 60 / 80	ВНУТР-10G	3 400	10,8	UC 1566	280
60	30	50	100	0 400 G 60 / 100	ВНУТР-10G	3 400	13,5	UC 1566	300
60	30	50	125	0 400 G 60 / 125	ВНУТР-10G	3 400	17,1	UC 1566	350
60	30	50	160	0 400 G 60 / 160	ВНУТР-10G	3 400	21,7	UC 1566	400
60	30	50	200	0 400 G 60 / 200	ВНУТР-10G	3 400	28,5	UC 1866	420
60	30	50	300	0 400 G 60 / 300	ВНУТР-10G	3 400	40,5	UC 1866	520
60	30	50	400	0 400 G 60 / 400	ВНУТР-10G	3 400	53,0	PSJ 1836	620
108	54	90	5	E 230 G 108 / 5	ВНУТР-10G	230	4,9	WZ 755	30
108	54	90	10	E 230 G 108 / 10	ВНУТР-10G	230	9,8	UC 1566	40
108	54	90	16	E 230 G 108 / 16	ВНУТР-10G	230	13,2	UC 1566	60
108	54	90	25	0 400 G 108 / 25	ВНУТР-10G	3 400	6,5	UC 1566	75
108	54	90	30	0 400 G 108 / 30	ВНУТР-10G	3 400	7,5	UC 1566	95
108	54	90	40	0 400 G 108 / 40	ВНУТР-10G	3 400	10,0	UC 1566	100
108	54	90	50	0 400 G 108 / 50	ВНУТР-10G	3 400	12,9	UC 1566	220
108	54	90	60	0 400 G 108 / 60	ВНУТР-10G	3 400	14,7	UC 1566	250
108	54	90	80	0 400 G 108 / 80	ВНУТР-10G	3 400	20,0	UC 1566	330
108	54	90	90	0 400 G 108 / 90	ВНУТР-10G	3 400	24,7	UC 1566	400
108	54	90	125	0 400 G 108 / 125	ВНУТР-10G	3 400	31,5	UC 1566	450
108	54	90	160	0 400 G 108 / 160	ВНУТР-10G	3 400	40,9	UC 1866	500
108	54	90	200	0 400 G 108 / 200	ВНУТР-10G	3 400	50,0	PSJ 1836	520
108	54	90	300	0 400 G 108 / 300	ВНУТР-10G	3 400	70,0	PSJ 1836	650
108	54	90	400	0 400 G 108 / 400	ВНУТР-10G	3 400	100,0	PSJ 2268	1100
216	108	180	5	E 230 G 216 / 5	ВНУТР-10G	230	9,4	WZ 755	40
216	108	180	10	0 400 G 216 / 10	ВНУТР-10G	3 400	5,1	UC 1566	60
216	108	180	16	0 400 G 216 / 16	ВНУТР-10G	3 400	6,9	UC 1566	120
216	108	180	25	0 400 G 216 / 25	ВНУТР-10G	3 400	12,4	UC 1566	266
216	108	180	30	0 400 G 216 / 30	ВНУТР-10G	3 400	15,2	UC 1566	266
216	108	180	40	0 400 G 216 / 40	ВНУТР-10G	3 400	21,0	UC 1566	400
216	108	180	50	0 400 G 216 / 50	ВНУТР-10G	3 400	25,2	UC 1566	400
216	108	180	60	0 400 G 216 / 60	ВНУТР-10G	3 400	30,5	UC 1566	450
216	108	180	80	0 400 G 216 / 80	ВНУТР-10G	3 400	40,0	UC 1566	500
216	108	180	100	0 400 G 216 / 100	ВНУТР-10G	3 400	50,0	PSJ 1836	620
216	108	180	125	0 400 G 216 / 125	ВНУТР-10G	3 400	63,0	PSJ 1836	770
216	108	180	160	0 400 G 216 / 160	ВНУТР-10G	3 400	81,0	PSJ 1836	800
216	108	180	200	0 400 G 216 / 200	ВНУТР-10G	3 400	100,0	PSJ 2268	1050
216	108	180	300	0 400 G 216 / 300	ВНУТР-10G	3 400	152,0	PSJ 221208	1300
216	108	180	400	0 400 G 216 / 400	ВНУТР-10G	3 400	203,0	PSJ 221208	1600

Иллюстрации являются лишь примерами и не являются окончательными. Другие типы устройств по отдельному запросу.



## ТНУОТРОНИК Серия выпрямителей для многоцелевого применения

**Функционирование**  
Самовосстанавливающиеся и инвель-сармерные выходные батареи достигают оптимального срока службы благодаря в зависимости от состояния при длительной подзарядке. В процессе работы в подогретой в параллель аккумуляторной батареи выпрямитель одновременно осуществляет питание потребителей и заряжает батареи. Электронная энергия аккумуляторной батареи используется только при аварии на входе сети или в случае пиковых нагрузок, превышающих номинальную мощность выпрямителя. Этот режим работы определяется как «параллельная работа» либо «параллельное резервирование» (см.рис. 2). При глубоком разряде батареи выпрямитель работает сначала в области I (превышение тока) характеристика

III, при этом зарядный ток определяется как разница между номинальным током выпрямителя и током потребителей. При достижении установленного высокого напряжения (напряжения длительного подзарядки) происходит переход к заряду постоянным напряжением - область II (см.рис. 3)

Для увеличения времени зарядки аккумуляторных батарей либо для тремперовых зарядок, в выпрямителе предусмотрена усовершенствованная (выравнивающая) зарядка. Переключение с режима длительного подзарядки осуществляется с помощью кнопки (содержимая, 2,23 В/ для самовосстанавливающейся батареи) и режима усоренного заряда (2,4 В/ для самовосстанавливающейся батареи) происходит в ручном режиме либо автоматически в зависимости от напряжения аккумуляторной батареи




Рис.2. Режим электронной параллельной работы

и времени разряда. Полностью заряженная батарея в режиме «параллельной работы» потребляет ток непрерывно с мощностью примерно от 0,3 мА до 1 мА на 1 АА емкости для конденсаторов внутренних батарей. Емкость аккумуляторной батареи определяется временем резервного электроснабжения. На время резервного электроснабжения также влияет величина нагрузки и качество сетей электроснабжения.

**Типовые периоды времени для резервного электроснабжения в зависимости от вида нагрузки и качества сетей электроснабжения**

- 10 - 30 минут
- электронная обработка данных
- аварийное освещение
- технологические процессы
- железнодорожный транспорт
- аэропорты
- больницы
- 2 - 8 часов
- связь
- транспортирование, переработка нефти и газа




Рис.3. Характеристики IU согласно DIN 41 773 для самовосстанавливающейся батареи

безопасность, надежность, производительность

**Серия Thyrotronics (Пиротроник)**  
В состав выпрямителя серии Thyrotronics входит два основных компонента - трансформаторно-управляемая (силовая) часть и микропроцессорный блок управления и контроля.

**Основные компоненты выпрямителя:**

- Сетевой ввод с защитными контакторами
- Сетевой трансформатор с разделительными обмотками
- 6 импульсная управляемая микропроцессором трансформаторная схема с защитным быстродействующим предохранителем (для защиты от подключения аккумуляторной батареи неправильной полярности)
- Стабилизирующий дроссель и конденсаторная батарея для стабилизации остаточных пульсаций
- Регулятор с цифровой установкой рабочих параметров
- Устройство цифрового контроля
- Панель управления и индикации с графическим ЖКИ на передней двери (рис. 5)
- ИИ-разрядник с защитой плавкой вставки и цепи аккумуляторной батареи
- 2-х полюсный ИИ-разрядник с перемычками (плавкими вставками) в цепи нагрузки




Рис. 4. Вид основных компонентов выпрямителя Thyrotronics

**Панель управления и индикации (см.рис. 5)**  
Панель управления и индикации в составе с графическим ЖКИ (рис.5) имеет следующие функции:


• мониторинг, измеренных значений в текстовом виде

• возможность на передней двери выпрямителя. В состав панели входят:



• генерал управление и индикация также входит 17 светодиодных индикаторов, управляемых устройством цифрового контроля.

Панель клавиатура с жестко назначенными функциями клавиш интегрирована в блок ЖКИ, над клавишами расположены 4 основных светодиодных индикатора (см. ниже рисунок). Два свободных светодиодных индикатора могут быть присвоены к внешним сигналам (событиям).



всесторонняя концепция мониторинга и контроля

**Функции устройства цифрового контроля**  
Стандартно в выпрямителях серии Thyrotronics включена всесторонняя концепция мониторинга и контроля со следующими функциями:

**Контроль сети электроснабжения**  
При аварии напряжения сети трансформатор регулятор блокируется, выходной контактор выключается, при этом активируется сигнал «Неисправность сети» совместно с реле. «Неисправность сети». После восстановления напряжения сеть регулятор возобновляет автоматическую по истечению установленного времени.

**Контроль выходных параметров выпрямителя**  
Выходное напряжение выпрямителя в режиме работы с характеристикой I) зависит от величины выходного тока. Если выходное напряжение упадет ниже установленного порога 2,1 В/л и его выходной ток ниже 90% номинального, устройство контроля сообщает «Неисправность выпрямителя при этом активируется сигнал (сигналы) «Сигналы неисправности».

**Контроль температуры**  
Если выходное напряжение ниже установленных пределов, при этом становится недостаточным выходное (первое) значение устанавливается), в течение 20 секунд осуществляется импульсная загрузка трансформатора и в течение 20 секунд осуществляется контроль. Контроль температуры осуществляется в режиме работы с характеристиками I) и II) (рис. 5). Система контроля фиксирует перегревания и предельное время периода 20 секунд 4 раза и более, по сетевой цепи отключается, и активируется реле общей неисправности.

**Напряжение батареи слишком низкое**  
Если напряжение батареи при разряде (например, во время аварии напряжения сети) падает ниже уровня 1,8 В/л (пороговое значение устанавливается), посылается соответствующее сообщение «Батарея разряжена» и активируется реле общей неисправности.

**Проверка цепи батареи**  
Цель батареи системы электрооборудования тестируется циклически один раз каждые 24 ч. На время 5 секунд выходное напряжение выпрямителя снижается до 1,9 В/л и при этом батарея разряжается.

Одновременно контролируется напряжение батареи. Если оно остается выше 1,9 В/л - цепь батареи в порядке. Если оно опускается ниже предельного значения, выдает сообщение «Обрыв цепи батареи» - будет также активирован соответствующий световой и реле общей неисправности. - Внимание! Этот пункт не заменяет регулярные профилактические работы с аккумуляторной батареей!

**Тест емкости батареи**  
При teste емкости батареи такое как и при teste цепи батареи выходное напряжение выпрямителя снижается и батарея разряжается, однако батарея разряжается за заданное время до предельного низкого уровня. Эти значения зависят от разрядного тока, при этом подготавливается отдаленная емкость во время теста. Если при teste емкости будут достигнуты предельные значения, то на соответствующий

световое посылается сообщение «Тест Батарея отрицательный» и включается реле общей неисправности. По истечении теста выпрямитель автоматически переключается в режим содержащего заряд либо в режим содержащего либо усоренного заряда.

**Контроль замыкания на землю**  
При контроле замыкания на землю устройство цифрового контроля контролирует сопротивление изоляции выхода выпрямителя относительно земли. Шины плюса и минуса контролируются попеременно. При появлении сопротивления изоляции ниже установленного порога (регулируется от 100 Ом до 1 МОм) выдает сообщение на соответствующие световые и включаются реле общей неисправности.

**ГР Компенсация**  
При ГР компенсация может быть включена только при наличии на борту вольту выпрямителя и без ГР на выходе по заданной длине и полярности сигнала.

**Программируемая зарядная характеристика**  
Если аккумуляторная батарея заряжается, то при этом выдает сигнал, при котором регулятор работает в режиме зарядки. После достижения уровня заряда регулятор автоматически переключается в режим усоренного заряда (регулируемое напряжение) и выдает сигнал «Высокий уровень заряда». После достижения уровня заряда регулятор автоматически переключается в режим усоренного времени (от 0 до 8 час.)

**Выпрямитель автоматически переключается обратно в режим содержания. Автоматический заряд может выключаться, при этом возможно ручное переключение в режим усоренного заряда с клавиатуры панели управления и индикации.**

**Обратное переключение в режим содержания можно произвести только вручную. Если этого не сделать, регулятор автоматически переключается назад, как при активированной зарядной автоматике.**

**Переключение на усоренный заряд может блокироваться внешним контактом или жесткой перемычкой на регуляторе.**

**Режим выравнивания заряда**  
Режим выравнивания заряда может включаться с клавиатуры панели управления и контроля. При этом повышается выходное напряжение выпрямителя, но его ток не превышает 20% (настраивается в диапазоне от 10% - 30%). Происходит выравнивание заряда всех зарядов для ввода в эксплуатацию с характеристиками I) вплоть до конечного напряжения заряда батареи.

Одновременно с включением режима выравнивающего заряда запускается временной счетчик, по истечении запрограммированного времени (16 до 72 час.) выпрямитель автоматически переключается в режим содержания. Переключение в режим выравнивающего заряда может быть заблокировано внешним контактом или жесткой перемычкой на регуляторе.

**Распределение тока в режиме параллельной работы**  
При соединении выпрямителей внутренним интерфейсом, распределение выходного тока составляет  $\pm 10\%$ .

ВЛЯРНО  
ИДИНА




Handwritten signature



IEC 601/204  
EN 60950 / 60304  
VDE 0805 / 0113

Overcurrent protection and braking device  
in feeder required according to:  
Überstromschutzeinrichtungen und Trennvorrichtung  
in der Zuleitung erforderlich nach:




Rectifier on / off  
Gerät Ein / Aus

Rev.	Change	Date	Name	Approved
1				
2				
3				
4				
5				
6				
7				
8				
<b>BENNING</b>				
Rectifier D400G22B/16BWup-TDG-C				
112500.00E3 10A3				
Sheet	7	85		



ВЪРВНО С  
ОРИГИНАЛ

Date	21.10.2013
Drawn	KRUDH
Checked	AKJACH



Copyright as per ISO 15016 to be observed!

БЪРНО С  
СЪИГНАЛА



Rev.	Change	Date	Name	Approved	Checked	Drawn	Date
1		10.12.2013					
2							


Rectifier  
D400G22B/16BWhup-IDG-C

**BENNING**


112500.00E310A3

HP2

Sheet 2  
7 Sl.



Rev.	Change	Date	Name	Approved	Date	21.10.2013	Drawn	KADH	Date	2	Date	21.10.2013	Checked	AHAPH	Date	10.12.2013	Rev.	10	Date	10.12.2013	Sheet	7	Sh.	8			
BENNING										Rectifier D400G328/16BWlug-TDG-C										112500.00E310A3				HP2			



Rev.	Change	Date	Name
1			

Date	Drawn	Checked	Approved
21.10.2013	KMCH	MJUPH	

**BENNING**

Rectifier  
D400G22B/16BWhug-TDG-C

112500.00E310A3

HP2

Sheet 4  
7 SH





ВЪРНО С


Rev.	Change	Date	Name	Approved	Checked	Drawn	Date
1					ANAPH	IGORH	21.10.2013
<p>HP2</p> <p>112500.00E310A3</p>							
<p>Sheet 7 of 8</p>							

**BENNING**

Rectifier  
D400G228/168Wlug-TDG-C


LED Display

- H1 Float charging  
Erhaltungsladen
- H2 Boost charging / Equalizing charge  
Startladen / Ausgleichsladen
- H3 Battery test  
Batterietest
- H4 Mains failure  
Netzstörung
- H5 Equipment failure  
Gerätestörung
- H6 High DC voltage  
DC-Spannung zu hoch
- H7 Low battery voltage  
Batteriespannung zu tief
- H8 Battery test negative  
Batterietest negativ
- H9 Battery circuit fault  
Batteriekreis gestört
- H10 Earth fault  
Erdschluss
- H11 Battery symmetry failure  
Batteriesymmetrie gestört
- H12 Load voltage too high  
Verbraucherspannung zu hoch
- H13 Load voltage too low  
Verbraucherspannung zu tief
- S1 LED-Test / reset  
LED-Test / Reset



15.BA > 15  
WZ


-A31





Bohrdaten Fronttür  
aus Pos. 1

Shunte und Drossel Rückseite



**BENNING**

Rectifier  
D400G22B/16BWhUp-TDG-C

115771.00M150A3



HP2

Sheet 1  
1 SB

Rev.	Change	Date	Name	Approved	Checked	Date	Name	Checked	Date	Name
1		22.10.2013	KUCH			21.10.2013	KUCH		21.10.2013	KUCH
		23.09.2013	KUCH				AKUPH			





ВЪРНО С ОДРЪВ  
ОРИГИНАЛ



600  
500  
400  
300  
200  
100  
0

Cable entry  
Kabeleinführung



Degree of protection IP20  
Schutzart IP20

**BENNING**

Rectifier  
D400G228/168Wwg-TDG-C  
Dimension and front view drawing

115771.00M000A3

HP2

Sheet 1  
1 Sh.


Rev.	Change	Name	Date
1			

Date	Drawn	Checked	Approved
20.10.2013	IKT	KMOH	



*[Handwritten signature]*

400V 3ph 50Hz



Rev.	Change	Date	Name	Approved
1				

Date	21.10.2013
Drawn	KMCH
Checked	PMAPH
Approved	

Recifier	
D400G228/16BWlug-TDC-C	
<b>BENNING</b>	
109595.00EG28A3	HP2
Sheet 1	Sh 1

**ТЕХНИЧЕСКА СПЕЦИФИКАЦИЯ – УНИВЕРСАЛЕН ТРИСТОРЕН ТОКОНЗПРАВИТЕЛ 220V/25A**

с МИКРОПРОЦЕСОРНО УПРАВЛЕНИЕ и МОНИТОРИНГ – СЕРИЯ THYROTTRONIC LINE

Серията THYROTTRONIC LINE работи с микропроцесорно управляван тиристорен регулиращ блок *Thysat*, микропроцесорна система за мониторинг MCU 2500, батерен шунт, автоматичен диоден стабилизатор (двустепенна противоелементна група), TCP/IP адаптер с Modbus интерфейс за връзка със СКАДА.

THYROTTRONIC LINE има над 15 интегрирани функции на мониторинг и сигнализации за работното състояние, аномалиите и повредите, контрол на изходното напрежение към консуматорите и към батериите. Посредством PC през RS232 порт, или през менюто на лицевия цифрено-буквен дисплей може да се контролира състоянието на системата и да се променят базовите настройки- аларми и повреди, продължителност и честота за тестове на батерията, брой клетки, тип на АБ, стойност на подзарядното и зарядно напрежение, температурен коефициент, токоограничение, според типа на батерията – VRLA или Ni-Cd и според броя на елементите, и т.н.

<b>ПАРАМЕТРИ /ТИП НА ТОКОНЗПРАВИТЕЛЯ:</b>	<b>D400 G216/25 BWrg-TDG 3</b>
<b>Производител:</b>	<b>BENNING GmbH – Германия</b>
<b>Мрежов вход:</b>	
<b>Захранващо напрежение:</b>	<b>3 x 400V ±10%, трифазно, N, PE</b>
<b>Максимален захранващ ток:</b>	<b>12A при пълно натоварване</b>
<b>Мрежова честота:</b>	<b>50Hz ± 5%</b>
<b>Разделителен трансформатор на входа:</b>	<b>За галванична изолация от мрежата</b>
<b>Пуск:</b>	<b>Плавен старт с пълна автодиагностика</b>
<b>Изход на токонзправителя:</b>	
<b>Номинално изходно напрежение:</b>	<b>220V DC</b>
<b>Номинален изходен ток:</b>	<b>25A</b>

Стр. 1/8

"МАРПЕКС" ООД  
Бул. "Черен връх" №.67  
1407 София, ПК 2  
тел.: (02) 964-0840  
факс: (02) 964-0861

**Марпекс**

<b>Дименсии/Тегло:</b>	Стоманен шкаф – модел PSJ 1866 / H 1800 x W 600 x D 600mm / 220kg
<b>Клас на защита на шкафа / Боя:</b>	IP 30 IEC 60529 / RAL 7035
<b>Подзарядно напрежение (настройваемо):</b>	2,27V/кл. За Pb батерии / 1,40V/кл. За Ni-Cd батерии
<b>Напрежение на автоматичен ускорен заряд:</b>	2,40V/кл. За Pb батерии / 1,55V/кл. За Ni-Cd батерии
<b>Изравнително зареждане (ръчен режим):</b>	2,70V/кл. За Pb конвенционални батерии / 1,70V/кл. За Ni-Cd батерии
<b>Обхват на настройка на зарядното напрежение:</b>	± 5% от зададената стойност
<b>Стабилизация на изходното напрежение:</b>	± 0,5%
<b>Стабилизация на изходния ток:</b>	± 2%
<b>Ограничение на изходния ток:</b>	Inom
<b>Електронно ограничение при късо съединение:</b>	< 105% Inom
<b>Зарядна характеристика:</b>	IU по DIN 41773 с ограничение на зарядния ток до 1/10 Cnom
<b>Изглаждане на пулсациите на напрежението:</b>	< 5% rms / типично 2,5% rms (без свързана батерия)
<b>Изглаждане на пулсациите в тока:</b>	< 5% eff / типично 2% eff (без свързана батерия)
<b>Динамични характеристики (отделена батерия):</b>	± 5% измен. В Уизх. / след 200ms, при промяна в товара 100% – 20% – 100%/
<b>Фактор на мощността (cos φ):</b>	Приблизително 0,8 в режим на подзаряд при номинален товар
<b>Коефициент на полезно действие:</b>	От 90% до 95% при натоварване от 50% до 100%
<b>Относителна влажност:</b>	Приблизително 95%, без кондензация
<b>Технически норми и стандарти:</b>	Актуалните DIN, VDE стандарти, EN50081-1, EN50082-2, IEC146-1-1, 204-1
<b>Подтискане на високочестотни смущения EMC:</b>	Съгл. EN610006-2, EN610006-3
<b>Работна температура:</b>	0 °C до +40 °C
<b>Клас на влажност:</b>	"F" по DIN 40040
<b>Ниво на акустичния шум:</b>	макс. 60dB (A)
<b>Надморско равнище за инсталиране:</b>	Макс. 1000 м – 100% номинален товар / макс 2000м – 92% номинален товар
<b>Охлаждане:</b>	Естествена конвекция

Проект: "Мини Марица Изток"

ВЯРНО С  
ОРИГИНАЛА



Стр. 2/8

<b>ЛИЦЕВ ПАНЕЛ НА ШКАФА</b>	
Интегриран буквено-цифров LCD-дисплей с реален текст и мониторинг юнит MCU 2500:	изходен ток, изходно напрежение, ток на акумулаторната батерия, с реален текст на работното състояние, повреди, меню и rapopти
Клавиатура с 4 клавиша:	За въвеждане и/или четене на данни и параметри, промяна на настройките
Светодиоди (СД) за фиксирани функции-4 броя:	нормална работа режим на разряд на батерията непешна повреда спешна повреда
Светодиоди (СД) за работното състояние-13 бр.	подзаряд подзаряд/ускорен заряд тест на батерията липса на мрежово захранване (1 или повече фази) повреда на устройството високо изходно напрежение ниско батерийно напрежение прекъсване и несиметрия на батерийната верига отрицателен батерийен тест земно съединение в положителния клон земно съединение в отрицателния клон високо DC напрежение към консуматорите ниско DC напрежение към консуматорите
<b>ИНТЕГРИРАНИ ФУНКЦИИ посредством MCU 2500:</b>	
Пряк мониторинг:	мрежов мониторинг мониторинг на изхода на токoнзправителя токово-зависим мониторинг за ниско изходно напрежение мониторинг за високо изходно напрежение с импулсно блокиране мониторинг за ниско батерийно напрежение периодичен тест на батерийната верига периодичен кондензитивен батерийен тест

	мониторинг за наличие на земно съединение температурна корекция на подзарядното напрежение + температурен датчик I x R компенсация на спада на напрежението върху батерията програмируемо автоматично зареждане (подзаряд/ускорен заряд) фаза на изравнителен заряд индикация на работния режим възможност за паралелна работа без декупиращи диоди надуерна базова настройка в случай на повреда в процесора RS232 интерфейс за връзка с PC 8 цифрови порта за външни функции на мониторинг
Дистанционен мониторинг посредством безпотенциални контакти (стандартни):	Липса на мрежа или 1 фаза, мрежово напрежение/честота извън толеранс, обща аларма (за обща повреда); ниско напрежение на батерията
Допълнителна реле платка за дист. мониторинг:	С 8 безпотенциални сигнала за дистанционен мониторинг на всички повреди
Звукова сигнализация:	При повреда или аномалии на системата ТИ-АБ
Пренос на данни за работното състояние на системата ТИ-АБ, за повреди или аномалии:	TCP/IP адаптер с Modbus интерфейс за връзка със СКАДА
Аналогови входове:	3 входа: 1 за DC напрежение, 1 за DC ток и 1 за DC ток или температура.
Цифрови входове:	8 входа за аларма изгорял предпазител или външно работно оборудване, като въздушни условия, пожароизвестителна аларма или газгенераторна аларма
Памет:	В паметта се съхраняват 100 rapopта за работата на ТИ и за повреди
Защити софтуерни:	Най-важните настройки са защитени чрез парола (4 нива на достъп).
Бутон за тест на светодиодите:	Ресет на СД индикации на запомнените повреди и тест за изправност на СД.
<b>ОПИСАНИЕ НА ИНТЕГРИРАНИТЕ ФУНКЦИИ:</b>	
Контрол за наличие на мрежовото захранване:	При отпадане на мрежовото напрежение, се активира електронен регулиращ блок и се появява сигнализация "отпаднала мрежа". След възстановяване на мрежата, регулиращия блок се изключва, токoнзправителят започва да работи отново и светва сигнализацията "наличие на мрежово захранване".
Контрол на изхода на токoнзправителя:	Токoвозависим контрол за ниско напрежение и контрол на 10 характеристики-



	ката на токоизправителя. Ако изходното напрежение спадне под настроената стойност 2,10V/кл., а изходния ток е $\leq 90\%$ от номиналния, то тогава се задейства алармения сигнал "повреда на устройството".
Контрол за високо напрежение:	Ако поради външни или вътрешни смущения (над 20 ms) изходното напрежение стане прекалено високо (стойността се настройва), тогава се задейства импулсна блокировка и токоизправителя се изключва автоматично. Контролирането е динамично и с автоматично възстановяване. В продължение на 30 сек. Контролният блок опитва 4 пъти да възстанови работата на ТИ и ако не успее, светва аларма "високо изходно напрежение", както и "обща аларма" на безпотенциалния контакт.
Ниско батерийно напрежение:	Ако при разряд напрежението на АБ се понижи под определена стойност (настройваема), напр. 1,80V/кл. Светва сигнал "ниско батерийно напрежение", както и "обща аларма" на безпотенциалния контакт.
Контрол целостта на батерийната верига:	Батерийната верига се тества автоматично на всеки 24 часа. За тази цел ТИ понижава изходното си напрежение до 1,90V/клетка за около 5 сек, в резултат на което АБ започва да се разрежда. През това време се проверява батерийното напрежение. Ако то е над 1,90V/кл., то батерийната верига е наред. Ако напрежението падне под тази стойност, светва СД сигнал "прекъсване на батерийната верига", и излиза "обща аларма" на безпотенциалния контакт.
Тест за функционалност на батерията:	По време на този тест токоизправителят отново понижава изходното си напрежение и батерията започва да се разрежда, както в случая на проверка на батерийната верига. Но батерията ще бъде разреждана до една настройваемо минимално гранично напрежение в продължение на определено време, също настройваемо. Тези граници са в пропорционална зависимост от капацитета на АБ, отнет по време на разряда, и могат да бъдат определени от разрядните криви на свързаната батерия. Ако по време на функционалния тест стойностите спаднат под настроените граници, излиза СД индикация за "отрицателен батерийен тест", а също така и "обща аларма" на безпотенциалния контакт. След теста ТИ автоматично се връща към "ускорен" или "подзаряд".
Контрол за наличие на земно в положителния и отрицателния клон на DC- веригата:	Контролира се изоляционното съпротивление на постоянно- токовия изход спрямо земя. Плюсът и минусът се измерват и контролират последователно

	един след друг. Ако изоляционното съпротивление спадне под настроената стойност (настройваема от 100 kΩ до 1 MΩ), това се индицира от съответния СД и от "обща аларма" на безпотенциалния контакт.
I*R компенсация:	Компенсира се спадът на напрежение от кабелните връзки между батерията и токоизправителя, като програмно се въвеждат сечение и дължината им.
Програмируемо автоматично преминаване от режим на подзаряд към ускорен заряд и обратно:	Ако батерийното напрежение се понижи поради отпадане на мрежово захранване (или по друга причина), токоизправителя започва да работи в режим на токоограничение. Ако работи в този режим за повече от 30 сек. След началото на заряда, той автоматично преминава към режим на ускорен заряд. След като бъде достигнато (с токоограничение) напрежението на ускорен заряд и зарядния ток спадне под 90% от номиналната стойност, се включва таймер. След изтичане на зададеното време (настройваемо от 0 до 6 часа), токоизправителят автоматично се връща към подзаряд. Автоматичния заряд може да бъде изключен със ключ, така че да е възможно само ръчно преминаване към ускорен заряд и обратно. Преминаването към ускорен заряд може да се блокира и чрез външен контакт, или шунтиращ мост на регулатора
Контрол на токоограничението на ТИ по I <sub>nom</sub> :	При работа в токоограничение над 10 s, светва СД "токоограничение".
Контрол симетрия между двата клона на АБ:	Сравнява се напрежението между двата клона на АБ. При нарушена симетрия има прекъсване на клетка, клетка на к.с., прекъсване на веригата на АБ и т.н. Излиза СД сигнализация на лицевия панел.
Хардуерни базови настройки:	При повреда на микропроцесора, ТИ продължава работа, като автоматично преминава към базовите настройки в паметта. Подзаряд на АБ и захранване на товара със същото напрежение. В този случай излиза и сигнал за "обща аларма" на безпотенциалния контакт.
Температурна компенсация на зар. напрежение:	Променя подзарядното напрежение в зависимост от околната температура
Автоматична противоелементна група 25A (диоден стабилизатор)	За автоматично поддържане на напрежение към товара в толеранс 220V +5% / - 10% във всички работни режими, максимален продължителен ток 25A
<b>КОНСТРУКЦИЯ:</b>	
Изпълнение на шкафа:	Управляващ ключ, дисплей, фиксирани СД индикатори са отпред



Връзки:	АС- и DC страна, нормални или болтови терминали.
Защити	Si- полупроводници са защитени от к. с. чрез свръх бързи предпазители
Трифазна защита срещу АС пренапрежение:	Срещу комутационни и/или атмосферни пренапрежения по АС мрежата
Вход на токоизправителя:	Автоматични прекъсвачи 400V AC
Изход на токоизправителя:	Изолірачни прекъсвачи 220V DC с NH00 предпазители
Изход към товара:	Двуполуосен изоліращ прекъсвач 220V DC с NH00 предпазители
Батериен изход:	Двуполуосен изоліращ прекъсвач 220V DC с NH00 предпазители
<b>ДОКУМЕНТАЦИЯ:</b>	
Техническа документация:	1 бр. на английски език + 1 бр. на български език
Ръководство за инсталиране, пуск и работа:	1 бр. на английски език + 1 бр. на български език
Сервизна документация:	1 бр. на английски език
Списък на части с кодови номера:	1 бр. на английски език
Тест репорт:	От проведени ваводски изпитания и настройки
Снабдяване с резервни части:	10 год. след спиране от производство
Отстраняване на повреди в гаранционен срок:	До 8 часа от уведомяването.
Производствен опит:	Над 40 години
MTBF:	Над 15 год.

**СВЕТОДИОДИ:**

-  Работен режим
-  Работа на акумулаторна батерия
-  Обща неизправност
-  Спешна неизправност

**БУТОНИ:**

-  Бутон за придвижване нагоре в менюто
-  Бутон за придвижване надолу в менюто
- E** Потвърждаване на опция в менюто  
Съхраняване на новоизбрана стойност  
Извикване на следващото ниво от менюто
- C** Излизане от менюто без промяна на стойността  
Извикване на следващото по-високо ниво от менюто

**ДИШЛЕЙ:**



22.04.2015 год.  
гр. София

Изготвил:  
И. Иванов  
/Р-л Проект/

*И. Иванов*



Typ/Type: Artikel-Nr./ Part No.:  
 D400 G216/60 BWnug-TDG-C 00100052845  
 Zeichnungs-Nr./Drawing No.: Serien-Nr./Serial No.:  
 112500.00E388 106000546742  
 Auftrags-Nr./ Order No.:  
 001-00223337.1

Die Anlage wurde geprüft nach/  
 Equipment tested according to/  
 DIN EN 60146-1-1 Absatz/Section 4

**EINGANG/INPUT**

Spannung / voltage:	400 V	Strom / current:	31,5 A	3 -phasig/phase(s)	50 Hz
<b>AUSGANG/OUTPUT:</b>					
<b>Laden / Boost charging</b>		<b>Erhaltungsladen / Float charging</b>			
258,9 V	60° A	244,9 V	60° A		
259,1 V	50 A	245,1 V	50 A		
259,2 V	30 A	245,2 V	30 A		
259,2 V	20 A	245,2 V	20 A		
259,3 V	10 A	245,3 V	10 A		
<b>Ausgleichsladen/equalizing charge</b>		291 V ca. 12 A			
<b>Frequenzbewertete Störspannung/ psophometric noise (nach/according CCITT):</b>					
mV					

bei Widerstandslast/by resistance load  
 bei Batteriebelastung/by battery load  
 Restwelligkeit/ripple voltage: 1,1 Veff. Vss  
 bei/by: 50 A 245,1 VDC = 0,45 %  
 bei Widerstandslast/by resistance load  
 bei Batteriebelastung/by battery load  
 Schutzart/protection mode IP 20  
 Sicherheitstest/safety test:

<b>HV-Test (1 sec)</b>		<b>ISO-Test (1 sec)</b>		<b>GND-Test (1 sec)</b>	
prim.-sek.	2,1 kV	DC mit with:	500 V	DC	24 V
prim.-GND	2,1 kV	DC Riso	> 100 MΩ		
sek.-GND	2,1 kV	DC			

**Bemerkungen/Remarks:**  
 Alle Messungen bei / all measurements at 20°C  
 \* = Strombegrenzung / current limitation  
 Einstellungen siehe Technisches Datenblatt / adjustments see technical data sheet: 00100052845.00T000  
 Alle Messungen ohne / all measurements without: Batteriestrombegrenzung / Battery current limitation

Datum/Date: 11.06.14  
 Datum/Date: 11.06.14  
 TB10.8 de-en MSch  
 Prüfer/Tester: N. Mohr  
 freigegeben/approved: V. Sewergin

Typ/Type: Artikel-Nr./ Part No.:  
 D400 G216/60 BWnug-TDG-C 00100052845  
 Zeichnungs-Nr./Drawing No.: Serien-Nr./Serial No.:  
 112500.00E388 106000540044  
 Auftrags-Nr./ Order No.:  
 001-00223337.1

Die Anlage wurde geprüft nach/  
 Equipment tested according to/  
 DIN EN 60146-1-1 Absatz/Section 4

**EINGANG/INPUT**

Spannung / voltage:	400 V	Strom / current:	31,5 A	3 -phasig/phase(s)	50 Hz
<b>AUSGANG/OUTPUT:</b>					
<b>Laden / Boost charging</b>		<b>Erhaltungsladen / Float charging</b>			
258,9 V	60° A	244,9 V	60° A		
259,1 V	50 A	245,1 V	50 A		
259,2 V	30 A	245,2 V	30 A		
259,2 V	20 A	245,2 V	20 A		
259,3 V	10 A	245,3 V	10 A		
<b>Ausgleichsladen/equalizing charge</b>		291 V ca. 12 A			
<b>Frequenzbewertete Störspannung/ psophometric noise (nach/according CCITT):</b>					
mV					

bei Widerstandslast/by resistance load  
 bei Batteriebelastung/by battery load  
 Restwelligkeit/ripple voltage: 1,1 Veff. Vss  
 bei/by: 50 A 245,1 VDC = 0,45 %  
 bei Widerstandslast/by resistance load  
 bei Batteriebelastung/by battery load  
 Schutzart/protection mode IP 20  
 Sicherheitstest/safety test:

<b>HV-Test (1 sec)</b>		<b>ISO-Test (1 sec)</b>		<b>GND-Test (1 sec)</b>	
prim.-sek.	2,1 kV	DC mit with:	500 V	DC	24 V
prim.-GND	2,1 kV	DC Riso	> 100 MΩ		
sek.-GND	2,1 kV	DC			

**Bemerkungen/Remarks:**  
 Alle Messungen bei / all measurements at 20°C  
 \* = Strombegrenzung / current limitation  
 Einstellungen siehe Technisches Datenblatt / adjustments see technical data sheet: 00100052845.00T000  
 Alle Messungen ohne / all measurements without: Batteriestrombegrenzung / Battery current limitation

Datum/Date: 11.06.14  
 Datum/Date: 11.06.14  
 TB10.8 de-en MSch  
 Prüfer/Tester: N. Mohr  
 freigegeben/approved: V. Sewergin



Typ/Type: D400 G216/60 BWRug-TDG-C  
 Zeichnungs-Nr./Drawing No.: 112500.00E388  
 Artikel-Nr./ Part No.: 00100052845  
 Serien-Nr./Serial No.: 106000546740  
 Auftrags-Nr./ Order No.: 001-00223337 1

Die Anlage wurde geprüft nach/  
 Equipment tested according to/

DIN EN 60146-1-1 Absatz/Section 4

INGANG/INPUT  
 Spannung / voltage: 400 V Strom / current: 31,5 A 3 -phasig/phase(s) 50 Hz  
 AUSGANG/OUTPUT:

Laden / Boost charging		Erhaltungsladen / Float charging	
258,9 V	60° A	244,9 V	60° A
259,1 V	50 A	245,1 V	50 A
259,2 V	30 A	245,2 V	30 A
259,2 V	20 A	245,2 V	20 A
259,3 V	10 A	245,3 V	10 A

Ausgleichsladen/equalizing charge 291 V ca. 12 A  
 Frequenzbewertete Störspannung/  
 psophometric noise (nach/according CCITT): mV

- bei Widerstandslast/by resistance load  bei Batterielast/by battery load
- Restwelligkeit/ripple voltage: 1,1 Veff. V ss
- bei/by: 50 A 245,1 VDC = 0,45 %
- bei Widerstandslast/by resistance load  bei Batterielast/by battery load
- Schutzart/protection mode IP 20
- Sicherheits-/safety test:

HV-Test (1 sec)		ISO-Test (1 sec)		GND-Test (1 sec)	
prim.-sek.	2,1 kV DC mit with:	500 V DC	ent with	24 V DC	25 A
prim.-GND	2,1 kV DC Riso	> 100 MΩ			
sek.-GND	2,1 kV DC				

Bemerkungen/Remarks:  
 Alle Messungen bei / all measurements at 20°C  
 Strombegrenzung / current limitation  
 Einstellungen siehe Technisches Datenblatt / adjustments see technical data sheet: 00100052845.00T000  
 Alle Messungen ohne / all measurements without: Batteriestrombegrenzung / Battery current limitation  
 Datum/Date: 11.06.14  
 Prüfer/Tester: N. Mohr  
 freigegeben/approved: V. Sewergin



Typ/Type: D400 G216/60 BWRug-TDG-C  
 Zeichnungs-Nr./Drawing No.: 112500.00E388  
 Artikel-Nr./ Part No.: 00100052845  
 Serien-Nr./Serial No.: 106000546741  
 Auftrags-Nr./ Order No.: 001-00223337 1

Die Anlage wurde geprüft nach/  
 Equipment tested according to/

DIN EN 60146-1-1 Absatz/Section 4

INGANG/INPUT  
 Spannung / voltage: 400 V Strom / current: 31,5 A 3 -phasig/phase(s) 50 Hz  
 AUSGANG/OUTPUT:

Laden / Boost charging		Erhaltungsladen / Float charging	
258,9 V	60° A	244,9 V	60° A
259,1 V	50 A	245,1 V	50 A
259,2 V	30 A	245,2 V	30 A
259,2 V	20 A	245,2 V	20 A
259,3 V	10 A	245,3 V	10 A

Ausgleichsladen/equalizing charge 291 V ca. 12 A  
 Frequenzbewertete Störspannung/  
 psophometric noise (nach/according CCITT): mV

- bei Widerstandslast/by resistance load  bei Batterielast/by battery load
- Restwelligkeit/ripple voltage: 1,1 Veff. V ss
- bei/by: 50 A 245,1 VDC = 0,45 %
- bei Widerstandslast/by resistance load  bei Batterielast/by battery load
- Schutzart/protection mode IP 20
- Sicherheits-/safety test:

HV-Test (1 sec)		ISO-Test (1 sec)		GND-Test (1 sec)	
prim.-sek.	2,1 kV DC mit with:	500 V DC	ent with	24 V DC	25 A
prim.-GND	2,1 kV DC Riso	> 100 MΩ			
sek.-GND	2,1 kV DC				

Bemerkungen/Remarks:  
 Alle Messungen bei / all measurements at 20°C  
 Strombegrenzung / current limitation  
 Einstellungen siehe Technisches Datenblatt / adjustments see technical data sheet: 00100052845.00T000  
 Alle Messungen ohne / all measurements without: Batteriestrombegrenzung / Battery current limitation  
 Datum/Date: 11.06.14  
 Prüfer/Tester: N. Mohr  
 freigegeben/approved: V. Sewergin

<b>BENNING</b>	<b>Prüfprotokoll</b>	Serial-Nr. / Serial No.: 106000540048
	<b>Test Report</b>	Blatt/Sheet: 17

Typ: D400G21/10-50B Wru-PDG	Auftrags-Nr.: 001-002233372
Zerchn. Nr.: 104380.00E794	Serial-Nr.: 106000540048

Die Anlage wurde geprüft nach:  
Equipment tested according to:

EN 60146-1-1  
IEC 60146-1-1

Prüfung test	Kapitel chapter	Typprüfung type test	Stichprüfung routine test	Zusatzprüfung optional test <sup>1</sup>
Sichtprüfung Visual test		X	X	
Isolationsprüfung		X	X	
Insulation test	7.2	X	X	
Schwachlast- und Funktionsprüfung		X	X	
Light load and functional test	7.3.1	X	X	
Prüfen mit Bemessungsstrom		X	X	
Rated current test	7.3.2	X	X	
Ermittlung der Verluste für Stromrichterstände und -geräte		X	X	
Power loss determination for assemblies and equipment	7.4.1	X	X	
Erwärmungsprüfung		X	X	
Temperature-rise test	7.4.2	X	X	
Messung des Leistungsfaktors		X	X	(X)
Power factor measurement	7.4.3	X	X	(X)
Prüfen der Hilfeinrichtungen		X	X	
Checking of auxiliary devices	7.5.1	X	X	
Ermittlung der inneren Spannungsänderung		X	X	
Measurement of the inherent voltage regulation	7.5.4	X	X	(X)
Prüfen der Eigenschaften der Steuereinrichtung		X	X	
Checking the properties of the control equipment	7.5.2	X	X	
Prüfen der Schutzrichtungen		X	X	
Checking the protective devices	7.5.3	X	X	
Prüfen der Störfestigkeit		X	X	
Immunity test	7.6 a)	X	X	(X)
Überstromprüfung		X	X	
Overcurrent capability test	7.6.3	X	X	(X)
Funktionsgrad		X	X	
Radio interference level	7.6 b)	X	X	(X)
Geräuschmessung		X	X	
Audible noise	7.7	X	X	(X)
Ermittlung der überlagerten Wechselgrößen		X	X	
Measurement of ripple AC values	7.5.5	X	X	(X)
Zusätzliche Prüfungen		X	X	
Additional tests	7.7	X	X	(X)
Messung der Oberschwingungsströme		X	X	
Measurement of Harmonics	7.3.6	X	X	(X)

Die in den "X" gekennzeichneten Einzelprüfungen werden nur durchgeführt, wenn sie ausdrücklich im Vertrag vereinbart sind.  
The tests marked with "X" characterized individual tests are accomplished only if they were agreed upon expressly in the contract.



<b>BENNING</b>	<b>Prüfprotokoll</b>	Serial-Nr. / Serial No.: 106000540048
	<b>Test Report</b>	Blatt/Sheet: 2/7

Vorgenommene Prüfungen und Kontrollen  
Inspections and tests performed

Ergebnis/Result  
Beurteilung  
complaints

o.k.

Sichtprüfung  
Visual test

Mechanische Kontrollen  
Mechanical checks

Kontrolle der eingebauten Geräte  
check of the incorporated devices

Kontrolle der Verdrahtung und Stromschienen  
Verification of the wiring and of the busbars

Kontrolle der Beschriftung und Schilder  
Verification of the markings and identification plates

Messkontrolle der Luft- und Kriechstrecken  
verification of the air gaps and creeping distances

Isolationsprüfung nach EN/IEC 60146-1-1/7.2  
Insulation test according to EN/IEC 60146-1-1/7.2

Spannungsprüfung  
Voltage test

Primär/Sekundär  
Primarily/secondary

Primär/GND  
Primarily/ground

Sekundär/GND  
Secondary/ground

Zeitdauer/duration

Vorgenommene Prüfungen und Kontrollen  
Inspections and tests performed

Ergebnis/Result  
Beausstanding  
complaints

o.k.

Isolationswiderstandsprüfung  
Insulation resistance test

Stromkreis Meßspannung Isolationswert  
circuit measuring voltage insulation resistance

Hauptstromkreis 500 V= > 100 MOhm

Hilfsstromkreis 500 V= > 100 MOhm

Zeitdauer/duration 10 Sek.

Schwachlast- und Funktionsprüfung  
Light load and functional test (EN/IEC 60146-1-1/7.3.1)

(Prüfen mit Bemessungsstrom Rated current test (EN/IEC 60146-1-1/7.3.1))  
Aufnahme der Neandaten  
checking of the nominal values

Eingang input	Spannung V voltage V	400	<input checked="" type="checkbox"/>
	Strom A current A	26 (34)	<input checked="" type="checkbox"/>
	Frequenz Hz frequency Hz	50	<input checked="" type="checkbox"/>

Ausgang output	Einstellung Set to	Einstellung Set to	Einstellung Set to
	102 cells	104 cells	106 cells
Batterie-spannung: V battery voltage: V	227,5 V	232,0 V	236,4 V <input checked="" type="checkbox"/>
Verbraucher-spannung: V load voltage: V	227,5 V	232,0 V	236,4 V <input checked="" type="checkbox"/>
Strom: A current A	10-50 A	10-50 A	10-50 A <input checked="" type="checkbox"/>



*[Handwritten signature]*

Vorgenommene Prüfungen und Kontrollen  
Inspections and tests performed

Ergebnis/Result  
Beausstanding  
complaints

o.k.

Ermittlung der Verluste für Stromrichtersätze und -geräte nach EN/IEC 60146-1-1/7.4.1  
Power loss determination for assemblies and equipment according to EN/IEC 60146-1-1/7.4.1

Eingangsleistung/input power kW

Ausgangsleistung/output power kW

$\eta = P_{out}/P_{in} =$

Erwärmungsprüfung nach EN/IEC 60146-1-1/7.4.2  
Temperature rise test according to EN/IEC 60146-1-1/7.4.2

Ausgangsspannung/output voltage V

Ausgangsstrom/output current A

Dauer/duration h

Gemessene Temperaturen/measured temperatures:

Transformator/transformer °C

Drossel/choke °C

Thyristorsatz/thyristor set °C

Umgebungstemperatur/ambient temperature °C

Messung des Leistungsfaktors nach EN/IEC 60146-1-1/7.4.3  
Power factor measurement according to EN/IEC 60146-1-1/7.4.3

$\cos \phi =$

Prüfen der Hilfseinrichtungen nach EN/IEC 60146-1-1/7.5.1  
Checking of auxiliary devices according to EN/IEC 60146-1-1/7.5.1

<b>BENNING</b>	Prüfprotokoll	Serien-Nr. / Serial No.: 106000540048
	Test Report	Blatt/Sheet: 5/7

Vorgenommene Prüfungen und Kontrollen  
Inspections and tests performed

Ergebnis/Result  
Bezustandung  
complaints

o.k.

Ermittlung der inneren Spannungsänderung nach EN/IEC 60146-1-1/7.3.4  
Measurement of the inherent voltage regulation according to EN/IEC 60146-1-1/7.3.4

Prüfen der Eigenschaften der Steuereinrichtung nach EN/IEC 60146-1-1/7.5.2  
Checking the properties of the control equipment according to EN/IEC 60146-1-1/7.5.2

bei Netzennennspannung  
at rated mains voltage

U = 400 V

104 Zellen/cells		106 Zellen/cells	
231,7 V	30,0 A	236,2 V	30,0 A
231,8 V	20,0 A	236,3 V	20,0 A
231,9 V	15,0 A	236,4 V	15,0 A
232,0 V	10,0 A	236,4 V	10,0 A
232,0 V	5,0 A	236,4 V	5,0 A

bei Netzunterspannung  
at mains undervoltage

U = 360 V

104 Zellen/cells		106 Zellen/cells	
231,7 V	30,0 A	236,2 V	30,0 A
231,8 V	20,0 A	236,3 V	20,0 A
231,9 V	15,0 A	236,4 V	15,0 A
232,0 V	10,0 A	236,4 V	10,0 A
232,0 V	5,0 A	236,4 V	5,0 A

bei Netzüberspannung  
at mains overvoltage:

U = 440 V

104 Zellen/cells		106 Zellen/cells	
231,7 V	30,0 A	236,2 V	30,0 A
231,8 V	20,0 A	236,3 V	20,0 A
231,9 V	15,0 A	236,4 V	15,0 A
232,0 V	10,0 A	236,4 V	10,0 A
232,0 V	5,0 A	236,4 V	5,0 A

bei Ausgangeingangsleistung/qualizing charging  
at mains output power/adjusted to

bis/to  
V A

Handladen eingestellt  
manual charging adjusted

V A max

i-Kennlinie/-characteristic

V A

<b>BENNING</b>	Prüfprotokoll	Serien-Nr. / Serial No.: 106000540048
	Test Report	Blatt/Sheet: 6/7

Vorgenommene Prüfungen und Kontrollen  
Inspections and tests performed

Ergebnis/Result  
Bezustandung  
complaints

o.k.

Prüfen der Schutzvorrichtungen nach EN/IEC 60146-1-1/7.5.3  
Checking the protective devices according to EN/IEC 60146-1-1/7.5.3

- Berührungsschutz/shock protection
- Schutzart/protection mode
- Schutzklasse/protection class
- Sicherungen/fuses
- Automaten/MCBs
- Leistungsschalter/MCCBs

Prüfen der Störfestigkeit nach EN/IEC 60146-1-1/7.6 a)  
Immunity test according to EN/IEC 60146-1-1/7.6 a)

Prüfen der Überstrombelastbarkeit nach EN/IEC 60146-1-1/7.3.3  
Overcurrent capability test according to EN/IEC 60146-1-1/7.3.3

bei Netzennennspannung  
at mains voltage

U = V

Funktionsgrad nach EN/IEC 60146-1-1/7.6 b)  
Radio interference level according to EN/IEC 60146-1-1/7.6 b)

Geräuschmessung nach EN/IEC 60146-1-1/7.7  
Audible noise according to EN/IEC 60146-1-1/7.7

Ermittlung der überlagerten Wechselgrößen nach EN/IEC 60146-1-1/7.3.5  
Measurement of ripple AC values according to EN/IEC 60146-1-1/7.3.5

bei Widerstands-/Batterielast  
at resistance/battery load

V  SS /  eff. bei Ausgangsspannung/  
at output voltage V DC

ergibt/results in %



*Handwritten signature*

<b>BENNING</b>	<b>Prüfprotokoll</b>	Serien-Nr. / Serial No.: 106000540048 Blatt/Sheet: 7/7
	<b>Test Report</b>	

Vorgenommene Prüfungen und Kontrollen  
 Inspections and tests performed

Ergebnis/Result  
 Beanstandung  
 complaints  
 o.k.

Zusätzliche Prüfungen nach EN/IEC 60146-1-1/7.7  
 Additional tests according to EN/IEC 60146-1-1/7.7

Spannungsebene für 102 Zellen = 227,5V o.k.  
 Voltage level for 102 cells = 227,5V o.k.

Für Prüfung bestückt mit 3 Modulen / equipped with 3 modules for testing

<b>BENNING</b>	<b>Prüfprotokoll</b>	Serien-Nr. / Serial No.: 106000540049 Blatt/Sheet: 1/7
	<b>Test Report</b>	

Typ:	Auftrags-Nr.:	
Type:	Order-No.:	001-00223337/2
Zeichn. Nr.:	Serien-Nr.:	
Drawing No.:	Serial No.:	106000540049

Die Anlage wurde geprüft nach:  
 Equipment tested according to:

EN 60146-1-1  
 IEC 60146-1-1

Prüfung test	Kapitel chapter	Typprüfung type test	Sitzprüfung routine test	Zusatzprüfung optional test
Sichtprüfung Visual test		X	X	
Isolationsprüfung Insulation test	7.2	X	X	
Schwachlast- und Funktionsprüfung Light load and functional test	7.3.1	X	X	
Prüfen mit Bemessungsstrom Rated current test	7.3.2	X	X	
Ermittlung der Verluste für Stromrichtersätze und -geräte Power loss determination for assemblies and equipment	7.4.1	X		
Erwärmungsprüfung Temperature-rise test	7.4.2	X		
Messung des Leistungsfaktors Power factor measurement	7.4.3			(X)
Prüfen der Hilfsrichtungen Checking of auxiliary devices	7.5.1	X	X	
Ermittlung der inneren Spannungsänderung Measurement of the inherent voltage regulation	7.3.4			(X)
Prüfen der Eigenschaften der Steuereinrichtung Checking the properties of the control equipment	7.5.2	X	X	
Prüfen der Schutzrichtungen Checking the protective devices	7.5.3	X	X	
Prüfen der Störfestigkeit Immunity test	7.6 a)			(X)
Überstromprüfung Overcurrent capability test	7.3.3			(X)
Funktionsgrad Radio interference level	7.6 b)			(X)
Geräuschmessung Audible noise	7.7			(X)
Ermittlung der überlagerten Wechselgrößen Measurement of ripple AC values	7.3.5			(X)
Zusätzliche Prüfungen Additional tests	7.7			(X)
Messung der Oberschwingungsströme Measurement of Harmonics	7.3.6			(X)

Die mit "(x)" gekennzeichneten Einzelprüfungen werden nur durchgeführt, wenn sie ausdrücklich im Vertrag vereinbart wurden.  
 With "(x)" characterized individual tests are accomplished only if they were agreed upon expressly in the contract.



Kontrollierung/supervisor: Schmeink, Ingo

Datum/date: 13.06.2014

Datum/date: 13.06.2014

Dieses Dokument wurde maschinell erstellt und freigegeben und ist ohne Unterschrift gültig.  
 This document has been drawn up electronically and released and is valid without signature.

**BENNING**

Prüfprotokoll

Serien-Nr. / Serial No.:  
106000540049

Test Report

Blatt/Sheet: 2/7

Vorgenommene Prüfungen und Kontrollen  
Inspections and tests performedErgebnis/Result  
o.k. Beanstandung  
complaintsSichtprüfung  
Visual testMechanische Kontrollen  
Mechanical checksKontrolle der eingebauten Geräte  
check of the incorporated devicesKontrolle der Verdringung und Stromschienen  
Verification of the wiring and of the busbarsKontrolle der Beschriftung und Schilder  
Verification of the markings and identification platesMesskontrolle der Luft- und Kriechstrecken  
verification of the air gaps and creeping distancesIsolationsprüfung nach EN/IEC 60146-1-1/7.2  
Insulation test according to EN/IEC 60146-1-1/7.2Spannungsprüfung  
Voltage testPrimär/Sekundär  
Primary/secondaryPrimär/GND  
Primary/groundSekundär/GND  
Secondary/ground

Zeitdauer/duration

2,1 kV DC

2,1 kV DC

2,1 kV DC

2 Sek.

**BENNING**

Prüfprotokoll

Serien-Nr. / Serial No.:  
106000540049

Test Report

Blatt/Sheet: 3/7

Vorgenommene Prüfungen und Kontrollen  
Inspections and tests performedErgebnis/Result  
o.k. Beanstandung  
complaintsIsolationswiderstandsprüfung  
Insulation resistance testStromkreis  
measuring voltage Isolationswert  
insulation resistanceHauptstromkreis  
Main circuit 500 V= > 100 MOhm Hilfsstromkreis  
Aux. circuit 500 V= > 100 MOhm Zeitdauer/duration 10 Sek. Schwachlast- und Funktionsprüfung  
Light load and functional test (EN/IEC 60146-1-1/7.3.1)  
(Prüfen mit Bemessungsstrom Rated current test (EN/IEC 60146-1-1/7.3.1))  
Aufnahme der Nenndaten  
checking of the nominal values

Eingang input	Spannung V voltage V	400	<input checked="" type="checkbox"/>
	Strom A current A	26 (34)	<input checked="" type="checkbox"/>
	Frequenz Hz frequency Hz	50	<input checked="" type="checkbox"/>

Ausgang output	Einstellung Set to 102 cells	Einstellung Set to 104 cells	Einstellung Set to 106 cells
Batterie- spannung: V battery voltage: V	227,5 V	232,0 V	236,4 V
Verbraucher- spannung: V load voltage: V	227,5 V	232,0 V	236,4 V
Strom: A current A	10-50 A	10-50 A	10-50 A



Vorgenommene Prüfungen und Kontrollen  
Inspections and tests performed

Ergebnis/Result  
o.k.  Beanstandung  
complaints

Ermittlung der Verluste für Stromrichtersätze und -geräte nach EN/IEC 60146-1-17.4.1  
Power loss determination for assemblies and equipment according to EN/IEC 60146-1-17.4.1

- Eingangsleistung/input power  kW
- Ausgangsleistung/output power  kW
- $\eta = P_{out}/P_{in} =$

Erwärmungsprüfung nach EN/IEC 60146-1-17.4.2  
Temperature rise test according to EN/IEC 60146-1-17.4.2

- Ausgangsspannung/output voltage  V
- Ausgangsstrom/output current  A
- Dauer/duration  h

Gemessene Temperaturen/measured temperatures:

- Transformator/transformer  °C
- Drossel/choke  °C
- Thyristorsatz/thyristor set  °C
- Umgebungstemperatur/ambient temperature  °C

Messung des Leistungsfaktors nach EN/IEC 60146-1-17.4.3  
Power factor measurement according to EN/IEC 60146-1-17.4.3

- $\cos \varphi =$
- Prüfen der Hilfseinrichtungen nach EN/IEC 60146-1-17.5.1  
Checking of auxiliary devices according to EN/IEC 60146-1-17.5.1



Vorgenommene Prüfungen und Kontrollen  
Inspections and tests performed

Ergebnis/Result  
o.k.  Beanstandung  
complaints

Ermittlung der inneren Spannungsänderung nach EN/IEC 60146-1-17.3.4  
Measurement of the inherent voltage regulation according to EN/IEC 60146-1-17.3.4

- bei Netznominalspannung  
at rated mains voltage
- U = 400 V
- 104 Zellen/cells
- 231,8 V 30,0 A
- 231,9 V 20,0 A
- 232,0 V 15,0 A
- 232,0 V 10,0 A
- 232,1 V 5,0 A

Prüfen der Eigenschaften der Steuereinrichtung nach EN/IEC 60146-1-17.5.2  
Checking the properties of the control equipment according to EN/IEC 60146-1-17.5.2

- bei Netznominalspannung  
at rated mains voltage
- U = 360 V
- 106 Zellen/cells
- 236,1 V 30,0 A
- 236,2 V 20,0 A
- 236,4 V 15,0 A
- 236,4 V 10,0 A
- 236,4 V 5,0 A

bei Netzüberspannung  
at mains overvoltage:

- U = 440 V
- 106 Zellen/cells
- 236,1 V 30,0 A
- 236,2 V 20,0 A
- 236,4 V 15,0 A
- 236,4 V 10,0 A
- 236,4 V 5,0 A

Ausgleichsladen/equalizing charging

- von/from
- eingestellt/adjusted to  bis/to  V  A

Handladen eingestell  
manual charging adjusted

- V
- I-Kennlinie/-characteristic  V  A max  A

<b>BENNING</b>	Prüfprotokoll	Serien-Nr. / Serial No.: 106000540049
	Test Report	Blatt/Sheet: 6/7

Vorgenommene Prüfungen und Kontrollen  
Inspections and tests performed

Ergebnis/Result  
o.k. Beanstandung  
complaints

Prüfen der Schutzrichtungen nach EN/IEC 60146-1-1/7.5.3  
Checking the protective devices according to EN/IEC 60146-1-1/7.5.3

- Berührungsschutz/shock protection
- Schutzart/protection mode
- Schutzklasse/protection class
- Sicherungen/fuses
- Automaten/MCBs
- Leistungsschalter/MCCBs

Prüfen der Störfestigkeit nach EN/IEC 60146-1-1/7.6 a)  
Immunity test according to EN/IEC 60146-1-1/7.6 a)

Prüfen der Überstrombelastbarkeit nach EN/IEC 60146-1-1/7.3.3  
Overcurrent capability test according to EN/IEC 60146-1-1/7.3.3

bei Netzennspannung U = V   
at mains voltage

Funktionsgrad nach EN/IEC 60146-1-1/7.6 b)  
Radio interference level according to EN/IEC 60146-1-1/7.6 b)

Geräuschmessung nach EN/IEC 60146-1-1/7.7  
Audible noise according to EN/IEC 60146-1-1/7.7

Ermittlung der überlagerten Wechselgrößen nach EN/IEC 60146-1-1/7.3.5  
Measurement of ripple AC values according to EN/IEC 60146-1-1/7.3.5

bei Widerstands-/Batterielast  
at resistance/battery load

V  SS /  eff. bei Ausgangsspannung/  
at output voltage V DC    
ergibt/result in %

<b>BENNING</b>	Prüfprotokoll	Serien-Nr. / Serial No.: 106000540049
	Test Report	Blatt/Sheet: 7/7

Vorgenommene Prüfungen und Kontrollen  
Inspections and tests performed

Ergebnis/Result  
o.k. Beanstandung  
complaints

Zusätzliche Prüfungen nach EN/IEC 60146-1-1/7.7  
Additional tests according to EN/IEC 60146-1-1/7.7

Spannungsebene für 102 Zellen = 227,5V o.k.  
Voltage level for 102 cells = 227,5V o.k.

Für Prüfung bestückt mit 3 Modulen / equipped with 3 modules for testing

Prüfer/tester: Schmeink, Ingo Datum/date: 13.06.2014

Kontrollleitung/supervisor: Sewergin, Viktor Datum/date: 13.06.2014

Dieses Dokument wurde maschinell erstellt und freigegeben und ist ohne Unterschrift gültig.  
This document has been drawn up electronically and released and is valid without signature.



**BENNING**

**EG-Konformitätserklärung**  
**EC-Conformation / Déclaration de conformité UE**

Dokument-Nr./ AB-Nr.: 00052/04.01

Hersteller: Theo Benning GmbH & Co. KG

Manufacturer / Fabricant:  
Münsterstraße 135-137

Anschrift:  
Address / Adresse:  
D-46397 Bocholt  
Telefon: +49 (0)2871 / 930

Produkt:  
Product name / Nom du produit:  
Beurrethe: Thymbrock  
E230 G2420, Burog-TDG – D400 G216/400 Burog-TDG

Geräte-Nr.:  
Serial No / Numéro de série:  
\_\_\_\_\_

Das bezeichnete Produkt stimmt mit den Vorschriften folgender Europäischen Richtlinien überein:  
The product is in accordance with European-Directive:  
Le produit indiqué ci-dessus est conforme aux directives européennes:

Nummer:  
Number / Nr.:  
7323EWG, Niederspannungsrichtlinie  
89/336EWG, EMV-Richtlinie

Normen:  
Standards / Normes:  
IEC 64, VDE 0108 Teil 101  
VDE 0160, VDE 435 Teil 320,  
EN 60742,  
EN 60146, VDE 871,  
EN 50178, EN 50081-2  
EN 50082-2

Aussteller:  
Issued by / Délivreur:  
GW

Bocholt, Datum und  
rechtsverbindliche Unterschrift  
03.04.2001  
ppa. W. Saut

Date et  
légalement binding Signature / Signature légale



Typ / Type: Rectifier	Artikel-Nr./ Part No.:
Zeichnungs-Nr./ Drawing No.:	Serien-Nr./ Serial No.:
	Auftrags-Nr./ Order No.:

Die Anlage wurde geprüft nach  
 Equipment tested according to/  
 DIN EN IEC 60146-1-1

Prüfung Test	Kapitel Chapter	Typ-prüfung Type test	Stück- prüfung Routine test	Zusatz- prüfung Optional test
Schprüfung Visual test		X	X	
Isolationsprüfung Insolation tests	7.2	X	X	
Schwachlast- und Funktionsprüfung Light load test and functional test	7.3.1	X	X	
Prüfen mit Bemessungsstrom Rated current test	7.3.2	X		
Ermittlung der Verlustleistung für Stromrichterätze und - geräte Power loss determination for assemblies and equipment	7.4.1	X		
Erwärmungsprüfung Temperature rise test	7.4.2	X		
Messung des Leistungsfaktors Power factor measurement	7.4.3			(X)
Prüfen der Hilfseinrichtungen Checking of auxiliary devices	7.5.1	X	X	
Ermittlung der inneren Spannungsänderung Measurement of the inherent voltage regulation	7.3.4			(X)
Prüfen der Eigenschaften der Steuerinrichtung Checking the properties of the control equipment	7.5.2	X	X	
Prüfen der Schutzinrichtungen Checking the protective devices	7.5.3	X	X	
Prüfen der Störfestigkeit Immunity test	7.6a			(X)
Prüfung der Überstrombelastbarkeit Over-current capability test	7.3.3			(X)
Funktstörgrad Radio interference degree	7.6.3			(X)
Geräuschmessung Measurement of audible noise	7.7			(X)
Messung von überlagerten Wechselgrößen Measurement of ripple voltage and current	7.3.5			(X)
Harmonische Störungen Harmonic currents	7.7			(X)
Überschwingungsströme Overswinging currents	7.3.6			(X)

Sonstige Messungen/Bemerkungen Other measurements/remarks	O.K.	Ergebnis Result
		Not O.K.

Measurement of harmonic currents		
Sicht- und Ausführungskontrollen: Visual and workmanship tests	<input type="checkbox"/>	<input type="checkbox"/>
Mechanische Kontrollen Mechanical tests	<input type="checkbox"/>	<input type="checkbox"/>
Gerätekontrolle (Kontrolle der eingebauten Geräte) Equipment tests (checks of the incorporated devices)	<input type="checkbox"/>	<input type="checkbox"/>
Kontrolle der Schutzmaßnahmen Verification of the protective measures	<input type="checkbox"/>	<input type="checkbox"/>
Kontrolle der Kriech- und Luftstrecken Verification of the creepage distances, clearances and distances	<input type="checkbox"/>	<input type="checkbox"/>
Kontrolle der Verdrahtung und Stromschienen Verification of the wiring and of the busbars	<input type="checkbox"/>	<input type="checkbox"/>
Kontrolle der Beschriftung und Schilder Verification of the markings and identification label	<input type="checkbox"/>	<input type="checkbox"/>
Überprüfung der Geräteunterlagen auf Übereinstimmung mit der Spezifikation Verification of the documentation if it is in accordance with the specification	<input type="checkbox"/>	<input type="checkbox"/>



Sonstige Messungen/Bemerkungen Other measurements/remarks		Ergebnis Result	
		O.K.	Not O.K.

7.2 Isolationsprüfung Insolation test		
Stromkreis Electric circuit	Meßspannung Measuring voltage	Isolationswert Insulation value
Hauptstromkreise Main circuits	kV	MΩ
Hilfsstromkreise Auxiliary electrical circuits	kV	MΩ

7.3 Hochspannungsprüfung High voltage test		Ergebnis Result
Primär -> GND Primary -> ground	kV	<input type="checkbox"/>
Sekundär -> GND Secondary -> ground	kV	<input type="checkbox"/>
Primär -> Sekundär Primary -> secondary	kV	<input type="checkbox"/>

7.3.1 Schwachlast- und Funktionsprüfung Light load and functional test		Ergebnis Result	
7.3.2 Prüfen mit Bemessungsstrom Rated current test			
Aufnahme der Nominaldaten Checking of the nominal values			
Eingang Input			
Spannung Voltage	V	<input type="checkbox"/>	<input type="checkbox"/>
Strom Current	A	<input type="checkbox"/>	<input type="checkbox"/>
Frequenz Frequency	Hz	<input type="checkbox"/>	<input type="checkbox"/>
Ausgang Output			
Batteriespannung Battery voltage	V	<input type="checkbox"/>	<input type="checkbox"/>
Verbraucherspannung Load voltage	V	<input type="checkbox"/>	<input type="checkbox"/>
Strom Current	A	<input type="checkbox"/>	<input type="checkbox"/>

Sonstige Messungen/Bemerkungen Other measurements/remarks		Ergebnis Result	
		O.K.	Not O.K.

7.4.1 Ermittlung der Verluste für Stromrichtersätze und -geräte Power loss determination for assemblies and equipment		
Eingangsleistung Input power	kW	<input type="checkbox"/>
Ausgangsleistung Output power	kW	<input type="checkbox"/>
$\eta = P_{out}/P_{in}$	%	<input type="checkbox"/>

7.4.2 Erwärmungsprüfung Temperature rise test		Ergebnis Result
Ausgangsspannung output voltage	V	<input type="checkbox"/>
Ausgangsstrom output current	A	<input type="checkbox"/>
Transformator Transformer	°C	<input type="checkbox"/>
Drossel Choke	°C	<input type="checkbox"/>
Thyristorsatz Thyristor set	°C	<input type="checkbox"/>
Umgebungstemperatur Ambient temperature	°C	<input type="checkbox"/>

7.4.3 Messung des Leistungsfaktors Power factor measurement		Ergebnis Result
cos φ =		<input type="checkbox"/>

7.5.1 Prüfen der Hilfsrichtungen Checking of auxiliary devices		Ergebnis Result
		<input type="checkbox"/>

7.3.4 Ermittlung der inneren Spannungsänderung Measurement of the inherent voltage regulation		Ergebnis Result
		<input type="checkbox"/>



Sonstige Messungen/Bemerkungen Other measurements/remarks	O.K.	Ergebnis Result	Not O.K.
--	------	--------------------	----------

7.5.2 Prüfen der Eigenschaften der Steuereinrichtung Checking the properties of control equipment			
bei Netzspannung at rated mains voltage	V		<input type="checkbox"/>
Laden Boost charging		Erhaltungsladen Float charging	
V	A	V	A
V	A	V	A
V	A	V	A
V	A	V	A
V	A	V	A
V	A	V	A
bei Netzunterspannung at mains undervoltage	V		<input type="checkbox"/>
Laden Boost charging		Erhaltungsladen Float charging	
V	A	V	A
V	A	V	A
V	A	V	A
V	A	V	A
V	A	V	A
bei Netzüberspannung at mains overvoltage	V		<input type="checkbox"/>
Laden Boost charging		Erhaltungsladen Float charging	
V	A	V	A
V	A	V	A
V	A	V	A
V	A	V	A
V	A	V	A
			

Sonstige Messungen/Bemerkungen Other measurements/remarks	O.K.	Ergebnis Result	Not O.K.
--	------	--------------------	----------

7.5.3 Prüfen der Schutzvorrichtungen Checking the protective devices according			
Berührungsschutz Shock protection			<input type="checkbox"/>
Schutzart Degree of Protection			<input type="checkbox"/>
Schutzklasse Class equipment			<input type="checkbox"/>
Sicherungen Fuses			<input type="checkbox"/>
Automaten Miniature circuit breaker			<input type="checkbox"/>
Leistungsschalter Moulded Case Circuit Breaker			<input type="checkbox"/>
Überprüfung der Geräteunterlagen auf Übereinstimmung mit der Spezifikation Verification of the documentation if it is in accordance with the specification			
			<input type="checkbox"/>
7.6a Prüfen der Störfestigkeit Immunity test			<input type="checkbox"/>
7.3.3 Prüfen der Überstrombelastbarkeit bei Netzspannung at mains voltage	V		<input type="checkbox"/>
7.6.3 Funkstörgrad Radio interference level			<input type="checkbox"/>
7.7 Geräuschmessung Audible noise			<input type="checkbox"/>
7.3.5 Messung der überlagerten Wechselgrößen Measurement of ripple AC values according bei Widerstands-/Batterielast at resistance/battery load	V	V/DC	<input type="checkbox"/>
	<input type="checkbox"/> SS / <input type="checkbox"/> eff	Ergebnis Results in	<input type="checkbox"/>
		%	<input type="checkbox"/>

Seite Page	7/7	Prüfprotokoll Test record	<b>BENNING</b>
---------------	-----	------------------------------	----------------

Sonstige Messungen/Bemerkungen Other measurements/remarks	Ergebnis Result	
	O.K.	Not O.K.

7.7	Zusätzliche Prüfungen: Additional tests:

Prüfer: Tester:	Datum: Date:
Freigegeben: Approved:	Datum: Date:

Das Dokument wurde maschinell erstellt und freigegeben und ist ohne Unterschrift gültig.  
This document has been drawn up electronically and released and is valid without signature.

ВЯПРО С  
ОРИГИНАЛ



Type: D380G125 / 200 BWruj-TDG3  
Order N°: Commande n°N 3549  
Zeichn. Nr.: N3549  
Plan n°: 3549001001  
Redresseur 1  
Rectifier 1

Equipment tested according to:  
EN 60146-1-1 (Avril 2011)  
Conformité de l'équipement testé selon:  
IEC 60146-1-1 (Avril 2011)

Test Essai	Chapitre Chapitre	Type Test Test de type	Individual Test Test individuel	Optional Test Essai facultatif
Visual test Contrôle visuel		X	X	
Insulation test Essai d'isolation	7.2	X	X	
Light load and functional test Essai à faible charge et essai de fonctionnement	7.3.1	X	X	
Rated current test Essai à courant nominal	7.3.2	X		
Overload capability test Essai d'aptitude aux surcharges	7.3.3			(X)
Measurement of the inherent voltage regulation Mesure de la régulation interne de tension	7.3.4			(X)
Measurement of the voltage and current ripple AC values	7.3.5			(X)
Measurement of the harmonic distortion currents Mesure des courants harmoniques	7.3.6			(X)
Power loss determination for assemblies and equipment Détermination des pertes pour les assemblages et les équipements	7.4.1	X		
Temperature-rise test Essai d'échauffement	7.4.2	X		
Power factor measurement Mesure du facteur de puissance	7.4.3			(X)
Checking of the auxiliary devices Contrôle des dispositifs auxiliaires	7.5.1	X	X	
Checking of the properties of the control equipment Contrôle des propriétés du système de commande	7.5.2	X	X	
Checking of the protection devices Contrôle des dispositifs de protection	7.5.3	X	X	
Immunity test Test d'immunité	7.6 a)			(X)
Radio interference level Niveau de interférence radioélectriques rayonnées et par rayonnées	7.6 b)			(X)
Radio immunity Immunité radioélectrique	7.7			(X)
Electromagnetic compatibility Compatibilité électromagnétique	7.7			(X)

EN 60146-1-1 (Avril 2011)  
IEC 60146-1-1 (Avril 2011)

Typetest 2013 En-fr  
Pdt: commande-2013-N3549-test report-N3549001001\_type\_001.doc

Inspections and test performed  
Inspection et essais réalisés  
o.k.  
Result/ Résultat  
complaints  
Réclamation

Type test and following optional tests :  
- Overload capability test  
- Measurement of the inherent voltage regulation  
- Measurement of the ripple AC values  
- Measurement of the power factor  
- Measurement of the audible noise

Visual test  
Contrôle visuel  
Mechanical checks  
Contrôles mécaniques  
Check of the incorporated devices  
Contrôle des dispositifs intégrés

Checking of the wiring and of the busbars  
Vérification du câblage et des Bus barres  
Checking of the marking and indication plates  
Vérification des marquages et des plaques d'identification  
Checking of the air gaps and creeping distances  
Vérification des entrefers et des distances

Insulation test according to EN/IEC 60146-1-1/7.2  
Essai d'isolation suivant EN/IEC 60146-1-1/7.2

Voltage test  
Tension d'essai  
Primarily/secondary  
Primaire /secondaire : 2,5 kV DC.  
Primarily/ground  
Primaire /terre : 2,5 kV DC.  
Secondary/ground  
Secondaire /terre : 2,5 kV DC.  
Duration / durée : 72 sec.

Released  
On behalf of: S.G.S.  
Client Name: AEP  
Company: S.I.T.E.L.E.S.  
Lab

Inspections and test performed  
Inspections et essais réalisés

Result/ Résultat  
complaints  
Réclamation

o.k.

**Insulation resistance test**

Mesure de la résistance d'isolement

Circuit measuring voltage insulation resistance  
Circuit Tension de mesure Résistance d'isolement

Hauptstromkreis   
Circuit principal : 500 V = > 100 MOhm

Hilfsstromkreis   
Circuit auxiliaire : 500 V = > 100 MOhm

Zeitdauer / durée : 10 sec.

**Light load and functional test (EN/IEC 60146-1-1/7.3.1)**

Essai fonctionnel et à faible charge

(Rated current test / Essai à courant nominal (EN/IEC 60146-1-1/7.3.2))

Checking of the nominal values

Contrôle des valeurs nominales :

Input Entrée	Voltage V Tension V	380 V	<input checked="" type="checkbox"/>
	Current A Intensité A	58 A	<input checked="" type="checkbox"/>
	Frequency Hz Fréquence Hz	60 Hz	<input checked="" type="checkbox"/>

Output Sortie	Battery-voltage: V Tension batterie: V	Load Charge	Erhaltungsladen Charge de maintenance
	133.4 V	133.4 V	129.3 V <input checked="" type="checkbox"/>
	133.4 V	133.4 V	129.3 V <input checked="" type="checkbox"/>
	200 A	200 A	200 A <input checked="" type="checkbox"/>

Reviewed/Reviewed/Releasend  
On behalf of 36,  
Print Name  
Signature  
Date 03/07/2013



Inspections and test performed  
Inspections et essais réalisés

Result/ Résultat  
complaints  
Réclamation

o.k.

**Overload capability test according to EN/IEC 60146-1-1/7.3.3**

Essai d'aptitude au surcharge selon EN/IEC 60146-1-1/7.3.3

bei Netznominalspannung   
à tension nominale secteur : U = 380 V

219.8 A

**Measurement of the inherent voltage regulation according to EN/IEC 60146-1-1/7.3.4**

Mesure de la régulation interne de tension selon EN/IEC 60146-1-1/7.3.4

**Checking the properties of the control equipment according to EN/IEC 60146-1-1/7.5.2**

Contrôle des propriétés du système de commande selon EN/IEC 60146-1-1/7.5.2

at rated mains voltage :   
à tension nominale secteur : U = 380 V

Boost Charge / Charge en boost/I ac input	Flot charge / Charge de maintien/I ac input
133.3 V 200 A 58 A 129.2 V 200 A <input checked="" type="checkbox"/>	60.2 A
133.4 V 100 A 29.7 A 129.3 V 100 A <input checked="" type="checkbox"/>	27.8 A
133.6 V 50 A 16.6 A 129.5 V 50 A <input checked="" type="checkbox"/>	14.6 A
133.8 V 0 A 15.4 A 129.7 V 0 A <input checked="" type="checkbox"/>	15.4 A
V A	A

The input current with no load come from cos phi capacitor

at mains undervoltage :

à sous-tension secteur :

U = 342 V

Boost Charge / Charge en boost	Flot charge / Charge de maintien
133.3 V 200 A 62.6 A 129.2 V 200 A <input checked="" type="checkbox"/>	63.1 A
133.4 V 100 A 29.7 A 129.3 V 100 A <input checked="" type="checkbox"/>	31.3 A
133.6 V 50 A 15.8 A 129.5 V 50 A <input checked="" type="checkbox"/>	15.7 A
133.9 V 0 A 14.7 A 129.7 V 0 A <input checked="" type="checkbox"/>	14.4 A
V A	A

at mains overvoltage:

à surtension secteur :

U = 418 V

Boost Charge / Charge en boost	Flot charge / Charge de maintien
133.3 V 200 A 59.1 A 129.2 V 200 A <input checked="" type="checkbox"/>	60.4 A
133.4 V 100 A 28.6 A 129.3 V 100 A <input checked="" type="checkbox"/>	27.3 A
133.5 V 50 A 15.1 A 129.5 V 50 A <input checked="" type="checkbox"/>	14.7 A
133.8 V 0 A 15.5 A 129.7 V 0 A <input checked="" type="checkbox"/>	15.4 A
V A	A

Reviewed/Reviewed/Releasend  
On behalf of 36,  
Print Name  
Signature  
Date 03/07/2013

Inspections and test performed  
Inspections et essais réalisés

Inspections and test performed  
Inspections et essais réalisés

Result/ Résultat  
complaints  
Réclamation

Result/ Résultat  
complaints  
Réclamation

o.k.

o.k.

Equalizing (manual) charging / Charge d'égalisation

Adjusted to / réglée à : 136.5 V 30.9A max

I-Characteristic / Courbe I : 120.4 V 220 A

Measurement of ripple AC values according to EN/IEC 60146-1-1/7.3.5  
Mesure de la résiduelle des valeurs c. a. selon EN/IEC 60146-1-1/7.3.5

at resistance/battery load  
sur charge resistive / Util.-batterie :

60mV  SS /  eff. at output voltage/  
à tension de sortie 133.3 V DC   
results in / soit 0.08 %

Power loss determination for assemblies and equipment according to EN/IEC 60146-1-1/7.4.1  
Détermination des pertes pour les assemblages et les équipements selon EN/IEC 60146-1-1/7.4.1

Input power / Puissance à l'entrée : 29.5 kW

Output power / Puissance à la sortie : 26.55 kW

$\eta = P_{out}/P_{in} = 0.892$

Temperature rise test according to EN/IEC 60146-1-1/7.4.2  
Essai d'échauffement selon EN/IEC 60146-1-1/7.4.2

Output voltage / Tension de sortie : 129.2 V   
Output current / Intensité de sortie : 200 A   
Duration / durée : h

Measured temperatures / Températures mesurées :

Power Transformer / Transformateur de puissance °C

Choke / Self °C

Thyristor bridge / pont thyristor °C

Ambient temperature / Température ambiante °C

You will find the graph and the tab of datas enclosed

Power factor measurement according to EN/IEC 60146-1-1/7.4.3  
Mesure du facteur de puissance selon EN/IEC 60146-1-1/7.4.3

cos  $\varphi = 0.86$


Reviewed/Released  
On behalf of : S.G.S.  
Print Name : M. ...  
Signature : ...  
Date : 6/21/2013

Reviewed/Released  
On behalf of : S.G.S.  
Print Name : M. ...  
Signature : ...  
Date : 6/21/2013

Audible noise according to EN/IEC 60146-1-1/7.7  
Bruit audible selon EN/IEC 60146-1-1/7.7

Shock protection / Protection contre les contacts   
Protection mode / Mode de protection   
Protection class / Classe de protection   
Fusc / Fusible   
MCCBs, MCBs / Disjoncteurs

Checking of auxiliary devices according to EN/IEC 60146-1-1/7.5.1  
Contrôle des dispositifs auxiliaires selon EN/IEC 60146-1-1/7.5.1   
Checking the protective devices according to EN/IEC 60146-1-1/7.5.3  
Contrôle des dispositifs de protection selon EN/IEC 60146-1-1/7.5.3



Inspections and test performed  
Inspections et essais réalisés

Result / Résultat  
complaints  
Réclamation

n.k.

Additional tests according to EN/IEC 60146-1-17.7  
Essais supplémentaires selon EN/IEC 60146-1-17.7

- 16h testrun, result attached.

burn in > 16 hours recifier 125 V / 200 A

03/07/2013

time	voltage	current	voltage/2	Current/4	transforme	dc choke	bridge	entry airf	exit airf
00:08:06	129.6	199.0	64.8	49.8	53.9	35.1	29.9	24.4	27.0
00:11:06	129.9	200.0	65.0	50.0	53.6	33.9	24.3	24.3	29.2
00:18:06	129.8	199.8	64.9	50.0	56.0	36.2	33.8	23.7	32.0
00:22:06	129.6	200.8	64.8	50.2	58.2	39.2	34.6	24.4	33.4
00:23:06	129.5	199.9	64.8	50.0	58.9	39.9	35.2	24.3	34.4
00:33:06	130.0	200.2	65.0	50.1	58.6	37.4	35.8	24.4	35.3
00:38:06	129.8	199.3	64.9	49.8	60.5	39.3	36.6	24.1	36.2
00:43:06	129.9	200.1	65.0	50.0	62.2	40.7	37.0	24.6	37.0
00:48:06	129.8	200.0	64.9	50.0	64.7	43.3	37.0	24.8	37.1
00:53:06	130.1	199.7	65.1	49.9	64.7	42.0	37.0	25.0	37.0
01:03:06	129.8	199.7	64.9	49.9	65.1	41.5	37.2	24.5	37.6
01:08:06	129.9	199.9	65.0	50.0	68.8	45.5	37.6	24.5	37.9
01:13:06	129.5	200.0	64.8	50.0	69.5	45.0	38.0	24.4	38.4
01:18:06	129.7	200.2	64.9	50.1	69.2	44.0	37.7	24.8	38.1
01:23:06	129.5	199.7	64.8	49.9	70.0	44.8	37.9	24.9	39.1
01:28:06	129.2	200.5	64.6	50.1	72.0	46.2	38.1	24.4	38.7
01:33:06	129.7	200.0	64.9	50.0	74.0	48.5	38.3	24.9	38.5
01:38:06	130.1	199.4	65.1	49.9	73.7	47.5	38.2	25.2	38.7
01:43:06	129.7	199.7	64.9	49.9	73.8	46.6	38.4	25.2	38.9
01:48:06	129.9	200.0	65.0	50.0	75.2	48.2	38.6	25.2	39.3
01:53:06	129.8	200.3	64.9	50.1	76.9	50.3	38.7	25.5	39.2
01:58:06	130.1	199.8	65.1	50.0	77.1	50.0	38.7	25.0	39.2
02:03:06	130.1	200.3	65.1	50.1	76.5	48.1	38.9	25.5	39.8
02:08:06	129.7	200.0	64.9	50.0	77.7	49.8	39.2	25.5	39.9
02:13:06	129.9	199.5	65.0	49.9	79.5	51.9	39.1	25.7	39.8
02:18:06	129.4	199.7	64.7	49.9	79.8	51.8	39.1	25.2	39.7
02:23:06	130.1	200.2	65.1	50.1	79.7	51.6	39.0	25.2	39.8
02:28:06	129.5	199.7	64.8	49.9	79.8	51.1	39.1	25.3	40.1
02:33:06	129.8	200.0	64.9	50.0	81.3	52.2	39.3	25.5	40.2
02:38:06	130.1	199.6	65.1	49.9	82.0	53.2	39.6	25.2	40.4
02:43:06	129.8	200.3	64.9	50.1	82.1	53.4	39.2	25.1	40.1
02:48:06	129.7	199.5	64.9	49.9	81.1	51.7	39.3	25.4	40.2

On behalf of  
Print Name  
Signature  
Date

БЮРО С ОБРАЗЦА  
БЪЛГАРИЯ  
БЪЛГАРСКО  
СТАРА ЗАГОРА  
МАШИНОСТРОИТЕЛНО  
ПРОИЗВОДСТВО

Tester / Contrôleur : L. Maugard  
Supervisor / Superviseur : P. P. 503101 565  
Date: 03/07/2013  
Date: 03/07/2013

This document has been drawn up electronically and released and is valid without signature.  
Ce document a été rédigé électroniquement et approuvé et il est valid sans signature.



burn in > 16 hours rectifier 125 V / 200 A

03/07/2013

time	voltage	current	voltage/2	Current/4	transforma	dc choke	bridge	entry airf	exit airf1
02:55:06	129.8	200.2	64.9	50.1	82.8	53.7	39.5	25.2	40.5
02:58:06	129.8	199.7	64.9	49.9	84.6	55.8	39.7	25.3	40.3
03:03:06	129.7	199.8	64.9	50.0	84.0	54.0	39.5	25.4	40.2
03:08:06	129.5	199.4	64.8	49.9	83.3	53.1	39.5	25.5	40.3
03:13:06	129.9	200.2	65.0	50.1	84.2	53.7	39.6	25.5	40.4
03:18:06	129.7	199.7	64.9	49.9	85.9	56.5	39.7	25.5	40.3
03:23:06	129.7	199.5	64.9	49.9	85.7	55.7	39.5	25.5	40.3
03:28:06	129.7	199.9	64.9	50.0	84.8	53.9	39.6	25.5	40.4
03:33:06	129.6	199.5	64.8	49.9	85.1	55.1	39.7	25.7	40.5
03:38:06	129.6	199.3	64.8	49.8	87.1	56.9	39.9	25.5	40.5
03:43:06	129.8	199.9	64.9	50.0	87.0	56.4	39.9	25.7	40.3
03:48:06	129.8	200.0	64.9	50.0	86.1	55.0	39.7	25.6	40.5
03:53:06	129.8	199.7	64.9	49.9	86.3	56.0	39.8	25.6	40.5
03:58:06	129.3	200.0	64.7	50.0	88.3	57.4	40.1	25.6	40.8
04:03:06	129.8	199.8	64.9	50.0	88.1	57.4	40.1	25.8	40.4
04:08:06	129.9	199.5	65.0	49.9	87.1	55.7	39.9	25.6	40.5
04:13:06	130.1	200.0	65.1	50.0	87.3	55.7	39.9	25.8	40.5
04:18:06	129.9	199.9	65.0	50.0	88.5	57.2	40.0	25.8	40.6
04:23:06	129.5	199.9	64.8	50.0	89.0	57.3	40.1	25.6	40.6
04:28:06	129.7	199.5	64.9	49.9	88.6	57.2	40.0	25.8	40.5
04:33:06	129.8	200.0	64.9	50.0	88.1	56.1	39.9	25.6	40.7
04:38:06	130.1	200.0	65.1	50.0	89.1	57.2	40.2	25.5	40.7
04:43:06	129.7	199.4	64.9	49.9	89.4	57.6	40.1	25.7	40.6
04:48:06	129.8	200.2	64.9	50.1	89.3	57.9	39.9	25.6	40.7
04:53:06	129.7	199.4	64.9	49.9	88.0	55.6	39.9	25.6	40.8
04:58:06	129.7	199.1	64.9	49.8	89.7	57.6	40.2	25.5	40.8
05:03:06	129.9	199.9	65.0	50.0	91.1	59.4	40.2	25.6	40.8
05:08:06	129.8	199.5	64.9	49.9	89.9	58.1	40.0	25.6	40.7
05:13:06	129.7	199.7	64.9	49.9	88.7	56.1	40.0	25.5	40.7
05:18:06	130.2	199.4	65.1	49.9	90.0	58.0	40.1	25.4	40.7
05:23:06	129.8	199.7	64.9	49.9	91.0	60.2	40.1	25.5	40.7
05:28:06	129.5	199.5	64.8	49.9	90.3	58.3	39.9	25.3	40.6
05:33:06	129.8	199.7	64.9	49.9	89.5	57.1	40.0	25.4	40.9

2/7

Reviewed/Witnessed/Released  
On behalf of JGS  
Print Name: [Signature]  
Signature: [Signature]  
Date: 03/07/2013

burn in > 16 hours rectifier 125 V / 200 A

03/07/2013

time	voltage	current	voltage/2	Current/4	transforma	dc choke	bridge	entry airf	exit airf1
05:38:06	129.5	199.8	64.8	50.0	90.4	57.8	40.0	25.4	40.9
05:43:06	129.6	199.6	64.8	49.9	91.3	60.4	40.1	25.3	40.8
05:48:06	129.9	199.4	65.0	49.9	91.0	58.9	39.9	25.3	40.8
05:53:06	129.7	199.9	64.9	50.0	90.0	57.3	39.9	25.2	40.9
05:58:06	129.8	199.9	64.9	50.0	90.2	58.5	40.0	25.1	40.9
06:03:06	129.7	199.7	64.9	49.9	91.6	60.2	40.0	25.1	40.9
06:08:06	129.8	199.6	64.9	49.9	91.5	59.3	40.0	25.2	40.7
06:13:06	129.9	199.5	65.0	49.9	90.2	57.2	39.8	25.1	40.8
06:18:06	129.5	199.6	64.8	49.9	90.5	58.6	39.9	25.2	40.8
06:23:06	129.7	200.0	64.9	50.0	92.0	60.5	40.1	25.1	40.8
06:28:06	130.2	199.5	65.1	49.9	91.6	59.3	39.9	25.1	40.6
06:33:06	129.3	200.3	64.7	50.1	91.2	59.1	39.8	25.1	40.7
06:38:06	129.4	199.2	64.7	49.8	90.6	58.1	39.8	25.2	40.7
06:43:06	129.8	199.5	64.9	49.9	91.4	58.9	40.0	25.1	40.7
06:48:06	130.0	199.3	65.0	49.8	92.7	61.1	39.9	25.0	40.9
06:53:06	129.6	199.8	64.8	50.0	91.3	59.3	39.7	25.0	40.7
06:58:06	129.9	200.0	65.0	50.0	90.3	58.3	39.8	25.0	40.8
07:03:06	129.7	200.1	64.9	50.0	91.4	59.0	39.8	24.9	40.8
07:08:06	129.6	199.5	64.8	49.9	92.4	60.9	39.9	24.9	40.6
07:13:06	129.9	199.6	65.0	49.9	91.9	59.5	39.6	24.9	40.6
07:18:06	129.7	199.8	64.9	50.0	90.8	58.0	39.6	24.8	40.8
07:23:06	129.5	199.4	64.8	49.9	91.0	59.0	39.6	24.9	40.8
07:28:06	129.9	199.8	65.0	50.0	92.1	60.6	39.8	24.9	40.9
07:33:06	130.0	199.6	65.0	49.9	92.2	60.0	39.7	24.9	40.4
07:38:06	129.6	200.1	64.8	50.0	91.1	58.8	39.6	24.8	40.4
07:43:06	129.8	199.2	64.9	49.8	90.9	58.6	39.5	24.8	40.6
07:48:06	129.8	199.3	64.9	49.8	91.7	59.3	39.6	24.8	40.5
07:53:06	129.6	199.2	64.8	49.8	92.8	61.3	39.7	24.7	40.4
07:58:06	129.9	198.8	65.0	49.7	91.8	59.9	39.4	24.7	40.6
08:03:06	129.8	199.5	64.9	49.9	90.8	58.3	39.5	24.7	40.7
08:08:06	129.4	199.9	64.7	50.0	91.5	59.4	39.5	24.7	40.9
08:13:06	129.7	200.2	64.9	50.1	92.5	61.1	39.6	24.7	40.3
08:18:06	130.1	199.8	65.1	50.0	92.1	60.5	39.5	24.6	40.6

3/7

Reviewed/Witnessed/Released  
On behalf of JGS  
Print Name: [Signature]  
Signature: [Signature]  
Date: 03/07/2013

time	voltage	current	voltage/2	Current/4	transforme	dc choke	bridge	entry airf	exit airf1
08:23:06	129.5	199.8	64.8	50.0	90.8	58.2	39.4	24.7	40.5
08:28:06	129.8	199.8	64.9	50.0	91.1	59.2	39.4	24.6	40.8
08:33:06	129.7	199.8	64.9	50.0	92.6	61.0	39.6	24.6	40.5
08:38:06	130.0	199.7	65.0	49.9	92.1	60.0	39.4	24.5	40.3
08:43:06	130.2	200.2	65.1	50.1	91.8	59.9	39.2	24.4	40.5
08:48:06	129.5	199.9	64.8	50.0	90.2	57.8	39.2	24.5	40.5
08:53:06	129.8	199.6	64.9	49.9	91.7	59.7	39.4	24.5	40.8
08:58:06	129.9	199.8	65.0	50.0	92.6	61.4	39.5	24.4	40.5
09:03:06	129.7	199.3	64.9	49.8	91.9	59.6	39.1	24.4	40.3
09:08:06	130.0	199.4	65.0	49.9	90.8	58.3	39.3	24.5	40.5
09:08:06	130.0	199.4	65.0	49.9	90.8	58.3	39.3	24.5	40.6
09:13:06	129.6	199.3	64.8	49.8	90.8	59.3	39.3	24.4	40.6
09:18:06	130.1	199.9	65.1	50.0	92.3	60.9	39.3	24.3	40.8
09:23:06	129.7	199.5	64.9	49.9	91.9	60.4	39.3	24.3	40.7
09:23:06	129.7	199.5	64.9	49.9	91.9	60.4	39.3	24.3	40.6
09:28:06	129.6	199.3	64.8	49.8	91.3	60.1	39.1	24.3	40.4
09:33:06	130.0	199.2	65.0	49.8	90.4	57.8	39.0	24.2	40.6
09:38:06	129.7	199.9	64.9	50.0	91.5	59.6	39.3	24.2	40.4
09:43:06	129.7	200.0	64.9	50.0	92.3	61.4	39.2	24.1	40.4
09:48:06	130.0	200.0	65.0	50.0	91.9	60.0	38.9	24.2	40.3
09:53:06	129.9	199.9	65.0	50.0	90.8	58.7	39.0	24.1	40.4
09:58:06	129.4	199.9	64.7	50.0	90.9	59.3	39.1	24.1	40.7
09:58:06	129.4	199.9	64.7	50.0	90.9	59.3	39.1	24.1	40.5
10:03:06	130.1	200.0	65.1	50.0	92.4	61.2	39.2	24.1	40.3
10:08:06	129.4	199.8	64.7	50.0	91.8	59.8	39.1	24.0	40.3
10:13:06	129.5	200.1	64.8	50.0	91.5	60.1	39.0	24.0	40.5
10:13:06	129.5	200.1	64.8	50.0	91.5	60.1	39.0	24.0	40.6
10:18:06	129.7	199.8	64.9	50.0	90.2	58.0	39.0	24.0	40.6
10:23:06	129.6	199.9	64.8	50.0	91.3	59.5	39.1	23.9	40.5
10:23:06	129.6	199.9	64.8	50.0	91.3	59.5	39.1	23.9	40.5
10:28:06	129.7	200.0	64.9	50.0	92.2	61.6	39.2	24.0	40.4
10:28:06	129.7	200.0	64.9	50.0	92.2	61.6	39.2	24.0	40.4
10:33:06	129.8	199.8	64.9	50.0	91.9	60.4	39.0	23.9	40.4
10:33:06	129.8	199.8	64.9	50.0	91.9	60.4	39.0	23.9	40.4
10:38:06	129.8	199.8	64.9	50.0	90.6	58.3	38.9	23.9	40.2
10:38:06	129.8	199.8	64.9	50.0	90.6	58.3	38.9	23.9	40.6
10:43:06	129.8	199.8	64.9	50.0	90.6	59.1	38.9	23.9	40.5
10:48:06	129.9	200.1	65.0	50.0	91.4	59.7	39.0	23.8	40.2
10:48:06	129.9	200.1	65.0	50.0	91.4	59.7	39.0	23.8	40.2
10:53:06	129.9	199.4	65.0	49.9	92.7	61.6	39.0	23.8	40.4
10:58:06	129.6	199.3	64.8	49.8	91.2	59.7	38.8	23.8	40.4
10:58:06	129.6	199.3	64.8	49.8	91.2	59.7	38.8	23.8	40.4
11:03:06	129.8	200.3	64.9	50.1	90.4	58.6	38.8	23.8	40.3

417

Reviewed/Witnessed/Released  
 On behalf of SCS  
 Print Name  
 Signature  
 Date 03/07/2013

time	voltage	current	voltage/2	Current/4	transforme	dc choke	bridge	entry airf	exit airf1
11:08:06	129.8	199.9	64.9	50.0	90.7	59.5	38.8	23.8	40.6
11:13:06	129.8	199.8	64.9	50.0	91.8	60.7	38.9	23.8	40.3
11:18:06	129.6	199.5	64.8	49.9	91.6	60.1	38.8	23.8	40.1
11:23:06	129.7	199.8	64.9	50.0	91.2	59.8	38.6	23.7	40.4
11:28:06	129.7	200.0	64.9	50.0	89.7	57.8	38.5	23.6	40.4
11:33:06	129.6	199.8	64.8	50.0	91.1	59.0	38.8	23.6	40.6
11:38:06	129.8	199.7	64.9	49.9	91.9	61.4	38.8	23.6	40.4
11:43:06	129.9	199.8	65.0	50.0	91.6	60.2	38.7	23.6	40.3
11:48:06	130.0	199.9	65.0	50.0	90.4	58.4	38.6	23.6	40.1
11:53:06	129.4	200.0	64.7	50.0	90.5	58.8	38.5	23.6	40.3
11:58:06	130.0	199.4	65.0	49.9	91.2	59.6	38.7	23.6	40.4
11:58:06	130.0	199.4	65.0	49.9	91.2	59.6	38.7	23.6	40.4
12:03:06	129.7	199.7	64.9	49.9	92.0	61.4	38.7	23.6	40.3
12:08:06	129.7	200.0	64.9	50.0	91.5	59.9	38.5	23.5	40.1
12:13:06	129.6	200.2	64.8	50.1	90.4	58.1	38.5	23.5	40.2
12:18:06	129.9	199.8	65.0	50.0	90.3	59.0	38.5	23.4	40.3
12:23:06	129.6	199.5	64.8	49.9	91.2	59.6	38.7	23.4	40.3
12:28:06	129.6	199.3	64.8	49.8	92.2	61.3	38.6	23.4	40.2
12:33:06	130.0	199.5	65.0	49.9	91.1	59.4	38.4	23.3	40.2
12:38:06	129.9	199.8	65.0	50.0	90.1	58.2	38.4	23.4	40.2
12:43:06	130.1	199.9	65.1	50.0	90.4	59.1	38.4	23.4	40.1
12:48:06	130.0	200.3	65.0	50.1	91.7	60.6	38.7	23.3	40.3
12:53:06	129.8	199.8	64.9	50.0	91.4	59.8	38.5	23.3	40.1
12:58:06	129.6	199.9	64.8	50.0	91.0	59.7	38.2	23.3	40.1
13:03:06	129.6	199.9	64.8	50.0	90.2	58.3	38.3	23.3	40.0
13:08:06	129.8	199.3	64.9	49.8	90.3	59.1	38.4	23.3	40.1
13:13:06	129.5	200.0	64.8	50.0	91.6	60.7	38.5	23.2	40.0
13:18:06	129.9	199.9	65.0	50.0	91.4	59.9	38.4	23.2	39.8
13:23:06	129.9	199.5	65.0	49.9	91.0	59.6	38.2	23.2	39.9
13:28:06	130.1	199.9	65.1	50.0	90.0	58.2	38.3	23.2	40.0
13:33:06	129.6	199.5	64.8	49.9	90.4	58.8	38.3	23.3	39.9
13:38:06	130.0	200.0	65.0	50.0	91.4	60.8	38.4	23.2	40.1
13:43:06	129.5	199.9	64.8	50.0	91.3	59.9	38.3	23.2	39.7
13:48:06	129.7	200.1	64.9	50.0	90.8	58.8	38.2	23.1	39.7

БЪЛГАРСКО  
СТАНДАРТИЗМА



Reviewed/Witnessed/Released  
 On behalf of SCS  
 Print Name  
 Signature  
 Date 03/07/2013

time	voltage	current	voltage/2	Current/4	transforma	dc choke	bridge	entry airf	exit airf1
13:53:06	129.9	200.1	65.0	50.0	89.9	58.0	38.2	23.2	39.9
13:58:06	129.8	199.8	64.9	50.0	90.6	58.6	38.2	23.1	39.9
14:03:06	129.6	200.0	64.8	50.0	91.3	60.6	38.3	23.1	39.9
14:08:06	129.9	200.2	65.0	50.1	91.2	59.8	38.2	23.1	39.8
14:13:06	130.1	200.3	65.1	50.1	90.8	59.7	38.1	23.0	39.6
14:18:06	130.0	199.9	65.0	50.0	89.6	57.7	38.2	23.1	40.1
14:23:06	129.7	200.2	64.9	50.1	90.7	58.6	38.2	23.1	39.7
14:28:06	130.1	200.2	65.1	50.1	91.3	60.8	38.2	23.0	39.9
14:33:06	129.8	199.7	64.9	49.9	91.3	60.0	38.2	23.1	39.7
14:38:06	129.5	200.0	64.8	50.0	90.6	59.7	38.1	23.0	39.7
14:43:06	129.7	200.0	64.9	50.0	89.6	57.3	38.0	23.1	39.8
14:48:06	129.7	200.3	64.9	50.1	90.5	58.6	38.1	23.1	39.9
14:53:06	130.0	200.0	65.0	50.0	91.2	60.8	38.3	23.2	39.8
14:58:06	129.7	199.9	64.9	50.0	91.1	59.6	38.2	23.1	39.7
15:03:06	130.0	199.3	65.0	49.8	90.6	59.6	38.0	23.1	39.6
15:08:06	130.1	199.8	65.1	50.0	89.3	57.4	38.1	23.1	39.7
15:13:06	129.9	200.3	65.0	50.1	90.6	58.8	38.2	23.1	39.9
15:18:06	129.7	200.2	64.9	50.1	91.1	60.8	38.2	23.1	39.5
15:23:06	130.1	199.9	65.1	50.0	91.3	59.2	38.3	23.3	39.1
15:28:06	129.5	199.8	64.8	50.0	90.8	59.0	38.2	23.3	39.2
15:33:06	129.9	199.3	65.0	49.8	89.3	57.1	38.1	23.3	39.4
15:38:06	129.9	199.9	65.0	50.0	90.7	58.2	38.2	23.3	39.4
15:43:06	129.7	199.8	64.9	50.0	91.3	60.7	38.4	23.4	39.6
15:48:06	129.3	200.0	64.7	50.0	91.1	59.6	38.3	23.5	39.8
15:53:06	130.3	199.7	65.2	49.9	90.6	59.2	38.2	23.4	39.7
15:58:06	130.0	200.2	65.0	50.1	89.2	56.5	38.2	23.5	39.4
16:03:06	129.7	199.4	64.9	49.9	90.5	58.0	38.2	23.6	39.3
16:08:06	130.1	199.4	65.1	49.9	91.4	60.4	38.2	23.4	39.2
16:13:06	129.3	200.2	64.7	50.1	91.3	59.1	38.1	23.2	39.0
16:18:06	129.5	199.8	64.8	50.0	90.5	58.7	37.9	23.1	38.9
16:23:06	129.8	199.9	64.9	50.0	89.6	56.9	37.9	23.1	39.1
16:28:06	129.6	199.5	64.8	49.9	90.6	58.5	37.9	23.1	39.2
16:33:06	130.1	199.9	65.1	50.0	91.4	60.2	38.1	23.1	39.0

6/7



Received/Witnessed/Released  
 On behalf of SCS  
 Plant Name  
 Signature  
 Date 03/07/2013


time	voltage	current	voltage/2	Current/4	transforme	dc choke	bridge	entry airf	exit airf1
16:38:06	130.0	200.3	65.0	50.1	91.4	58.8	38.1	23.3	39.1
16:43:06	129.5	200.5	64.8	50.1	90.1	56.9	37.9	23.1	38.9
16:48:06	129.7	200.3	64.9	50.1	90.2	57.9	37.9	23.3	39.2
16:53:06	129.6	200.0	64.8	50.0	90.7	58.4	37.9	23.2	39.6
16:58:06	129.7	200.0	64.9	50.0	91.3	60.3	38.1	23.3	39.4
17:03:06	129.4	199.5	64.7	49.9	91.1	59.3	38.1	23.4	39.2
17:08:06	129.7	200.1	64.9	50.0	89.8	57.2	37.7	23.3	39.3
17:13:06	129.6	200.1	64.8	50.0	89.7	58.0	37.8	23.3	39.5
17:18:06	129.7	200.1	64.9	50.0	90.5	58.7	38.0	23.3	39.5
17:23:06	129.8	200.3	64.9	50.1	91.8	60.3	38.1	23.0	38.8
17:28:06	129.5	199.9	64.8	50.0	91.1	58.4	38.3	22.1	38.3
17:33:06	129.7	200.3	64.9	50.1	90.0	57.0	37.7	22.1	38.5
17:38:06	130.0	200.0	65.0	50.0	89.8	57.6	37.5	22.0	38.4
17:43:06	129.5	200.5	64.8	50.1	90.5	58.6	37.9	22.8	38.5

Received/Witnessed/Released  
 On behalf of SCS  
 Plant Name  
 Signature  
 Date 03/07/2013



Burn in Acclim 125V/200A






**BENNING**  
 AUTOMATIC BATTERY CHARGER  
 27100 LOUVERNOIS FRANCE

**125VDC SYSTEM**  
 DC BATTERY CHARGER 125V/200A ELECTRICAL DRAWING (SHEET 1/2)

PLAN N° **N3549 / 0**  
 05



**BENNING**  
 AUTOMATIC BATTERY CHARGER  
 27100 LOUVERNOIS FRANCE

**125VDC SYSTEM**  
 125V/200A DC CHARGER ELECTRICAL DRAWING (SHEET 2/2)

PLAN N° **N3549 / 0**  
 06

Lignes

Numero d'article	Index	Nom d'article	Numero de dessin	Groupe d'article	Unité	Quantité de commande standard	Quantité de commande min.	Quantité de commande standard	Quantité de commande min.	Prix de revient	Prix
6110442		RECT D380G125700 TDG3 PSJ1898		FIG	Pcs	1,00	0,00	1,00	0,00	0,00	0,00
780030		RESISTOR 28 24*130 70W		Article		1,0000		1	Pcs	R10	
786483		WASHER ISOPLAN 20X32MM R10		Article		2,0000		1	Pcs	R10	
786900		SCREW M6 LENGTH 150		Article		1,0000		1	Pcs	R10	
6130016		RESISTOR HEATER 60W 120-240V		Article		1,0000		1	Pcs	R8	
10030683		TDO MAINS FILTER 400V		Article		1,0000		1	Pcs	Z1	
10001005		CAPA TRIPHASE 3x85uF 440VAC M		Article		1,0000		1	Pcs	CO01	
10086254		ELECTROLYTIC CAPACITOR 250V 1 E32 (78.2X147)		Article		14,0000		1	PCS	C10	
787253		RUBBER DISK FOR ELKO Fan		Article		14,0000		1	Pcs	C10	
61300006		WHITE PLASTIC KIT D=76 FOR CA		Article		2,0000		1	Pcs	C10	
584990		MOUNTING PLATE CAPA x9 PSJ003		Article		1,0000		1	Pcs	A10	
547387		RC NETWORK FOR 8 TH BRIDGE		Article		1,0000		1	Pcs	V1 VS	
61307893		BRIDGE 68C 380A 10-500F 500A A		Article		3,0000		1	Pcs	F17	
61300030		SOCKET 1P 18x38 MSC10		Article		1,0000		1	Pcs	F4	
61300851		SOCKET 1P-H MSC10 24208		Article		3,0000		1	Pcs	F17	
61300490		FUSE 10*38 G1 0 SA		Article		1,0000		1	Pcs	F4	
61300503		FUSE 10*38 G2 4A		Article		1,0000		1	Pcs	F17	
61300842		ASSEMBLY 2P CMS 101 FERRAZ		Article		2,0000		1	Pcs	CO01	
61301583		"CB TRI NSK 100P" 100A LV42963		Article		1,0000		1	Pcs	CO01	
61304597		MOSFET TRU DC NSK2305DC LV43421		Article		2,0000		1	Pcs	CO02	
61301477		"ALU. "OF 60" (NS 100x30) 29450"		Article		1,0000		1	Pcs	DO01-0002	
61300898		COUNTS E50 88796 230400VAC U/		Article		1,0000		1	Pcs	TH1.3	
61300895		TC 3 PHASES 1803A1 COG18-70		Article		1,0000		1	Pcs	TH1	
61300850		THERMOSTAT 0-90° C		Article		1,0000		1	Pcs	HU1	
61301000		HYGRO 35%-85% OF STEGO 01220		Article		1,0000		1	Pcs	S4	
61310100		SWITCH ON/OFF HEATER 230V/2A :		Nonventilateur		1,0000		1	Pcs	CAB	
61308790		CABINET PSJ1898 RAL7038 IP41 V91		Nonventilateur		1,0000		1	Pcs	CABINET	
61308760		BASE CAB RAL7038 PSJ1898		Nonventilateur		2,0000		1	Pcs	GRID	
61308760		COVER IP20 800*800 RAL7038		Article		4,0000		1	Pcs		
61308760		CORNER POST 30°*30°1800 RAL7038		Article		2,0000		1	Pcs		
62830F30		BASE FRAME SKURTMG 800mm RAL		Article		2,0000		1	Pcs		
62831F30		FRONT COVER TOP FRAME 800mm		Article		2,0000		1	Pcs		
62833F30		BASE FRAME CROSS BAR 800mm R		Article		2,0000		1	Pcs		
62833F30		SIDE COVER TOP FRAME 800mm R		Article		2,0000		1	Pcs		
61877F30		FRONT DOOR ADAPTATOR PSJ 18C		Article		2,0000		1	Pcs		
62833F30		SIDE COVER TOP FRAME 800mm R		Article		1,0000		1	Pcs		
62840F30		RAISED FACE IP42 PSJ1898 RAL703		Article		2,0000		1	Pcs		
735050		PLASTIC TUB COVER 30*30		Article		4,0000		1	Pcs		
718181		BRACKET CORNER BASE/TOP FRA		Article		8,0000		1	Pcs		
618908		SIDE PANEL ANGLE 1800mm		Article		2,0000		1	Pcs		
61300707		BOTTOM PLATE GALVA 1210 832x7		Article		1,0000		1	Pcs	CABINET	
772578		COLUMN BLACK INF L=100 MM		Article		2,0000		1	Pcs	CABINET	
6189178		SUPPORT ANGLE FOR BASE BLIND		Article		1,0000		1	Pcs	CABINET	
6189178		ADD. FRONT PLATE IP40 PSJ1898X-		Article		1,0000		1	Pcs	CABINET	
6189178		LOCK 028 7010 SW BLACK		Article		2,0000		1	Pcs	CABINET	
6189178		FRONT DOOR HANDLE BLACK		Article		2,0000		1	Pcs	CABINET	
727141		DOOR DAMPER		Article		1,0000		1	Pcs	CABINET	
789077		DOOR HANGERS 1110-05		Article		2,0000		1	Pcs	CABINET	
789077		KEY FOR LOCK 028 7010 SW		Article		1,0000		1	Pcs	CABINET	
61300703		CABLE PLATE GALVA 1910 830x183		Article		1,0000		1	Pcs	CABINET	
785416		HANDLING BOX for DESCRIPTION		Article		1,0000		1	Pcs	CABINET	
514879		SUPPORT TRANSFO. FIXING 900mm		Article		4,0000		1	Pcs	CABINET	
61300294		SWITCH SUPPORT DIAM 22- RAIL C		Article		1,0000		1	Pcs	CABINET	
516192		CROSS ANGLE 800		Article		2,0000		1	Pcs	CABINET	
747130		"ADHESIVE LABEL "BENNING"		Article		1,0000		1	Pcs	CABINET	
61303328		UPPER TRANSFORMER ANGLE 800		Article		1,0000		1	Pcs	CABINET	
61303195		MECHANICAL KIT FOR RECT. PSJ		Nonventilateur		1,0000		1	Pcs	CABINET	
518182		CROSS ANGLE 800		Article		8,0000		1	Pcs	CABINET	
518184		MOUNTING ANGLE PSJ 1280mm		Article		2,0000		1	Pcs	CABINET	
518174		MOUNTING PLATE 320*900		Article		2,0000		1	Pcs	CABINET	
518845		MOUNTING PLATE 160*900		Article		1,0000		1	Pcs	CABINET	
533063		UNIVERSAL CROSS ANGLE 800		Article		2,0000		1	Pcs	CABINET	

Reviewed by  
On behalf of: SCS  
Print Name: A.L.M.  
Signature: [Signature]  
Date: 03/07/2013

This is an uncontrolled document. Please refer to the network for the latest revision

Lignes

Numero d'article	Index	Nom d'article	Numero de dessin	Type d'article	Position	N° ordre	Quantité	Quantité de base	Unité	Designation de composant	Norme
618187		REAR MOUNT ANGLE 30*30 450mm		Article			2,0000		1	Pcs	CABINET
618187		CORNER RETAINING BAR 1800		Article			4,0000		1	Pcs	CABINET
618149F30		SIDE WALL 1800*800 RAL7038		Article			2,0000		1	Pcs	
10007020F30		FRONT DOOR PSJ1898 WITH BOTI		Article			1,0000		1	Pcs	DOOR
618181F30		BASE BLIND VENTIL. PSJ 300 RAL70		Article			1,0000		1	Pcs	
618123F30		TOP OF COVER IP21 800*1600 RAL7		Article			1,0000		1	Pcs	
618148F30		SIDE WALL 1600*800 RAL7038		Article			1,0000		1	Pcs	
61301183		"CB UNB-N DT40N "C" 6A 21364"		Article			1,0000		1	Pcs	Q3
748248		CB 6I 8A 320VDC CB QX-211310		Article			1,0000		1	Pcs	Q8
748256		SHUNT DIN 43703 250A 60mV		Article			1,0000		1	Pcs	RO01
61300031		FAST FUSE 17842768 250A		Article			1,0000		1	Pcs	F7
61300678		M.S. O-F 17840235		Article			1,0000		1	Pcs	F7
61301816		COMP. FRONT STD TDG3		Nonventilateur			1,0000		1	Pcs	A31
6131274		SWITCH 2P		Article	1		1,0000		1	Pcs	S1
751271		COVER FOR SWITCH		Article	2		1,0000		1	Pcs	S1
627895		REAR COVER PLATE THYSAT		Article	3		1,0000		1	Pcs	
648395		COMP. FRONT SDT+TDG3/MCU2501		Article	4		1,0000		1	Pcs	A31
639707		CABLE L=1.5m FOR I2C-BUS		Article	8		1,0000		1	Pcs	DC
684061		COVER FRONT DISPLAY		Article			1,0000		1	Pcs	
529744		THY. FRONT CABLING FOR THY		Article			1,0000		1	Pcs	CABLING
10058218		6 PULSES A/VA3 CABLE SET for W/c		Article			1,0000		1	Pcs	CABLING
610059		CABLE SET THYSAT 3Ph >1500mm		Article			1,0000		1	Pcs	CABLING
549823		MCU BAT 8 RELAY BOX 75-270V		Article			1,0000		1	Pcs	A14
734296		BAT-BUS CABLE RJ45/RJ45 2m		Article			1,0000		1	Pcs	A14/A14
645884		PULSES 6TH THYREQ 3.1		Article			1,0000		1	Pcs	A3
538050		COMP REG THYSAT 3Ph 60-330V		Article			1,0000		1	Pcs	A1
625173		FRONT PLATE M08 BLEU ANALOG		Article			1,0000		1	Pcs	P1
61302183		HEATSINK BRUT 1M16 P4200		Article			1,0000		1	Pcs	VO01
61300090		DIODE 400V 240A S4R240M4 M16		Article			1,0000		1	Pcs	VO01
10007346		DC CHOKER 120V/260A 6mH 18B		Article			1,0000		1	Pcs	L1
61300090		KIT ACCESSORIES FOR TDG 200A		Nonventilateur			1,0000		1	Pcs	
61302056		VIS TH 6X10		Article			4,0000		1	Pcs	
61302058		VIS TH 6X20		Article			30,0000		1	Pcs	
61302084		VIS TH 8X18		Article			6,0000		1	Pcs	
61302099		VIS TH 8X30		Article			8,0000		1	Pcs	
61302102		VIS NYLON 8/18		Article			4,0000		1	Pcs	
61302827		VIS SAN'S TETE 6x18		Article			44,0000		1	Pcs	
61307838		VIS INOX 3 X 12 CRUCI RONDE		Article			4,0000		1	Pcs	
61302100		VIS TAPITTE TCBL 4x20		Article			5,0000		1	Pcs	
786282		VIS TAPITTE TCBL PQ21 2N Blanc M		Article			4,0000		1	Pcs	
61302048		VIS TR AUT. 6X10		Article			10,0000		1	Pcs	
61302120		RONDELLE PLATE BLANC 8		Article			2,0000		1	Pcs	
61302121		RONDELLE PLATE 8		Article			80,0000		1	Pcs	
61302123		RONDELLE PICOT 6X38		Article			4,0000		1	Pcs	
61302128		RONDELLE SWIVEL 8		Article			8,0000		1	Pcs	
61302138		RONDELLE AZ 2x BL Dng 8x13		Article			2,0000		1	Pcs	
61302124		RONDELLE PICOT DIA 3		Article			6,0000		1	Pcs	
61302144		RONDELLE LARGE PLT 6		Article			10,0				

Lignes

Numero d'article	Index	Nom d'article	Numero de dessin	Type d'article	Position	N° optr.	Quantite		Designation de composants	Norme
							de base	Unité		
01301630		BAR DIM PERFORE PDR15		Article			1,4000	1	Pcs	
01301620		COLLIER 100x2.5mm Da=16mm		Article			40,0000	1	Pcs	
01301621		COLLIER 200x4.8mm Da=50mm		Article			20,0000	1	Pcs	
730079		ISOLATOR H30D35M6 F.F		Article			10,0000	1	Pcs	
726083		ISOLATOR H30D35M6		Article			10,0000	1	Pcs	
786187		GROUND LABEL		Article			2,0000	1	Pcs	
01301818		"ETIQ REPERE MASSE "CLEMI"		Article			3,0000	1	Pcs	
01301726		BUTEE BADL 019940802		Article			1,0000	1	Pcs	
01301744		TERMINAL WAGO 2002-1401		Article			18,0000	1	Pcs	
01301745		FLASQUE WAGO 2002-1491		Article			12,0000	1	Pcs	
516912		SPACER L=30mm D=18mm		Article			7,0000	1	Pcs	
01301894		TERMINAL M35/16 11812407		Article			8,0000	1	Pcs	
01301709		TERMINAL M35/16P 10311114		Article			2,0000	1	Pcs	
01301726		BUTEE BADL 019940802		Article			1,0000	1	Pcs	
10050121		TERMINAL PPV 4 CR 36x7.5 DGR		Article			2,0000	1	Pos	
10050122		END PLATE PAP PRIV/PPV4 CR		Article			2,0000	1	Pcs	
10050123		DEVISING PLATE TW PRIV 4 A-D		Article			1,0000	1	Pcs	
10078787		TR. COMOG118220 TDG 60x4x 785 AJ		Article			1,0000	1	Pcs	

On behalf of SGS  
Print Name A. P. P.  
Signature [Signature]  
Date 03/07/2013

This is an uncontrolled document. Please refer to the network for the latest revision



# Certificate

Standard **ISO 9001:2008 and ISO 14001:2004**

Certificate Registr. No. 01 150 079699

TÜV Rheinland Cert GmbH certifies:

Certificate Holder: **Benning Elektrotechnik und  
Elektronik GmbH & Co. KG**  
Münsterstraße 135-137  
Robert-Bosch-Straße 20  
D - 46397 Bocholt

Scope: Development, manufacture and sales of power supply equipment (such as battery chargers, power supply-modules and -systems, rectifiers, inverters, DC-converters) and test- and measurement-devices, as well as repair, or revamping, installation and testing of electrical devices, systems and engines (such as motors and generators)

An audit was performed, Report No. 079699. Proof has been furnished that the requirements according to ISO 9001:2008 and ISO 14001:2004 are fulfilled.  
The due date for all future audits is 08-05 (dd.mm).


Validity: The certificate is valid from 2012-05-22 until 2015-05-21 for ISO 9001 and from 2012-05-22 until 2015-05-21 for ISO 14001.

2012-03-26

  
TUV Rheinland Cert GmbH  
Am Grauen Stein · 51105 Köln





DGA-ZM-58-95-00 / DGA-ZM-58-95-60



ВРХО С



Article No: 2U1186 Rack-Type: 2E-PGU 1-to H Battery: 18 x A412/100,0 A




ВЯРНО С  
ОРИГИНАЛА



Length: 1800 mm

Height incl. battery: HB = 855 mm

Battery Layout: 18 x A412/100.0 A



ВЪРНО С  
ОРИГИНАЛА



**Supplier statement of product range test results**

1) General product type information	
Product manufacturer	Exide Technologies GmbH
Manufacturing site of tested product	Bidingen, Germany
Product model range	Sonnenschein A400
Product comprising the above model range	see Annex 1
Product tested	A412/90 A, as a representative of the range
2) Product test performance information	
IEC 60896-21 test clause result	
6.1 Gas emission (at the float voltage and at 2.40Vpc)	2.27Vpc - 0.026 ml/Cell x h x Ah / 2.40Vpc - 0.271 ml/Cell x h x Ah
6.2 High current tolerance	No.1 - 2.13 Vpc No.2 - 2.13 Vpc No.3 - 2.13 Vpc
6.3 Short circuit and d.c. internal resistance	see Annex 2
6.4 Internal ignition from external spark sources	Passed, no evidence of rapid combustion or explosion beyond valve
6.5 Protection against ground short propensity	< 1mA, passed, no ground short current flow was detected (detection limit 1mA)
6.6 Content and durability of required markings	Passed
6.7 Material identification	Lid: PP Container: PP
6.8 Valve operation	Before: gas release could be detected After: Passed: gas release could be detected
6.9 Flammability rating of materials	Lid and case: according to UL94 HB, for all models except those identified as VO flame retardant: UL94-V0
6.10 Intercell connector performance	Passed, no hazard (max. temperature: 48°C)
IEC 60896-21 test clause result	
6.11 Discharge capacity at 20°C	Compliant (≥ 95%) see Annex 3
C10 : C8 : C3 : C1 : C0.25 :	
6.12 Charge retention during storage	91.5% 90.5% 90.8% 91.7% 91.0% 91.3%
6.13 Float service with daily discharges	Classification: suitable for 'very unreliable mains power' ( more than 300 cycles) Cycles : 950 928 1000 C at : 84.2% 49.8% 62.6% C ab : 86.0% 46.6% 73.8%
6.14 Recharge behavior	24h : 102.0 101.9 101.7 % 168h : 102.2 102.1 102.0 %
IEC 60896-21 test clause result	
6.15 Float service life at 40°C	1086 951 980 Days with C3 rate test at 40°C >80% 1066 906 974 Days with C0.25 rate test at 40°C >80%
6.16 Impact of stress temperature of 55°C or 60°C	353 358 364 Days with C3 rate test at 55°C >80% 298 310 300 Days with C0.25 rate test at 55°C >80%
6.17 Abusive over-discharge	92.46 % unbalanced string over-discharge test cyclic over-discharge test
6.18 Thermal runaway sensitivity	No.1=117% No.2=115% No.3=117% after 168 h with 2.45Vpc: 25.0°C after 168 h with 2.60Vpc: 24.1°C
6.19 Low temperature sensitivity	no damage caused by freezing No.1=112% No.2=113% No.3=109%
6.20 Dimensional stability at elevated internal pressure and temperature	Length: 3.0 mm (0.01%) Width: 11.3 mm (0.04%)
6.21 Stability against mechanical abuse of units during installation	Passed (no leakage)
Company name: Company officer: Address/phone/fax/e-mail: Signature/date/place: Document established as reply for RFI:	
Exide Technologies GmbH Director Product Management Dr. Martin Sienz Im Thiergarten, 63654 Bidingen Bidingen, March 7th, 2012	

NOTE The data in above Product Range Test Result Supplier Statement must comply with the test methods and degree of detail specified in the requirements 6.1 to 6.21 of the IEC 60896-21 and IEC 60896-22

**Certificate of Compliance**  
**IEC 60896-21,-22 (replacing IEC 896-2)**

Herewith GNB Industrial Power declares that Sonnenschein A400 monoblocks (including A412/120 FT) comply with the above mentioned international standard. Please see attached document for further details.

Date: April 2<sup>nd</sup>, 2012  
Bidingen, Germany

Storant  
Svenje Merlant  
Product Management Network Power  
GNB Industrial Power, a Division of Exide Technologies

БЪЛГАРСКО УПРАВЛЕНИЕ НА КАЧЕСТВОТО  
BULGARIAN QUALITY CONTROL ENGINEERING  
СТАР ЗАКОН  
STARA ZAKONA  
ИЗПИТНА СЛУЖБА  
TESTING SERVICE

Supplier statement of product range test results

1.) General product type information	
Product manufacturer	Eside Technologies GmbH
Manufacturing site of tested product	Büdingen, Germany
Product model range	Sonnenschein A400
Product comprising the above model range	A412 / 20 G5 A412 / 32 G6 A412 / 32 F10 A412 / 50 A A412 / 50 F10 A412 / 50 G6 A412 / 65 G6 A412 / 65 F10 A412 / 85 F10 A412 / 90 A A412 / 90 F10 A412 / 100 A A412 / 100 F10 A412 / 120 A A412 / 120 F10 A412 / 120 FT A406 / 165 A A406 / 165 F10 A412 / 170 FT A412 / 180 A A412 / 180 F10

Supplier statement of product range test results

2.) Product Test Performance																																																																			
Product manufacturer	Eside Technologies GmbH																																																																		
Manufacturing site of tested product	Büdingen, Germany																																																																		
Product model range	A400																																																																		
Clause 6.3 Short circuit and DC internal resistance																																																																			
	<table border="1"> <thead> <tr> <th>Product Model</th> <th>Isc [A]</th> <th>RI [mOhm]</th> </tr> </thead> <tbody> <tr><td>A412 / 12 SR</td><td>174</td><td>72.6</td></tr> <tr><td>A412 / 20 G5</td><td>445</td><td>27.8</td></tr> <tr><td>A412 / 32 G6</td><td>667</td><td>18.5</td></tr> <tr><td>A412 / 32 F10</td><td>667</td><td>18.5</td></tr> <tr><td>A412 / 50 A</td><td>1050</td><td>11.8</td></tr> <tr><td>A412 / 50 F10</td><td>1050</td><td>11.8</td></tr> <tr><td>A412 / 65 G6</td><td>1229</td><td>10.0</td></tr> <tr><td>A412 / 65 F10</td><td>1229</td><td>10.0</td></tr> <tr><td>A412 / 85 F10</td><td>1099</td><td>11.3</td></tr> <tr><td>A412 / 90 A</td><td>1744</td><td>7.1</td></tr> <tr><td>A412 / 90 F10</td><td>1744</td><td>7.1</td></tr> <tr><td>A412 / 100 A</td><td>1917</td><td>6.5</td></tr> <tr><td>A412 / 100 F10</td><td>1917</td><td>6.5</td></tr> <tr><td>A412 / 120 A</td><td>1576</td><td>7.8</td></tr> <tr><td>A412 / 120 F10</td><td>1576</td><td>7.8</td></tr> <tr><td>A412 / 120 FT</td><td>1134</td><td>11.2</td></tr> <tr><td>A406 / 165 A</td><td>2419</td><td>2.8</td></tr> <tr><td>A406 / 165 F10</td><td>2419</td><td>2.8</td></tr> <tr><td>A412 / 170 FT</td><td>2432</td><td>5.1</td></tr> <tr><td>A412 / 180 A</td><td>1994</td><td>6.2</td></tr> <tr><td>A412 / 180 F10</td><td>1994</td><td>6.2</td></tr> </tbody> </table>	Product Model	Isc [A]	RI [mOhm]	A412 / 12 SR	174	72.6	A412 / 20 G5	445	27.8	A412 / 32 G6	667	18.5	A412 / 32 F10	667	18.5	A412 / 50 A	1050	11.8	A412 / 50 F10	1050	11.8	A412 / 65 G6	1229	10.0	A412 / 65 F10	1229	10.0	A412 / 85 F10	1099	11.3	A412 / 90 A	1744	7.1	A412 / 90 F10	1744	7.1	A412 / 100 A	1917	6.5	A412 / 100 F10	1917	6.5	A412 / 120 A	1576	7.8	A412 / 120 F10	1576	7.8	A412 / 120 FT	1134	11.2	A406 / 165 A	2419	2.8	A406 / 165 F10	2419	2.8	A412 / 170 FT	2432	5.1	A412 / 180 A	1994	6.2	A412 / 180 F10	1994	6.2
Product Model	Isc [A]	RI [mOhm]																																																																	
A412 / 12 SR	174	72.6																																																																	
A412 / 20 G5	445	27.8																																																																	
A412 / 32 G6	667	18.5																																																																	
A412 / 32 F10	667	18.5																																																																	
A412 / 50 A	1050	11.8																																																																	
A412 / 50 F10	1050	11.8																																																																	
A412 / 65 G6	1229	10.0																																																																	
A412 / 65 F10	1229	10.0																																																																	
A412 / 85 F10	1099	11.3																																																																	
A412 / 90 A	1744	7.1																																																																	
A412 / 90 F10	1744	7.1																																																																	
A412 / 100 A	1917	6.5																																																																	
A412 / 100 F10	1917	6.5																																																																	
A412 / 120 A	1576	7.8																																																																	
A412 / 120 F10	1576	7.8																																																																	
A412 / 120 FT	1134	11.2																																																																	
A406 / 165 A	2419	2.8																																																																	
A406 / 165 F10	2419	2.8																																																																	
A412 / 170 FT	2432	5.1																																																																	
A412 / 180 A	1994	6.2																																																																	
A412 / 180 F10	1994	6.2																																																																	

ВЯРНО С  
КОПИРА



Supplier statement of product range test results

2.) Product Test Performance	
Product manufacturer	Exide Technologies GmbH
Manufacturing site of tested product	Bildesheim, Germany
Product model range	A400

Clause 6.1.1 Discharge capacity at 20 °C

	min	min	min	min	min	min	min	min	min	min
AA12 / 20 G5	C10	649	648	646	628	603	649			
	C8	566	609	554	477	541	595			
	C3	200	209	202	206	211	205			
	C1	67	68	57	66	63	64			
	C0.25	17	19	18	18	18	18			
AA12 / 32 G6	C10	614	608	621	605	620	615			
	C8	506	503	503	502	500	491			
	C3	194	187	180	176	187	186			
	C1	65	66	66	65	64	65			
	C0.25	16	16	16	16	15	16			
AA12 / 50 A	C10	577	573	571	542	577	577			
	C8	465	456	461	464	470	465			
	C3	172	171	171	173	173	172			
	C1	58	57.0	57.0	58.0	58.0	57.0			
	C0.25	15	15	15	14	14	15			
AA12 / 65 G6	C10	595	602	602	590	599	597			
	C8	488	491	498	493	492	492			
	C3	179	181	177	181	178	182			
	C1	57	58	57.0	57.0	58	58			
	C0.25	19	20	19	19	19	19			
AA12 / 85 F10	C10	613	602	609	619	622	624			
	C8	513	521	532	521	506	500			
	C3	186	195	183	182	187	191			
	C1	69	72	66	68	60	65			
	C0.25	18	18	17	17	16	18			
AA12 / 90 A	C10	615	604	598	622	612	621			
	C8	488	493	472	483	470	491			
	C3	188	186	184	188	186	186			
	C1	66	65	66	65	65	66			
	C0.25	17	17	16	17	17	17			
AA12 / 100 A	C10	622	627	627	625	627	621			
	C8	532	539	541	535	542	538			
	C3	205	203	201	206	200	198			
	C1	72	73	74	72	73	71			
	C0.25	17	17	17	16	16	17			
AA12 / 120 A	C10	629	635	647	636	639	606			
	C8	576	580	581	584	576	573			
	C3	207	213	213	215	210	205			
	C1	68	67	67	68	67	66			
	C0.25	19	19	19	19	19	19			
AA12 / 120 FT	C10	629	615	621	613	622	623			
	C8	509	515	520	515	505	503			
	C3	197	188	189	178	194	175			
	C1	64	57	62	66	64	70			
	C0.25	17	17	17	17	17	17			
AA06 / 165 A	C10	654	649	643	632	639	644			
	C8	533	570	594	588	561	510			
	C3	202	207	207	206	206	201			
	C1	74	74	74	70	72	63			
	C0.25	19	19	19	19	19	19			
AA12 / 180 A	C10	651	670	654	657	647	660			
	C8	582	581	566	578	574	578			
	C3	212	211	211	210	210	211			
	C1	75	77	75	79	82	77			
	C0.25	19	19	19	19	19	19			





Inspection and Test Schedule									
	Battery Type: All battery types	Status: Serial Production	Plant: Södingen	ID-No. PAP 1000	NEC conformant	FMEA Status:	ID-No. PAP 0000	Rev. Index 01	
	Working Process: Battery Production	Inspection and Test Schedule Production			Established:	Günter Weibohatz	Date: 08.02.13		
					Approved:	Christine Krawczyk	Date: 08.02.13		

This Inspection and Test Schedule described the correlation of documents and tests for pre, intermediate and final products during the different production steps.

List of used abbreviations

DC = Dry Charge (tank formation)  
 DF = Direct formation  
 GF = Gel formation  
 CL = Closed Loop formation

FA W = production procedure  
 RA W = Setting up procedure  
 MT W = Measuring table  
 PP = Test/Inspection plan

PA = Test/Inspection procedure  
 MV = Material Specification

Seq. No.	Process	Machine/Device	Product	Specification/Process		Test/Inspection Specifications			Date collection	Measure to be taken at non-conformance
				Materials	Process procedure	Measuring Device Measuring Methods	Test Plan	Test/Inspection Procedure		
1	Decasting	Wirtz C40 Wirtz C80	Positive Grid Pb/CaSn, with respect without Cu Negative Grid Pb/CaSn without Cu	High pressure decasting MV B25, B27 MV 10,23 High pressure decasting MV B33 MV 10,23 in addition MV B01, B31 Recycling test	FA W 708, 707, 709 FA W 708, 711, 712, 729 MT W 708 RA W 708	Weighting Test of moisture Spectrometer analysis Visual test	PP 1200 PP 1210 PP 1220 PA 1200 PA 1201 PA 1010	CAQ-System		
2	Lead acid production	Chondo	Outside iron mill	Grinding of ingots	FA W 701, 705	PbO-Content Acid absorption Process parameter	PP 1150 PA 1010 PA 1800 PA 1150 PA 1160	CAQ		
		CAU	Outside for ends mixture	Casting of cylinder and milling	FA W 731a, b, c, d, e, f, g	PbO-Content Acid absorption Process parameter	PP 1160 PA 1160	CAQ Records		
	Grids Mixing	Reactor	Grids mixture for production of plates	Site distributed adding of H2SO4 MV B11	FA W 702	Process parameter Sulfuric content	PP 1170 PA 1170 PA 1171 PA 1800	Record		
	Mixer Chamber filter press	Drive-Mixer	Active masses Recovery of recyclable lead deposit	Dry/Wet mixing production	FA W 715, 734 MT W 715, 718 FA W 730	Lab device Weighting Permeation Temperature	PP 1170 PA 1170 PA 1171 PA 1800	Record		
3	Pasting	Sovema Bendopaster	Pasted grids	Pasting on Sovema and pre-drying restoration of paste mass	FA W 718, 717 FA W 732, 733, 734 MT W 715, 718 RA W 718 FA W 718	Weighting Residual moisture content Visual test Test of moisture	PP 1250 PP 1270 PA 1250 PA 1270 PA 1270a PA 1170 PA 1300	CAQ-System		
4	Curing	OSI-Chamber Insulation-Chamber Cast-Chamber	Cured neg. plates Cured pos. Plates	Curing in curing chambers Curing in curing chambers	FA W 718 MT W 718	Analysis Visual test Physic. Tests	PP 1270 PA 1270a	Batch card		

Seite 1 von 8

Inspection and Test Schedule									
	Battery Type: All battery types	Status: Serial Production	Plant: Södingen	ID-No. PAP 1000	NEC conformant	FMEA Status:	ID-No. PAP 0000	Rev. Index 01	
	Working Process: Battery Production	Inspection and Test Schedule Production			Established:	Günter Weibohatz	Date: 08.02.13		
					Approved:	Christine Krawczyk	Date: 08.02.13		
5	Tank formation	Formation-series	Iron formed, dried plates	Assembly and disassembly of plates Carry out of formation Programme of currents	FA W 721 MT W 721, 721b	Add density Temperature Visual test Formation programs	PP 1300 PP 1310 PA 1800	Records Correction software	
4	Washing Drying	OSI-Equipment	Washed and dried, formed pos. and neg. plates	Washing, drying	FA W 723 MT W 722, MT W 708	Analysis of bath Temperature Analysis of plates Visual test Residual moisture content Vibration resistance	PP 1350 PA 1350 PA 1381 PA 1800	Batch card Batch record	
7	Separation - brushing	Grinding shop	Assembly-ready formed plates	Cleaning/brushing	FA W 724, 723, 728, 727, 728 MT W 726 RA W 723, 728, 727	Measure test (miscellaneous) Visual tests	PP 1400 PA 1400	OK	
6	Plate set production CO3	Stecher CO3	Structure of plate sets CO3 and return, plate set easy	Production of plate sets CO3 CO3 CO3 S, B1, B2, B3	FA W 802, 804, 805, 804 FA W 878, 882, 884 MT W 802, 802a, 804, 804b, MT W 878, 878b, 879a, MT W 882, 882b RA W 802, 804a, 804b, RA W 878, 882, FA W 833 (File: TB, WAG)	Embedding Adherent Analysis of alloy Visual test Measure test Polished microsection test	PP 1450 PA 1450 PA 1777 PA 1010 PA 1800 PA 1300	PCL AGB	
	Production of cork Plate set production Manual washing	Welding Jig	Plate set	Plate set production CO3 18 by manual welding	FA W 807, MT W 807	Embedding Alignment			

Seite 2 von 8

DRPHO C



Inspection and Test Schedule											
		Battery Type: All battery types	Status: Serial Production	Plant: Södingen	ID-No. PAP 1000	TSELA certification	FMEA Status:	ID-No. PAP 1000	Rev. Index 01		
Working Process: Battery Production		Inspection and Test Schedule Production			Established:	Göster Weisholz		Date: 05.02.13			
					Approved:	Christine Krawczyk		Date: 05.02.13			
9	Battery assembly	Assembly line 1361, 1362, 1363, 1364	Assembled unfilled batteries	Assembly and mounting	FAW 801, 801b FAW 813, 812 FAW 813, 814, 818 FAW 818, 817, 817a, 819 FAW 821b, 826, 826, 828 FAW 884, 825, 887, 888 FAW 889a, 893, 893 MTW 801a, 801b, 801c MTW 808a, 808c MTW 810a, 810c, 810d MTW 812, 812a, 818a MTW 817, 826 MTW 887a, 887b, 887c, 888 RAW 801, 810, 816a, 821, 828 RAW 887, 888, 890, 892, 903	HSP- Short circuit test Faulty polarization HSE: Venting current monitoring Revolving breaking test Diagnosis in pressure Decompressing test Measure test	PP 1800	PA 1800 PA 1801 PA 1802 PA 1804 PA 1805 PA 1808 PA 1809 PA 1830	DEK PCL ASK		
	Return shipment			Residual amount of battery disassembly	FAW 884 (File PM)						
	Container punching	Punching machine Maid		Punching of container and insert. Screwdriver	FAW 816, 818a, MTW 818a RAW 818a	Gauge test	PP1382		ASK		
	Re-work	Assembly line	Finished batteries	Re-work	FAW 808, FAW 827						
10	Get production DC, GP 18a 18b 18c	Get mixing dept.	Electrolyt DC, GP	Get preparation Mixing of three acid Mixing of acid measure Mixing of Gel	FAW 845, 845, 884 MTW 852, 850a MTW 871, 871b	Temperature H2SO4 H2SO4	PA 1806	PA 1810	Computer		
11	Get filling	Filling machine	Batteries filled with Gel (DC and GF)	Filling of Gel electrolyt DC and GF Get release for dryfill-batteries Carry out of filling and connection to charging circuits Filling of commissioning water bathes or acid mixing	FAW 851, 854, 884, 888, MTW 851a, 851g, 888b  FAW 874, MTW 878, MTW 873a	Open-circuit-voltage Filling weight Filling height Temperature of Gel Commissioning-temperature (GF) Water level of bathes (GF)	PP 1800  PP 2005	PA 1810 PA 1800	PCL		
11a	Acid filling DF and formation	Direct formation	Batteries filled with acid (DF)	Carry out of filling (DF), transport to water bathes and connection to charging circuits Formation takes place in the battery	FAW 840, 841, 842, 843, 844 MTW 840, 842, 844a, 844b RAW 840, 842, 844	Filling weight Commissioning-temperature Water level of bathes	PP 2000	PA 1800 PA 1800	BP PCL		


Inspection and Test Schedule									
		Battery Type: All battery types	Status: Serial Production	Plant: Södingen	ID-No. PAP 1000	TSELA certification	FMEA Status:	ID-No. PAP 1000	Rev. Index 01
Working Process: Battery Production		Inspection and Test Schedule Production			Established:	Göster Weisholz		Date: 05.02.13	
					Approved:	Christine Krawczyk		Date: 05.02.13	
11b	Fast Formation	Closed Loop	Fast and charged batteries	Commissioning and Gel filling	MTW 870 MTW 870a, MTW 871a, MTW 872, 873, 873a	Acid density suite Acid density manual Filling weight manual Analysis of acid Leaking man			DEK CAQ CAQ
12	Commissioning DC and GF	Commissioning/ charging circuits	dryfill-batteries	Commissioning/charging current programmes	FAW 851, 851b, 857, 887a, 887b FAW 888 MTW 857, 889a, 889b		PP1803 PP 2005 (GF)		
12	Finishing	Finishing conveyors	dryfill-Batteries	Shoe set storage tank equipment and final production (finishing)	FAW 883 FAW 828a, 842, 843 FAW 828, 828a, 829a, 829b, 829c, 829d, FAW 833, 833a  FAW 884, 886, 888 MTW 828, 842, 842a, 844a, 851b, MTW 828a, 829a, 829b, 829c, 829d, MTW 828, 829a, MTW 828, 890 RAW 842, 843, 852, 852a, RAW 829b, 829c, MTW 874, 878, 875a, 878b	Ball, Manager Commissioning records Open-circuit-voltage HRT HVT Leakage proof of valve Suction level Leakage torque of valve Visual test	PP 1008 (DF) PP 3000 (DF) PP 2005 (GF) PP 1810 PP 1700	PA 1700-1 PA 1774, 1776 PA 1778, 1779 PA 1780, 1781 PA 1782	PCL BP Computer
		Storage of batteries Stock buffer	Finished dryfill-batteries	Final tests	FAW 883 FAW 828		PA 1680 PA 1681		
	Commissioning re-work	Commissioning/ charging circuits	re-Work Kassy	Re-work	FAW 868		PA 1800		
13	Final test	Electrical lab	Shipping ready dryfill-Batteries	Electrical tests Mechanical tests	VG 8824 T2, VG 8824 T3, 9, 10	Capacity Cycles Self-discharge Deep discharge Float High voltage Weight Thermo- cycle test	PP1700 PP 1703 PP 1705	PA 1700-1, 1700-2, PA 1700-3, 1700-4 PA 1700-5, 1700-6 PA 1700-7, 1700-8, PA 1702, 1705-7, PA 1700-8, 1785 PA 1772, 1773 PA 1774, 1775, 1778 PA 1778, 1779, 1783, PA 1781, 1782, 1789	Records Computer
14	Storage Shipment		Shipping units	Packing	FA-829YH 110 00, 121 00, 123 00, 172 00, 180 00, 181 00, 210 00, 225 00, 221 00, 238 00, 235 00, 290 00, 291 00 282 00, 300 00, 389 00	Open-circuit-voltage Visual test	PP 1703, 1705, 1780 PP 2702, 4001 PA 1788, 1772, 1773, PA 1774, 1778, 1779, PA 1778, 1780, 1781, 1782		PCL Standard valve test
16	Injection moulding	Injection moulding machines No. 1-3	Valve body, valve lid, adaptor	Injection	FAW 860, 861, 862	Visual test Measure test Gauge test Pressure measuring	PP 1130 PP 1131 PP 1134 PP 1135 PP 1136 PP 1137 PP 1140	PA 1120	DEK PCL
16	Assembly	Assembly assembly	Valve	Assembly	FAW 780	Visual test	PP 1124		PCL
				Test of actuator	FAW 781	Opening pressure Closing pressure Leak tightness Non-conformity record	PP 1124		DEK
	Adaptor assembly	Adaptor Manual (opt.)	Valve with adaptor (optional)	Assembly	FAW 783, 784, 786, 863, 864 RAW 784, 786	Visual test Breaking test	PP 1124 PP 1121	PA 1121 PA 1125 PA 1161	
	Assembly post heart call			Assembly O-Range Packing of valves	FAW 801 FAW 788 FAW 785, TSELA (General File)				



Inspection and Test Schedule								
	Battery Type: All battery types	Status: Serial Production	Plant: Bodingen	ID-No. PAP 1000	FMEA reproduction	FMEA Status: Göster Weidhartz	ID-No. PAP 1000	Rev. Index 01
	Working Process: Battery Production	Inspection and Test Schedule Production			Established: Christina Krawczyk	Approved: Christina Krawczyk	Date: 08.02.13	Date: 08.02.13


Flowchart

Figure 8: Seq.No. of Inspection and Test Schedule



Seite 1 von 6

Inspection and Test Schedule								
	Battery Type: All battery types	Status: Serial Production	Plant: Bodingen	ID-No. PAP 1000	FMEA reproduction	FMEA Status: Göster Weidhartz	ID-No. PAP 1000	Rev. Index 01
	Working Process: Battery Production	Inspection and Test Schedule Production			Established: Christina Krawczyk	Approved: Christina Krawczyk	Date: 08.02.13	Date: 08.02.13



Seite 2 von 6



Тип на акумулаторите	Клиент
Каталожен №	Проект
Номинално напрежение	Обект
Зарядно напрежение (20°C)	Устройство
Доставчик / Изпълнител	Дата на монтаж
Производител	Гаранция

**ИНСТРУКЦИЯ ЗА ЕКСПЛОАТАЦИЯ**

**за стационарни, необслужваеми оловно-киселинни акумулаторни батерии**

**НОМИНАЛНИ СТОЙНОСТИ:**

- Номинално напрежение на AB -  $U_N$  :
- Номинален капацитет -  $C_N = C_{10}$  :
- Крайно разрядно напрежение -  $U_S$  :
- Номинална температура -  $T_N$  : 20 °C
- Коэффициенти на корекция -  $f_1, f_2$  : За вентилация (по DIN/VDE 0510, част 1)  $f_1=0.5; f_2=0.5$

	• Спазвайте тези инструкции и ги съхранявайте в близост до батерията, за справка по всяко време. За работа с батерията трябва да се допуска само квалифициран персонал.
	• Не пушете в акумулаторното помещение! Не използвайте необезопасени електрически прибори, инструменти и апаратура, както и други източници на огън!
	• По време на работа с батериите носете защитни очила и дрехи! Спазвайте правилата за безопасност и предпазване от злополука, също така и DIN VDE 0510, VDE 0185 част II!
	• Всяка капка киселина попаднала върху кожата или очите, трябва незабавно да бъде промита с обилно количество студена и чиста вода! След това потърсете спешна медицинска помощ. Разплицените по дрехите калки трябва да бъдат изплакнати и отстранени с вода.
	• Опасност от експлозия и пожар при възникване на къси съединения в токопроводящата мрежа! Внимание! Металните части на батерията са винати под напрежение, затова не поставяйте токопроводящи предмети или инструменти върху батерията.
	• Електролитът е силно разкожд. При нормални работни условия контактът с електролита е невъзможен. Ако корпусът е механически повреден (счупен и разкритизиран), откритият желиран електролит не изтича, но изпаренията са също толкова разкождащи, както и на течния електролит.
	• Батериите/клетките са тежки! Осигурете достатъчна безопасност при манипулиране с тях и винаги използвайте подходящи съоръжения за товарене, разтоварване и транспортиране.
	• Металните части са винати под напрежение, поради което не слагайте инструменти върху батерията.
	Пази от деца!

**2.1.**

Стационарните херметизирани необслужваеми оловно-киселинни батерии не изискват никаква техническа поддръжка (следователно не изискват подмяна с вода). Количеството превъздушен налягане се използва за херметизация на корпуса и ако бъдат отворени се разрушават.

**1.**

**Пускане в експлоатация**

Проверете всички клетки/ блокове за механични повреди, свързването на полярността и надлъжното свързване на съединителите. За да избегнете и запалване на съединителните съединители към полюсите накрайници да се използва динамометричен ключ със следните условия на затегане:

Код-тип	14-20Ah	25-35Ah	45-65Ah	75-100Ah	120-150Ah	180-210Ah	270-330Ah	360-450Ah	540-630Ah	720-840Ah
Универсал	-	-	4 Nm	4 Nm	4 Nm	4 Nm	4 Nm	4 Nm	4 Nm	4 Nm
Спринг	4 Nm	4 Nm	4 Nm	4 Nm	4 Nm	4 Nm	4 Nm	4 Nm	4 Nm	4 Nm
Спринг S	-	-	11 Nm	11 Nm	11 Nm	11 Nm	11 Nm	11 Nm	11 Nm	11 Nm
Power S20	-	-	5 Nm	5 Nm	5 Nm	5 Nm	5 Nm	5 Nm	5 Nm	5 Nm
Power S20	-	-	5 Nm	5 Nm	5 Nm	5 Nm	5 Nm	5 Nm	5 Nm	5 Nm
Code-тип	6-85	8-85	6-100	6-100	6-100	6-100	6-100	6-100	6-100	6-100
A-60	5 Nm	5 Nm	6 Nm	6 Nm	6 Nm	6 Nm	6 Nm	6 Nm	6 Nm	6 Nm
A-50	3 Nm	3 Nm	4 Nm	4 Nm	4 Nm	4 Nm	4 Nm	4 Nm	4 Nm	4 Nm
A-300 c/s	-	-	-	-	-	-	-	-	-	-
A-200 c/s	-	-	-	-	-	-	-	-	-	-
A-70	-	-	4 Nm	4 Nm	4 Nm	4 Nm	4 Nm	4 Nm	4 Nm	4 Nm

Таблица 1

Преди монтажа трябва да се поставят и в лоста крава на кабелните връзки защитните гумени капачки (полюсни капачки).

Нови батерии: > 1MΩ

Използвани батерии: > 100 Ω/V

Свържете батерията към токопроводителя като внимавайте за спазване на правилната полярност (положителния полюс към положителната присъединителна клемма). Този процес трябва да се извършва при изключен токопроводител и изключен консуматор. След това включете токопроводителя и заключете зареждането съгласно точка 2.2.

**2.**

**Експлоатация на батерията**

За монтажа и експлоатацията на стационарните батерии е задължително спазването на DIN VDE 0510, част I (версия) и част 2.

Батерията трябва да бъде инсталирана в такова помещение, където температурните разлики между отделните елементи не са по-големи от 3 градуса по Целзий/Келвин.

**Разряд на батерията**

Крайното разрядно напрежение, под което батерията не трябва да бъде разредена, се определя от полярността на разрядния ток. При необходимост от по-дълбоки разряди се консултирайте с производителя. Заредете отново батерията веднага след нейния пълен или частичен разряд.

**Зареждане на батерията**

Приложими са всички зарядни методи със съответните ограничения, прогностични от DIN 41773 (U-характеристика). По време на заряд, през батерията освен постоянния ток протича и променлив, който се налага върху постоянния, и чиято величина зависи от характеристиките на токопроводителя. Променилият ток е съставка (ако назовава допустимата стойност) и реалната на товара могат да доведат до допълнително нарастване на вътрешната температура на батерията и механичен натиск върху електродите с възможност за повреда (виж т.2.5)

В зависимост от начина на експлоатация на батерията и вида на зарядната апаратура (съгласно DIN VDE 0510, част 1), могат да бъдат приложени някои от следните зарядни методи:

Работа на батерията в *standby* режим.

Тук товарът, източникът на постоянен ток и батерията са постоянно свързани в паралел. При малки на външно зареждане, батерията е в режим на поддържащо зареждане (подзаряд), не се използва като основен енергиен източник, а само като резерв. В този случай зарядното напрежение е едновременно и работното напрежение и напрежението на батерията, а токопроводителът е в състояние да осигури във всеки момент максималния товар на консуматорите и зарядния ток на батерията. Батерията преминава от аварен в основен източник само при повреда на зарядното устройство или отпадане на мрежовото захранване. Стойността за зарядното напрежение, измерено при изходите на батерията, трябва да бъде според Таблица 2 x броя на клетките.



Model	Float voltage [Vdc]	Nominal temp. [°C]
Marathon L	2.27	20
Marathon M	2.27	25
Sprinter P	2.27	25
Sprinter S	2.27	20
Powerfit S 300	2.27	20
Powerfit S 500	2.27	20
A 400	2.27	20
A 500	2.30	20
A 600	2.25	20
A 700	2.25	20

Таблица 2

За напълване времето на пълно зареждане, може да се премине към ускорен заряд, като се повиши зарядното напрежение според Таблица 3 V/кл. ±1% х броя на клетките, по само ако това е допустимо за нормалната работа на консуматорите. Следва автоматичното прекъсване към подзаряд.

Model	Voltage on boost charge stage [Vdc]	Nominal temp. [°C]
Marathon L	2.35-2.40	20
Marathon M	2.35-2.40	25
Sprinter P	2.35-2.40	25
Sprinter S	2.35-2.40	25
Powerfit S 300	2.35-2.40	20
Powerfit S 500	2.35-2.40	20
A 400	2.37-2.40	20
A 500	2.40-2.45	20
A 600	2.35-2.40	20
A 700	2.35-2.40	20

Таблица 3

6). Работа на батериите в буферен режим  
При работа в буферен режим, източникът на постоянен ток не може да поддържа през цялото време товара на консуматорите. През периода, в който този консуматор достига максималните си стойности и пресича по стойност номинални ток на токоизправителя, батериите го буферират и лесно допълнителни товари. Батериите не се намират в начално заредено състояние през цялото време. Ето защо, в зависимост от големината на товара, зарядното напрежение трябва да бъде настроено според Таблица 4 V/кл. ±1% х броя на клетките. Този режим следва да се прилага в съответствие с препоръките на производителя.

Model	Voltage in buffer operation [Vdc]	Nominal temp. [°C]
Marathon L	2.27	20
Marathon M	2.29-2.33	25
Sprinter P	2.30	25
Sprinter S	2.29-2.33	25
Powerfit S 300	2.27	20
Powerfit S 500	2.27	20
A 400	2.27	20
A 500	2.30-2.35	20
A 600	2.27-2.30	20
A 700	2.27-2.30	20

Таблица 4

с). **Прекъсвачен режим на работа.**  
Когато зареждаме, батериите е отделена от товара. Максималната стойност на зарядното напрежение е според Таблица 3. Процесът на зареждане трябва да се контролира. Ако зарядния ток спадне под 1,5A/100Ah номин. капацитет при 2,35V/кл., работния режим се превключва към подзаряд, съсл. точка 2.3. (преключва се след достигане до 2,35V/кл.).  
д). **Циклически работен режим (заряд/разряд)**  
Товарът се захранва само от батериите. Зарядния процес зависи от начина на експлоатация и трябва да се прилага в съответствие с препоръките на производителя.  
2.3. **Поддържащ заряд (подзаряд) - float заряд**  
Батериите е в състояние на пълно зареждане във всеки един момент. Трябва да се използват зарядни устройства, изпълняващи изискванията на DIN 41773. Те се нагласят така, че средната стойност на напрежението да е съгласно Таблица 2.

2.4. **Изравняващ заряд**  
По време на изравняващ заряд е възможно да се надхвърлят допустимото напрежение на товара, поради което трябва да се вземат съответните мерки, т.е. да се изключи товара. Изравняващ заряд се извършва след дълбоки разряди и/или недостатъчен заряд. Те трябва да бъдат провеждани в продължение на не повече от 48 часа с напрежение съгласно Таблица 3. Зарядна ток не трябва да надхвърля 10A/100Ah номинален капацитет. Ако максималната температура по време на зареда превиши 45°C, изравняващото зареждане трябва да бъде прекратено, или прекъснато към подзаряд-за да позволи снижаване на температурата.

2.5.

**Променилни токове**  
При ускорен заряд до 2,4V/клетка, съгласно посочените в точка 2.2. зарядни способи, допустимо е стойността на променливия ток да достигне до 20A/100Ah номинален капацитет. В начално заредено състояние, при работа на батериите в поддържащ (float) или изравняващ режим, реалната стойност на променливия ток не трябва да надхвърля 5A/100Ah номинален капацитет.

2.6.

**Зарядни токове**  
При работа в поддържащ или в изравняващ режим, когато отсъства необходимостта от ускорено зареждане, зарядния ток не се ограничава. Приблизителната стойност на максималния заряден ток е съгласно Таблица 5.  
При напълно заредена батерия, остатъчните зарядни токове са минимални и при различните температури трябва да имат стойности, по-ниски от посочените по-долу гранични стойности (необходима предостатъка за това е поддържащото напрежение да бъде в съответствие с Таблица 2).

Model	Charging current
Marathon L	10 to 30 A per 100Ah
Marathon M	10 to 35 A per 100Ah
Sprinter P	10 to 30 A per 100Ah
Sprinter S	10 to 35 A per 100Ah
Powerfit S 300	10 to 30 A per 100Ah
Powerfit S 500	10 to 30 A per 100Ah
A 400	10 to 35 A per 100Ah
A 500	10 to 35 A per 100Ah
A 600	10 to 35 A per 100Ah
A 700	10 to 35 A per 100Ah

Таблица 5

Измерването може да се счита за представително само когато остатъчният заряден ток е достатъчно постоянен по стойност. Това става след около 6 дни (150 часа) от приключване на последното зареждане. При отклонение на измерените данни от изискваните, трябва да се проведе контролен разряд съгласно изискванията на DIN 43539 в точка 8.3. (напр. 10-часов разряд на напълно заредена батерия при 20°C, с разряден ток 0,1xС<sub>10</sub> до достигане на крайно разрядно напрежение 1,40 V/кл.), или да се потвърди сериалния представител. Протоколирайте резултатите!

2.7.

**Температура**  
Номиналният работен температурен обхват за основно-киселинни батерии е между 10°C и 30°C (най-добър е обхватът 20°C ±5°C). Всички технически номинални данни са измерени

при 20°C. Високите температури снижават значително експлоатационния срок и повишават съвсем несъществено капацитета (Таблица 2). Абсолютният максимум на температурата с 55°C и той е недопустим за експлоатация, а средната стойност на постоянната работна температура не би трябвало да надхвърля 45°C. По-ниските температури намаляват капацитета (Таблица 2), и удължават несъществено срока на експлоатация. Недопустима е постоянната работна температура под -20°C.

2.8. **Зависимост на зарядното напрежение от температурата**

Температурно зависимо регулиране на зарядното напрежение е съгласно фигури 1 до 5.




Fig. 1: Marathon L and Powerfit S; charging voltage vs. temperature




Fig. 2: Marathon M, Sprinter P, Sprinter S; charging voltage vs. temperature

ВЯРНО С  
ОРИГИНАЛА



Handwritten signature.




Fig. 3: A 400; charging voltage vs. temperature




Fig. 4: A 500; charging voltage vs. temperature




Fig. 5: A 600, A 700; charging voltage vs. temperature

- 2) напрежението на няколко клетки/блока;
  - 3) повърхностната температура на няколко клетки/блока;
  - 4) температурата в акумулаторните помещения;
- Ако разликата между средната стойност на подзарядното напрежение (измерена в двата края на батериите и разделена на общия брой на клетки/блокове) и конкретната стойност на подзарядното напрежение (измерена върху отделните клетки/блокове) е по-голяма от допустимото отклонение съгласно Таблица 6, или ако повърхностната температура между отделните клетки/блокове се различава с повече от 5°C, трябва да се обрнете към сервизния представител.

	2V	4V	6V	8V	12V
Marathon L	+0.2/-0.1	--	+0.35/-0.17	--	+0.6/-0.24
Marathon M	--	--	+0.35/-0.17	--	+0.6/-0.24
Spartan P	--	--	+0.35/-0.17	--	+0.6/-0.24
Spurline S	--	--	+0.35/-0.17	--	+0.6/-0.24
PowerB S 300	--	--	+0.35/-0.17	--	+0.6/-0.24
PowerB S 500	--	--	+0.35/-0.17	--	+0.6/-0.24
A 400	+0.2/-0.1	+0.26/-0.14	+0.35/-0.17	+0.46/-0.26	+0.6/-0.24
A 500	+0.2/-0.1	--	+0.35/-0.17	--	+0.6/-0.24
A 600	--	--	+0.35/-0.17	--	+0.6/-0.24
A 700	--	--	+0.35/-0.17	--	+0.6/-0.24

Таблица 6

Годишно измерване и протоколиране:

- 1) напрежението на всички клетки/блокове;
- 2) повърхностната температура на всички клетки/блокове;
- 3) температурата в акумулаторното помещение;
- 4) изолационното съпротивление съгласно DIN 43539, част 1

Годишна визуална проверка:

- 1) степен на нагнетаваност на винтовете съединения;
- 2) монтаж и подреждане на батериите;
- 3) вентилацията.

Тестове

Тестовите се провеждат съгласно DIN 43539, част 1 и 100 (чертежа). Да се спазват и специалните инструкции като DIN VDE 0107 и DIN VDE 0108.

Повреди

В случай на повреда в батериите или зарядното устройство, незабавно потърсете сервизния представител. Наличието на протоколи с данните от т. 3 е много важно за откриване на причината за повредата.

6. Съхранение и снемане от експлоатация  
Акумулаторните клетки/блокове се доставят от завода винаги напълно заредени и следва да се спазват само в заредено състояние, в сухи помещения, в които не съществува опасност от замръзване. Максимално време за съхранение без необходимост от дозарядване, е две години при 20°C. При постоянни температури над 30°C, дозарядване се правят на всеки 12 месеца, а при > 40°C - на всеки 6 месеца.

Дозарядването може да се извърши по един от следните зарядни методи:

- 1) годишен изравнителен заряд в съответствие с изискванията на т. 2.4;
- 2) подзаряд - съгласно т. 2.3.

7. Транспорт  
Съгласно изискванията на Международната асоциация за въздушен транспорт IATA, батериите трябва да се опаковат в специални контейнери, които да са изградени от удароустойчив материал. Това важи за автомобилни, въздушни и железопътни транспорт. Клетките и блоковете трябва да се транспортират прави. За предпазване от късо съединение, изводите са изолирани и обособени със защитни капачки, които не трябва да се свалят до момента на монтажа.

Технически данни

В типа акумулаторна плоча се съдържа данни за номиналното напрежение, броят на клетки/блокове, номиналната капацитет ( $C_{10=20}$ ) и типа на батериите.

ВЯРНО С  
ОРИГИНАЛА



Handwritten signature

9.1 AGM - Types  
9.1.1. Marathon L

Discharge time t <sub>d</sub>	Capacity C <sub>d</sub> [Ah]	15 min. power [W]							Length [mm]	Width [mm]	Height max. [mm]	Weight approx. [kg]
		C <sub>10</sub>	C <sub>5</sub>	C <sub>3</sub>	C <sub>1</sub>	C <sub>0.5</sub>	C <sub>0.2</sub>	C <sub>0.1</sub>				
L12V15	6.5	13.0	9.9	13.2	14.0	14.0	18.1	167	76	167	6.5	
L12V24	10.6	13.9	15.8	21.0	21.5	23.0	168	177	174	174	10.0	
L12V32	14.1	18.7	21.4	27.9	30.0	32.0	198	188	175	175	13.5	
L12V42	19.6	25.7	29.4	38.1	39.5	42.0	234	189	190	185	18.5	
L12V55	21.6	29.5	36.0	44.7	49.0	55.0	272	166	190	22.0	22.0	
L12V60	30.3	41.5	51.2	68.1	71.0	80.0	359	172	228	30.0	30.0	
L6V110	48.4	65.0	75.5	102.3	107.0	112.0	272	166	180	23.0	23.0	
L6V160	66.8	93.5	111.0	133.5	146.0	162.0	359	171	228	31.5	31.5	
L2V220	87.4	127.0	150.0	196.8	208.0	220.0	208	135	282	18.0	18.0	
L2V270	108.3	155.5	183.0	229.2	243.0	270.0	208	135	282	18.3	18.3	
L2V320	135.8	190.5	225.0	271.8	288.0	320.0	208	201	282	24.2	24.2	
L2V375	165.8	221.5	262.0	318.0	337.5	375.0	208	201	282	26.5	26.5	
L2V425	169.9	247.0	291.0	360.0	382.5	425.0	208	201	282	28.8	28.8	
L2V470	186.6	277.0	324.0	399.0	428.5	470.0	208	270	282	32.6	32.6	
L2V520	204.1	304.5	357.0	438.0	474.0	520.0	208	270	282	35.0	35.0	
L2V575	220.8	334.5	394.0	486.0	520.0	575.0	208	270	282	37.3	37.3	
U <sub>1</sub> (2 V cell)	1.80	1.50	1.70	1.75	1.75	1.80						
U <sub>2</sub> (4 V block)	4.80	4.80	5.10	5.25	5.40							
U <sub>3</sub> (6 V block)	6.60	6.60	7.00	7.25	7.50							

All technical data refer to 20° C.

9.1.2. Marathon M

Type	Nominal voltage [V]	C <sub>10</sub> [Ah]	Constant current discharge [Ah]							Length [mm]	Width [mm]	Height max. [mm]	Weight approx. [kg]
			0.5 h	1 h	1.5 h	3 h	5 h	10 h	15 h				
M12V30FT	12	30	36.8	21.2	15.1	8.40	5.50	2.80	171	130	186	10.7	
M12V40FT	12	40	51.3	30.5	21.5	11.9	7.80	4.10	198	167	189	17.8	
M12V45FT	12	45	57.8	33.2	24.0	13.5	8.70	4.70	220	121	254	17.5	
M12V70FT	12	70	90.6	51.6	36.8	20.6	13.4	7.40	260	174	235	27.8	
M12V90FT	12	90	107	65.7	46.6	25.9	16.7	9.20	306	174	235	32.8	
M6V180FT	6	180	246	144	102	56.0	35.9	19.5	366	174	235	34.0	
M6V200	6	200	220	135	100	55.2	36.3	20.2	361	132	250	34.0	
M12V30FT	12	35	44.0	26.5	14.0	19.2	6.80	3.50	280	107	189	14.0	
M12V50FT	12	47	61.0	34.3	20.0	13.5	6.80	4.70	280	107	231	18.0	
M12V60FT	12	59	64.8	40.1	26.0	16.6	11.0	6.00	290	107	263	23.0	
M12V90FT	12	86	108	64.0	46.4	24.9	15.9	8.70	395	105	270	31.0	
M12V105FT	12	100	115	70.0	51.6	24.5	18.7	10.3	511	110	338	35.8	
M12V125FT	12	121	141	86.1	63.3	37.2	23.4	12.4	559	124	263	47.5	
M12V155FT	12	150	174	103	77.7	45.2	28.1	13.4	559	124	283	53.8	

All technical data refer to 25° C.

9.1.3. Sprinter P

Type	Nominal voltage [V]	15 min. power [W]	Capacity C <sub>d</sub> [Ah]	Length [mm]	Width [mm]	Height max. [mm]	Weight approx. [kg]
P12V610	12	910	21	168	177	128	9.5
P12V600	12	600	24	188	127	174	8.5
P12V675	12	875	41	186	168	115	14.3
P12V1230	12	1230	51	234	169	180	24.0
P12V1575	12	1575	61	272	166	228	33.0
P12V2130	12	2130	86	359	172	228	48.1
P 6V1700	6	1700	122	272	166	190	23.0
P 6V2030	6	2030	178	359	172	226	32.5

These batteries are especially designed for high rate discharges. Further details depending on the discharge time and cut off voltage must be taken from the actual product brochure.

All technical data refer to 25° C.

9.1.4. Sprinter S

Type	Nominal voltage [V]	C <sub>10</sub> [Ah]	Constant power [Watt per cell]				Length [mm]	Width [mm]	Height max. [mm]	Weight approx. [kg]		
			5 min	10 min	15 min	30 min						
S12V120F	12	24	242	151	117	72	41	29	173	167	166	12.1
S12V170F	12	40	320	215	167	102	58	41	188	107	189	16.4
S12V250F	12	70	543	365	285	159	96	60	260	174	235	27.8
S12V300F	12	89	654	415	368	180	105	76	260	174	235	28.7
S12V370F	12	87	723	484	373	230	131	82	306	174	235	33.4
S12V500F	12	131	864	619	505	310	176	126	344	172	288	48.1
S6V140F	6	173	1448	970	746	458	262	184	306	174	235	33.4

All technical data refer to 25° C.

9.1.5. Power1 S 300

Type	Nominal voltage [V]	C <sub>10</sub> [Ah]	C <sub>d</sub> [Ah]			Length [mm]	Width [mm]	Height max. [mm]	Weight approx. [kg]
			1.75 V per cell	1.75 V per cell	1.80 V per cell				
S300/1.2 S	6	6	1.2	1.13	0.78	87	25	50	0.3
S306/4 S	6	4.0	4.0	3.80	2.02	70	47	106	0.8
S306/7 S	6	7.0	7.0	6.55	4.38	151	34	100	1.3
S312/1.2 S	6	12	1.2	1.13	0.78	97	45	59	0.6
S312/2.3 S	12	2.3	2.3	2.19	1.90	178	34	85	0.8
S312/4.3 S	12	4.3	4.3	4.00	3.00	134	67	66	1.3
S312/7 S	12	7.0	7.0	6.64	4.58	151	65	98	2.8
S312/12 S	12	12	12	11.4	7.96	151	98	98	4.0
S312/18 OS	12	18	18	16.1	11.1	181	76	165	6.2
S312/26 OS	12	26	26	24.7	17.0	168	175	125	9.4
S312/40 OS	12	40	40	37.9	26.2	196	166	171	14.3

All technical data refer to 20° C.

9.1.6. Power1 S 600

Type	Nominal voltage [V]	C <sub>10</sub> [Ah]	C <sub>d</sub> [Ah]			Length [mm]	Width [mm]	Height max. [mm]	Weight approx. [kg]
			1.75 V per cell	1.75 V per cell	1.80 V per cell				
S512/25	12	25.0	25.0	24.0	15.8	168	127	174	9.5
S512/38	12	38.0	38.0	36.0	23.2	188	169	175	13.5
S512/50	12	51.0	51.0	48.0	32.5	234	169	180	18.5
S512/60	12	61.0	61.0	58.0	40.8	272	166	190	23.0
S512/80	12	82.0	82.0	81.0	54.4	359	172	226	30.0
S506/130	6	130	121	121	80.0	272	166	180	23.0
S506/185	6	185	174	174	116	359	171	226	31.5

All technical data refer to 20° C.



9.2 GEL - Типы  
9.2.1. А 600

Discharge time L <sub>h</sub> Capacity C <sub>t</sub> [Ah]	10 min		30 min		1 h		3 h		5 h		10 h		Length [mm]	Width [mm]	Height max. [mm]	Weight approx. [kg]
	C <sub>10</sub>	C <sub>10</sub>	C <sub>30</sub>	C <sub>30</sub>	C <sub>1</sub>	C <sub>1</sub>	C <sub>3</sub>	C <sub>3</sub>	C <sub>5</sub>	C <sub>5</sub>	C <sub>10</sub>	C <sub>10</sub>				
A408/165	53.0	80.0	2.80	3.40	4.80	5.00	143.5	165	244	190	282	31.5				
A412/150	1.83	2.67	3.90	4.70	6.60	7.50	8.00	8.00	152	66	98	2.5				
A412/150	3.85	5.50	8.00	9.50	13.0	15.0	20.0	22.0	181	76	156	3.6				
A412/220	7.00	9.50	12.0	14.0	19.0	22.0	29.0	32.0	210	178	181	8.5				
A412/250	11.5	16.5	20.0	23.0	31.0	35.0	44.5	50.0	278	175	181	14.1				
A412/300	16.3	23.0	28.0	32.0	42.0	47.0	57.5	65.0	353	175	220	23.5				
A412/350	20.5	28.0	35.0	40.0	52.0	58.0	71.5	80.0	404	244	276	32.0				
A412/400	25.0	34.0	42.0	48.0	62.0	70.0	85.0	95.0	484	267	337	40.0				
A412/450	30.5	41.5	51.0	58.0	75.0	85.0	100	110	513	189	223	49.0				
A412/500	38.0	50.0	62.0	71.0	90.0	100	120	130	513	223	244	64.5				
A412/600	53.5	71.0	87.0	99.0	130	150	180	200	518	274	244	88.5				
A412/700	68.5	91.0	110	125	160	180	220	250	548	274	273	115				
U <sub>1</sub> [V (5 V block)]	4.8	4.8	5.1	5.1	5.1	5.4										
U <sub>2</sub> [V (12 V block)]	9.5	9.6	10.2	10.2	10.2	10.8										

All technical data refer to 20° C.

9.2.2. А 700

Discharge time L <sub>h</sub> Capacity C <sub>t</sub> [Ah]	10 min		30 min		1 h		3 h		5 h		10 h		Length [mm]	Width [mm]	Height max. [mm]	Weight approx. [kg]
	C <sub>10</sub>	C <sub>10</sub>	C <sub>30</sub>	C <sub>30</sub>	C <sub>1</sub>	C <sub>1</sub>	C <sub>3</sub>	C <sub>3</sub>	C <sub>5</sub>	C <sub>5</sub>	C <sub>10</sub>	C <sub>10</sub>				
A508/110	4.30	6.40	7.10	8.00	9.00	9.50	10.0	10.0	53	51	98	0.7				
A508/125	1.40	1.95	2.30	2.70	3.00	3.50	3.50	3.50	91	35	64	0.5				
A508/150	0.50	0.65	0.80	1.00	1.00	1.20	1.20	1.20	97	26	56	0.3				
A508/175	1.40	1.95	2.30	2.70	3.00	3.50	3.50	3.50	135	35	64	0.7				
A508/200	1.10	1.25	1.50	1.70	1.70	2.00	2.00	2.00	52	62	102	0.9				
A508/225	2.60	3.50	4.00	4.60	5.50	6.00	6.50	6.50	152	35	98	1.3				
A508/250	4.80	6.40	7.10	8.00	9.00	9.50	10.0	10.0	179	34	64	1.0				
A508/275	1.40	1.95	2.30	2.70	3.00	3.50	3.50	3.50	179	34	64	1.0				
A512/100	0.50	0.65	0.80	1.00	1.00	1.20	1.20	1.20	98	50	55	0.7				
A512/125	0.80	1.10	1.50	1.80	2.00	2.00	2.00	2.00	135	67	64	1.5				
A512/150	1.40	1.95	2.30	2.70	3.00	3.50	3.50	3.50	182	66	98	2.5				
A512/175	2.60	3.50	4.00	4.60	5.50	6.00	6.50	6.50	182	66	98	2.5				
A512/200	4.80	6.40	7.10	8.00	9.00	9.50	10.0	10.0	181	76	167	6.0				
A512/225	7.30	11.4	14.4	18.8	20.5	22.0	25.0	25.0	167	178	126	8.5				
A512/250	11.4	16.3	20.1	24.6	28.5	34.0	36.0	40.0	210	175	175	14.6				
A512/275	14.1	19.5	24.0	28.5	34.0	36.0	40.0	40.0	210	175	175	14.6				
A512/300	19.3	27.5	33.7	42.9	48.5	50.0	55.0	55.0	261	135	230	18.8				
A512/350	22.1	30.9	37.1	48.6	52.0	56.0	60.0	60.0	278	175	190	20.8				
A512/400	22.5	33.8	40.9	53.7	58.5	62.0	66.0	66.0	330	175	190	24.0				
A512/450	33.1	47.5	59.0	69.0	75.5	80.0	85.0	85.0	300	171	236	30.0				
A512/500	37.8	58.5	67.0	84.0	95.0	104	115	126	286	268	230	40.0				
A512/550	44.5	62.0	74.0	88.7	96.0	102	120	120	513	189	223	41.0				
A512/600	50.5	71.5	85.4	105	113	118	140	140	513	223	223	48.0				
A512/700	68.5	101	120	151	164	173	200	200	518	274	238	67.0				
U <sub>1</sub> [V (5 V block)]	1.6	1.6	1.65	1.70	1.70	1.80	1.75									
U <sub>2</sub> [V (6 V block)]	3.2	3.2	3.4	3.4	3.4	3.6	3.5									
U <sub>3</sub> [V (8 V block)]	4.8	4.8	4.95	5.1	5.1	5.4	5.25									
U <sub>4</sub> [V (12 V block)]	6.4	6.4	6.6	6.8	6.8	7.2	7.0									
U <sub>5</sub> [V (12 V block)]	9.6	9.6	10.2	10.2	10.2	10.8	10.5									

All technical data refer to 20° C.

9.2.3. А 600

Type	DIN type designation	Nominal voltage [V]	C <sub>1</sub> [Ah]		C <sub>5</sub> [Ah]		C <sub>10</sub> [Ah]		Length [mm]	Width [mm]	Height max. [mm]	Weight approx. [kg]
			C <sub>1</sub>	C <sub>1</sub>	C <sub>5</sub>	C <sub>5</sub>	C <sub>10</sub>	C <sub>10</sub>				
A612/100	12 V 2 OPzV 100	12	58.9	76.5	82.5	82.5	91.0	273	204	319	4.3	
A612/150	12 V 3 OPzV 150	12	86.9	114.6	124.0	124.0	137.0	391	204	319	6.3	
A608/200	6 V 4 OPzV 200	6	114.0	152.7	165.5	165.5	182.0	273	204	319	4.3	
A608/300	6 V 6 OPzV 300	6	166.0	228.2	248.0	248.0	274.0	391	204	319	6.3	
A608/400	4 OPzV 400	2	123.8	163.6	201.5	201.5	224.0	105	208	360	16	
A608/500	5 OPzV 500	2	154.7	229.5	251.5	251.5	280.0	158	208	360	22	
A608/600	6 OPzV 600	2	185.8	275.4	302.0	302.0	337.0	147	208	360	25	
A608/700	7 OPzV 700	2	239.9	349.5	406.0	406.0	448.0	156	208	475	32	
A608/800	8 OPzV 800	2	287.9	419.4	487.5	487.5	549.0	147	208	475	37	
A608/900	9 OPzV 900	2	354.9	490.3	568.5	568.5	632.0	168	208	475	42	
A608/1000	10 OPzV 1000	2	437.8	596.5	676.0	676.0	748.0	147	208	650	50	
A608/1200	12 OPzV 1200	2	563.4	783.0	898.5	898.5	998.0	212	181	650	68	
A608/1400	14 OPzV 1400	2	720.0	979.0	1123.0	1123.0	1248.0	212	235	650	82	
A608/1600	16 OPzV 1600	2	874.6	1176.3	1347.0	1347.0	1487.0	212	277	650	96	
A608/1800	18 OPzV 1800	2	958.9	1335.3	1445.5	1445.5	1643.0	212	277	800	112	
A608/2000	20 OPzV 2000	2	1278.5	1780.5	1927.5	1927.5	2180.0	216	400	775	153	
A608/2500	25 OPzV 2500	2	1598.1	2225.7	2409.5	2409.5	2726.0	215	490	775	196	
A608/3000	30 OPzV 3000	2	1917.8	2670.6	2891.0	2891.0	3288.0	216	580	775	225	
U <sub>1</sub> [V (5 V block)]		--	1.60	1.70	1.75	1.80						
U <sub>2</sub> [V (6 V block)]		--	4.80	5.10	5.25	5.40						
U <sub>3</sub> [V (12 V block)]		--	9.60	10.20	10.50	10.80						

All technical data refer to 20° C.

9.2.4. А 700

Discharge time L <sub>h</sub> Capacity C <sub>t</sub> [Ah]	10 min		30 min		1 h		3 h		5 h		10 h		Length [mm]	Width [mm]	Height max. [mm]	Weight approx. [kg]
	C <sub>10</sub>	C <sub>10</sub>	C <sub>30</sub>	C <sub>30</sub>	C <sub>1</sub>	C <sub>1</sub>	C <sub>3</sub>	C <sub>3</sub>	C <sub>5</sub>	C <sub>5</sub>	C <sub>10</sub>	C <sub>10</sub>				
A706/21	7.00	7.00	10.2	10.2	12.2	12.2	18.5	18.5	115	178	259	8.5				
A706/42	14.1	20.5	24.4	28.4	33.0	33.0	42.0	42.0	115	178	268	10.1				
A706/63	21.1	31.7	36.6	43.8	49.5	49.5	57.0	57.0	198	178	272	16.3				
A706/84	28.3	41.0	48.8	58.0	66.0	66.0	76.5	76.5	186	178	272	18.3				
A706/105	35.3	51.0	61.0	73.2	82.8	82.8	95.5	95.5	282	178	272	25.3				
A706/126	42.3	61.5	73.2	88.5	99.3	99.3	114.5	114.5	282	178	272	28.2				
A706/147	49.3	69.5	83.2	100.0	111.0	111.0	128.0	128.0	285	232	327	36.3				
A706/168	56.3	79.5	94.0	112.0	126.0	126.0	145.0	145.0	285	232	327	39.7				
A706/189	63.3	89.5	106.0	126.0	144.0	144.0	165.0	165.0	285	232	327	42.9				
A706/210	70.3	100.0	118.0	144.0	165.0	165.0	188.0	188.0	285	232	327	46.9				
A706/231	77.3	109.5	128.0	156.0	178.0	178.0	204.0	204.0	285	232	327	50.9				
A706/252	84.3	119.0	138.0	168.0	190.0	190.0	220.0	220.0	285	232	327	54.9				
U <sub>1</sub> [V (5 V block)]		3.2	3.2	3.2	3.4	3.4	3.4	3.4	3.4	3.4	3.6					
U <sub>2</sub> [V (6 V block)]		4.8	4.8	4.8	5.1	5.1	5.1	5.1	5.1	5.1	5.4					

All technical data refer to 20° C.



# Operating Instruction Stationary valve regulated lead-acid batteries

81700849

**Nominal data**

- Nominal voltage  $U_n$ : 2,0V x number of cells
- Nominal capacity  $C_{10}$  at  $C_{10}$ : 10 h, 20 h discharge (see type plate on cells/blocks and technical data in these instructions)
- Nominal capacity  $C_{20}$  at  $C_{20}$ : 20 h, 10 h discharge (see type plate on cells/blocks and technical data in these instructions)
- Final discharge voltage  $U_f$ :  $C_{10}$ /10h;  $C_{20}$ /20h
- Nominal temperature  $T_n$ : see technical data in these instructions
- Nominal temperature  $T_n$ : 20° C; 25° C

Battery type: \_\_\_\_\_ Number of cells/blocks: \_\_\_\_\_ date: \_\_\_\_\_  
 Assembly and CE marking by: \_\_\_\_\_ GNB order no.: \_\_\_\_\_ date: \_\_\_\_\_  
 Commissioned by: \_\_\_\_\_ date: \_\_\_\_\_  
 Safety signs attached by: \_\_\_\_\_ date: \_\_\_\_\_

Observe these instructions and keep them located near the battery for future reference.

- Work on the battery should be carried out by qualified personnel only.
- Do not smoke.
- Do not use any naked flame or other source of ignition.
- Risk of explosion and fire.
- While working on batteries wear protective eye-glasses and clothing.
- Observe the accident prevention rules as well as EN 50272-2, EN 50110-1.
- Any acid splashes on the skin or in the eyes must be flushed with plenty of clean water immediately. Then seek for medical assistance. Spillages on clothing should be rinsed out with water!
- Warning: Risk of fire, explosion or burns. Do not disassemble, heat above 60°C, or incinerate. Avoid short circuits.
- Avoid electrostatic charges and discharges/sparks!
- Electrolyte is very corrosive. In normal working conditions the contact with the electrolyte is impossible. If the cell/block container is damaged do not touch the exposed electrolyte because it is corrosive.
- Batteries/cells are very heavy! Make sure they are installed securely! Only use suitable means of transport!
- Block/cell containers are sensitive to mechanical damage.
- Handle with care!
- Do not lift or pull up blocks/cells on the poles.
- Caution! Metal parts of the battery are always alive, therefore do not place items or tools on the battery.
- Keep children away from batteries.

Non-compliance with operating instructions, installations or repairs made with other than original accessories and spare parts or with accessories and spare parts not recommended by the battery manufacturer or repairs made without authorization (e.g. opening of valves) voids the warranty.

Spend batteries have to be collected and recycled separately from normal household waste (EWV 160801). The handling of spent batteries is described in the EU Battery Directive (2006/66/EC) and their national legislations (UK: HS Regulation 1994 No. 232, Ireland: Statutory Instrument No. 73/2000). Contact your supplier to agree upon the collection and recycling of your spent batteries or contact a local and authorized Waste Management Company.

Stationary valve regulated lead acid batteries do not require topping-up water. Pressure valves are used for sealing and cannot be opened without destruction.

1. Start Up  
 Check all cells/blocks for mechanical damage, correct polarity and firmly seated connectors. Torques as shown in table 1 apply for screw connectors.

Before installation the supplied rubber covers should be fitted to both ends of the connector cables (pole covers).

Control of insulation resistance:  
 New batteries: > 1M Ω  
 Used batteries: > 100 kΩ/Volt

Connect the battery with the correct polarity to the charger (see pole to pole terminal). The charge must not be switched on during this process, and the load must not be connected. Switch on charger and start charging following instruction no. 2.2.

2. Operation  
 For the installation and operation of stationary batteries EN 50272-2 is mandatory. Battery installation should be made such that temperature differences between individual units do not exceed 3 degrees Celsius (Kelvin).

2.1 Discharge  
 Discharge must not be continued below the voltage recommended for the discharge time. Deeper discharges must not be carried out unless specifically agreed with the manufacturer. Recharge immediately following complete or partial discharge.

2.2 Charging  
 All charging must be carried out according to DN 41773 (U-characteristic with limit values: I-constant: ± 2%; U-constant: ± 1%).

Depending on the charging equipment, specification and characteristics alternating currents flow through the battery. Alternating currents and the reaction from the loads may lead to an additional temperature increase of the battery, and strain the electrodes with possible damages (see 2.5) which can shorten the battery life. Depending on the installation charging (acc. to EN 50272-2) may be carried out in following operations.

a.) Standby Parallel Operation  
 Here, the load, battery and battery charger are continuously in parallel. Therefore, the charging voltage is the operational voltage. The charging voltage in the battery station voltage. With the correct polarity, the battery charging current is available at any time, of supplying the maximum load current and the battery charging current. The battery only supplies current when the battery charger fails. The charging voltage should be set acc. to table 2 measured at the end terminals of the battery.

Marathon L/L	Marathon M/M-FT	Sprinter P/P	Sprinter S	Powerfit S200S/300	Powerfit S 500	A 400/FT	A 500	A 600	A 700
6 Nm	6 Nm	6 Nm	6 Nm	6 Nm	6 Nm	6 Nm	6 Nm	6 Nm	6 Nm
11 Nm	11 Nm	11 Nm	11 Nm	11 Nm	11 Nm	11 Nm	11 Nm	11 Nm	11 Nm
5 Nm	5 Nm	5 Nm	5 Nm	5 Nm	5 Nm	5 Nm	5 Nm	5 Nm	5 Nm
8 Nm	8 Nm	8 Nm	8 Nm	8 Nm	8 Nm	8 Nm	8 Nm	8 Nm	8 Nm
17 Nm	17 Nm	17 Nm	17 Nm	17 Nm	17 Nm	17 Nm	17 Nm	17 Nm	17 Nm
6 Nm	6 Nm	6 Nm	6 Nm	6 Nm	6 Nm	6 Nm	6 Nm	6 Nm	6 Nm
8 Nm	8 Nm	8 Nm	8 Nm	8 Nm	8 Nm	8 Nm	8 Nm	8 Nm	8 Nm
12 Nm	12 Nm	12 Nm	12 Nm	12 Nm	12 Nm	12 Nm	12 Nm	12 Nm	12 Nm
6 Nm	6 Nm	6 Nm	6 Nm	6 Nm	6 Nm	6 Nm	6 Nm	6 Nm	6 Nm
11 Nm	11 Nm	11 Nm	11 Nm	11 Nm	11 Nm	11 Nm	11 Nm	11 Nm	11 Nm

Table 1: Torque

All torques apply with a tolerance of ± 1 Nm

\* M-M8-45° 8Nm

## a.) Battery operation (charge/discharge operation)

The load is only supplied by the battery. The charging process depends on the application and must be carried out in accordance with the recommendations of the battery-manufacturers.

2.3 Maintaining the full charge (float charge)  
 Devices complying with the stipulations under DN 41773 must be used. They are to be set so that the average cell voltage is acc. to table 2.

2.4 Equalizing charge  
 Because it is possible to exceed the permitted load voltages, appropriate measures must be taken, e.g. switch off the load. Equalizing charges are required after deep discharges and/or inadequate charges. They can be carried out with 2.40 Vpc (A 500: 2.45 Vpc) for up to 48 hours and with unlimited current.

The cells / block temperature must never exceed 45° C. If it does, stop charging or revert to float charge to allow the temperature to drop.

2.5 Alternating currents  
 When recharging up to 2.40 Vpc under operation modes 2.2 the actual value of the alternating current is occasionally permitted to reach 10 A (RMS) / 100 Ah  $C_{10}$ . In a fully charged state during float charge or standby parallel operation the actual value of the alternating current must not exceed 5 A (RMS) / 100 Ah  $C_{10}$ .

2.6 Charging currents  
 The charging currents are not limited during standby parallel operation or buffer operation without recharging stage. The charging current should range between the values given in table 5 (guide values).

In cycling operation, the maximum current values as shown in table 5 must not be exceeded.

Float voltage [Vpc]	Nominal temp. [°C]
2.27	20
2.27	25
2.27	25
2.27	25
2.27	20
2.27	20
2.27	20
2.30	20
2.25	20
2.25	20

Table 2: Float voltage

To reduce the charging time a boost charging stage can be applied in which the charging voltage acc. to table 3 can be adjusted (standby-parallel operation with boost recharging stage). Automatic change over to charging voltage acc. to table 2 should be applied.

Marathon L/L	Marathon M/M-FT	Sprinter P/P	Sprinter S	Powerfit S200S/300	Powerfit S 500	A 400/FT	A 500	A 600	A 700
2.35-2.40	2.35-2.40	2.35-2.40	2.35-2.40	2.35-2.40	2.35-2.40	2.35-2.40	2.35-2.40	2.35-2.40	2.35-2.40
2.35-2.40	2.35-2.40	2.35-2.40	2.35-2.40	2.35-2.40	2.35-2.40	2.35-2.40	2.35-2.40	2.35-2.40	2.35-2.40
2.35-2.40	2.35-2.40	2.35-2.40	2.35-2.40	2.35-2.40	2.35-2.40	2.35-2.40	2.35-2.40	2.35-2.40	2.35-2.40
2.35-2.40	2.35-2.40	2.35-2.40	2.35-2.40	2.35-2.40	2.35-2.40	2.35-2.40	2.35-2.40	2.35-2.40	2.35-2.40
2.35-2.40	2.35-2.40	2.35-2.40	2.35-2.40	2.35-2.40	2.35-2.40	2.35-2.40	2.35-2.40	2.35-2.40	2.35-2.40
2.35-2.40	2.35-2.40	2.35-2.40	2.35-2.40	2.35-2.40	2.35-2.40	2.35-2.40	2.35-2.40	2.35-2.40	2.35-2.40
2.35-2.40	2.35-2.40	2.35-2.40	2.35-2.40	2.35-2.40	2.35-2.40	2.35-2.40	2.35-2.40	2.35-2.40	2.35-2.40
2.35-2.40	2.35-2.40	2.35-2.40	2.35-2.40	2.35-2.40	2.35-2.40	2.35-2.40	2.35-2.40	2.35-2.40	2.35-2.40
2.35-2.40	2.35-2.40	2.35-2.40	2.35-2.40	2.35-2.40	2.35-2.40	2.35-2.40	2.35-2.40	2.35-2.40	2.35-2.40

Table 3: Voltage on boost charging stage

## b.) Buffer operation

With buffer operation the battery charger is not able to supply the maximum load current at all times. The load current intermittently exceeds the nominal current of the battery charger. During this period the battery supplies power to the load. The charging current is limited to the peak operation. The charging current must be set acc. to table 4. This has to be carried out in accordance with the manufacturers restrictions.

Marathon L/L	Marathon M/M-FT	Sprinter P/P	Sprinter S	Powerfit S200S/300	Powerfit S 500	A 400/FT	A 500	A 600	A 700
2.29-2.32	2.29-2.32	2.29-2.32	2.29-2.32	2.29-2.32	2.29-2.32	2.29-2.32	2.29-2.32	2.29-2.32	2.29-2.32
2.29-2.32	2.29-2.32	2.29-2.32	2.29-2.32	2.29-2.32	2.29-2.32	2.29-2.32	2.29-2.32	2.29-2.32	2.29-2.32
2.29-2.32	2.29-2.32	2.29-2.32	2.29-2.32	2.29-2.32	2.29-2.32	2.29-2.32	2.29-2.32	2.29-2.32	2.29-2.32
2.29-2.32	2.29-2.32	2.29-2.32	2.29-2.32	2.29-2.32	2.29-2.32	2.29-2.32	2.29-2.32	2.29-2.32	2.29-2.32
2.29-2.32	2.29-2.32	2.29-2.32	2.29-2.32	2.29-2.32	2.29-2.32	2.29-2.32	2.29-2.32	2.29-2.32	2.29-2.32
2.29-2.32	2.29-2.32	2.29-2.32	2.29-2.32	2.29-2.32	2.29-2.32	2.29-2.32	2.29-2.32	2.29-2.32	2.29-2.32
2.29-2.32	2.29-2.32	2.29-2.32	2.29-2.32	2.29-2.32	2.29-2.32	2.29-2.32	2.29-2.32	2.29-2.32	2.29-2.32
2.29-2.32	2.29-2.32	2.29-2.32	2.29-2.32	2.29-2.32	2.29-2.32	2.29-2.32	2.29-2.32	2.29-2.32	2.29-2.32
2.29-2.32	2.29-2.32	2.29-2.32	2.29-2.32	2.29-2.32	2.29-2.32	2.29-2.32	2.29-2.32	2.29-2.32	2.29-2.32
2.29-2.32	2.29-2.32	2.29-2.32	2.29-2.32	2.29-2.32	2.29-2.32	2.29-2.32	2.29-2.32	2.29-2.32	2.29-2.32

Table 4: Charge voltage in buffer operation

## c.) Switch-mode operation

When charging, the battery is separated from the load. The charge voltage of the battery must be set acc. to table 3 (max. values). The charging process must be monitored. If the charge current reduces to less than 1.5 A / 100 Ah  $C_{10}$ , the mode switches to float charge acc. to item 2.3 or it switches after reaching the voltage value acc. to table 3.

Marathon L/L	Marathon M/M-FT	Sprinter P/P	Sprinter S	Powerfit S200S/300	Powerfit S 500	A 400/FT	A 500	A 600	A 700
10 to 35 A per 100Ah	10 to 35 A per 100Ah	10 to 35 A per 100Ah	10 to 35 A per 100Ah						
10 to 35 A per 100Ah	10 to 35 A per 100Ah	10 to 35 A per 100Ah	10 to 35 A per 100Ah						
10 to 35 A per 100Ah	10 to 35 A per 100Ah	10 to 35 A per 100Ah	10 to 35 A per 100Ah						
10 to 35 A per 100Ah	10 to 35 A per 100Ah	10 to 35 A per 100Ah	10 to 35 A per 100Ah						
10 to 35 A per 100Ah	10 to 35 A per 100Ah	10 to 35 A per 100Ah	10 to 35 A per 100Ah						
10 to 35 A per 100Ah	10 to 35 A per 100Ah	10 to 35 A per 100Ah	10 to 35 A per 100Ah						
10 to 35 A per 100Ah	10 to 35 A per 100Ah	10 to 35 A per 100Ah	10 to 35 A per 100Ah						
10 to 35 A per 100Ah	10 to 35 A per 100Ah	10 to 35 A per 100Ah	10 to 35 A per 100Ah						
10 to 35 A per 100Ah	10 to 35 A per 100Ah	10 to 35 A per 100Ah	10 to 35 A per 100Ah						

Table 5: Charging currents

## 2.7 Temperature

The recommended operation temperature range for lead acid batteries is 10° C to 30° C (best: nominal temperature ± 5K). Higher temperatures will seriously reduce service life. Lower temperatures reduce the available capacity. The absolute maximum temperature is 55° C and should not exceed 45° C in service. All technical data refer to a nominal temperature of 20° C and 25° C respectively.

2.8 Temperature related charge voltage  
 The temperature related adjustment has to be carried out acc. to the following figures 1 to 5. An adjustment of the charge voltage must not be applied within a specified temperature range as shown in table 6.

Marathon L/L	Marathon M/M-FT	Sprinter P/P	Sprinter S	Powerfit S200S/300	Powerfit S 500	A 400/FT	A 500	A 600	A 700
15° C to 35° C	15° C to 35° C	15° C to 35° C	15° C to 35° C	15° C to 35° C	15° C to 35° C	15° C to 35° C	15° C to 35° C	15° C to 35° C	15° C to 35° C
15° C to 35° C	15° C to 35° C	15° C to 35° C	15° C to 35° C	15° C to 35° C	15° C to 35° C	15° C to 35° C	15° C to 35° C	15° C to 35° C	15° C to 35° C
15° C to 35° C	15° C to 35° C	15° C to 35° C	15° C to 35° C	15° C to 35° C	15° C to 35° C	15° C to 35° C	15° C to 35° C	15° C to 35° C	15° C to 35° C
15° C to 35° C	15° C to 35° C	15° C to 35° C	15° C to 35° C	15° C to 35° C	15° C to 35° C	15° C to 35° C	15° C to 35° C	15° C to 35° C	15° C to 35° C
15° C to 35° C	15° C to 35° C	15° C to 35° C	15° C to 35° C	15° C to 35° C	15° C to 35° C	15° C to 35° C	15° C to 35° C	15° C to 35° C	15° C to 35° C
15° C to 35° C	15° C to 35° C	15° C to 35° C	15° C to 35° C	15° C to 35° C	15° C to 35° C	15° C to 35° C	15° C to 35° C	15° C to 35° C	15° C to 35° C
15° C to 35° C	15° C to 35° C	15° C to 35° C	15° C to 35° C	15° C to 35° C	15° C to 35° C	15° C to 35° C	15° C to 35° C	15° C to 35° C	15° C to 35° C
15° C to 35° C	15° C to 35° C	15° C to 35° C	15° C to 35° C	15° C to 35° C	15° C to 35° C	15° C to 35° C	15° C to 35° C	15° C to 35° C	15° C to 35° C
15° C to 35° C	15° C to 35° C	15° C to 35° C	15° C to 35° C	15° C to 35° C	15° C to 35° C	15° C to 35° C	15° C to 35° C	15° C to 35° C	15° C to 35° C
15° C to 35° C	15° C to 35° C	15° C to 35° C	15° C to 35° C	15° C to 35° C	15° C to 35° C	15° C to 35° C	15° C to 35° C	15° C to 35° C	15° C to 35° C

Table 6: Temperature range without voltage adjustment




Fig. 1: Marathon L/L and Powerfit S; charging voltage vs. temperature

The charging voltage must be set to the nominal value, the maximum value must not be exceeded.

**5. Faults**  
 Call the service agents immediately if faults in the battery or the charging unit are found. Recorded data as described in item 3, must be made available to the service agent. It is recommended that a service contract is taken out with our agent.

**6. Storage and taking out of operation**  
 In case of storage or taking out of operation for a longer period of time, the battery must be fully charged and the electrolyte level must be checked. To avoid acid damage the following charging methods can be chosen:  
 1. Annual refreshing charge acc. to item 2.4.  
 2. Gel-batteries AGO, ASO, AGO and A700 can be stored without refreshing charge for maximum 24 months at 5 20°C. At average ambient temperatures of more than the nominal temperature shorter intervals can be necessary.

**7. Transport**  
 Cells and blocks must be transported in an upright position. Batteries without any visible damage are not defined as dangerous goods under the regulations for transport of dangerous goods by road (ADR) or by railway (RID). They must be protected against short circuits, slipping, upsetting or damaging. Cells/blocks must be suitable stacked and secured on pallets (ADR and RID, special provision 508). It is prohibited to ship pallets.

**8. Central degassing**  
 The ventilation of battery rooms and cabinets, respectively, must be carried out acc. to EN 50272-2 always. Battery rooms are to be considered as safe from explosions, when by natural or technical ventilation the concentration of hydrogen is kept below 4% in air. This standard contains also notes and calculations regarding safety distance of battery objects.

**9. Technical Data**  
 The following tables contain values of either capacity (C<sub>10</sub>) or discharge rates (constant current or constant power) at different voltages (U<sub>1</sub>, U<sub>2</sub>) and to different final voltages (U<sub>3</sub>).

All technical data refer to either 20°C or 25°C (depends on battery type).

**9.1 AGM - Types**  
**9.1.1. Marathon LXL**

Discharge time t <sub>d</sub>	10 min		30 min		1 h		3 h		5 h		10 h		Length [mm]	Width [mm]	Height* [mm]	Weight approx. [kg]
	C <sub>10</sub>	C <sub>10</sub> [Ah]	C <sub>30</sub>	C <sub>30</sub> [Ah]	C <sub>1</sub>	C <sub>1</sub> [Ah]	C <sub>3</sub>	C <sub>3</sub> [Ah]	C <sub>5</sub>	C <sub>5</sub> [Ah]	C <sub>10</sub>	C <sub>10</sub> [Ah]				
L12V15	8.5	8.5	9.9	13.2	13.0	13.0	14.0	14.0	14.0	14.0	14.0	14.0	161	76	167	6.5
L12V24	10.6	13.9	15.8	21.0	21.0	21.0	22.0	22.0	22.0	22.0	22.0	22.0	181	127	174	10.0
L12V32	14.1	18.7	21.4	27.9	27.9	27.9	32.0	32.0	32.0	32.0	32.0	32.0	198	168	175	13.5
L12V42	19.6	25.7	29.4	38.1	38.1	38.1	42.0	42.0	42.0	42.0	42.0	42.0	234	169	190	18.5
L12V55	21.6	29.5	36.0	44.7	44.7	44.7	49.0	49.0	49.0	49.0	49.0	49.0	272	166	190	22.0
L12V60	30.3	41.5	51.2	65.1	71.0	71.0	80.0	80.0	80.0	80.0	80.0	80.0	359	172	226	30.0
L6V110	48.4	65.0	75.5	102.3	107.0	107.0	112.0	112.0	112.0	112.0	112.0	112.0	272	166	190	23.0
L6V160	66.6	95.5	111.0	133.5	148.0	148.0	162.0	162.0	162.0	162.0	162.0	162.0	359	171	228	31.5
L2V220	87.4	127.0	150.0	198.6	198.6	198.6	220.0	220.0	220.0	220.0	220.0	220.0	209	139	265	18.0
L2V270	107.3	155.5	183.0	229.2	229.2	229.2	243.0	243.0	243.0	243.0	243.0	243.0	209	136	265	18.3
L2V320	135.8	190.5	225.0	271.8	271.8	271.8	288.0	288.0	288.0	288.0	288.0	288.0	209	202	265	24.2
L2V375	155.8	221.5	262.0	318.0	318.0	318.0	337.5	337.5	337.5	337.5	337.5	337.5	209	202	265	26.5
L2V425	169.9	247.0	291.0	360.0	360.0	360.0	382.5	382.5	382.5	382.5	382.5	382.5	209	202	265	28.8
L2V470	186.6	277.0	324.0	399.0	399.0	399.0	428.5	428.5	428.5	428.5	428.5	428.5	209	270	265	32.8
L2V575	204.1	304.5	357.0	438.0	438.0	438.0	474.0	474.0	474.0	474.0	474.0	474.0	209	270	265	35.0
XL12V50	220.8	334.5	394.0	490.0	490.0	490.0	520.0	520.0	520.0	520.0	520.0	520.0	209	270	265	37.3
XL12V70	28.6	39.1	45.8	57.0	57.0	57.0	61.5	61.5	61.5	61.5	61.5	61.5	220	172	239	19.5
XL12V85	34.6	48.1	57.5	73.5	73.5	73.5	80.5	80.5	80.5	80.5	80.5	80.5	262	172	239	25.0
XL6V160	74.3	100	120	147	147	147	165.5	165.5	165.5	165.5	165.5	165.5	309	172	239	29.7
U <sub>1</sub> (V) (2 V cell)	1.60	1.60	1.60	1.70	1.70	1.70	1.80	1.80	1.80	1.80	1.80	1.80				
U <sub>2</sub> (V) (6 V block)	4.80	4.80	4.80	5.10	5.10	5.10	5.25	5.25	5.25	5.25	5.25	5.25				
U <sub>3</sub> (V) (12 V block)	9.60	9.60	9.60	10.2	10.2	10.2	10.5	10.5	10.5	10.5	10.5	10.5				

All technical data refer to 20°C.  
 \* Includes installed connector




Fig. 2: Marathon M/M-FT, Sprinter P/P/P, Sprinter S; charging voltage vs. temperature




Fig. 3: A 400FT; charging voltage vs. temperature




Fig. 4: A 500; charging voltage vs. temperature




Fig. 5: A 600; A 700; charging voltage vs. temperature

**2.9. Electrolyte**  
 The electrolyte is diluted sulphuric acid and is used in a glass mat for AGM products or in a gel for Sonnenschein products.

**3. Battery maintenance and control**  
 Keep the battery clean and dry to avoid creeping currents. The cleaning should be carried out acc. to the information leaflet. Cleaning of batteries\* published by ZVEI (German Electrical and Electronic Manufacturer Association, Working Group 'Industrial Batteries'). Plastic parts of the battery, especially containers, must be cleaned with pure water without additives.

**4. Tests**  
 Tests have to be carried out according to IEC 60956-21, DIN 43539 part 1. Special instructions like DIN VDE 0107 and EN 50272 have to be observed.

**Capacity test**  
 In order to make sure the battery is fully charged IU-charge methods as shown in table 8 can be applied depending on the different battery types. The current available to the battery must be between 10 A / 100 Ah C<sub>10</sub> and 35 A / 100 Ah C<sub>10</sub>.

**Annual visual check:**  
 - Screw-connections without locking devices have to be checked for tightness  
 - Battery installation and arrangement  
 - Ventilation

**At least every 6 month measure and record:**  
 - Float voltage of several cells/blocks  
 - Surface temperature of several cells/blocks  
 - Battery-room temperature

**Annual measurement and recording:**  
 - Float voltage of all cells / blocks  
 - Surface temperature of all cells/blocks  
 - Battery-room temperature  
 - Insulation-resistance acc. to DIN 43539 part 1

	2V	4V	6V	12V
Marathon L	+0.27/-0.1	-	+0.35/-0.17	+0.49/-0.24
Marathon XL	-	-	+0.35/-0.17	+0.49/-0.24
Marathon M/M-FT	-	-	+0.35/-0.17	+0.49/-0.24
Sprinter P/P/P	-	-	+0.35/-0.17	+0.49/-0.24
Sprinter S	-	-	+0.35/-0.17	+0.49/-0.24
Powerfit S 200/S 300	-	-	+0.35/-0.17	+0.49/-0.24
Powerfit S 500	-	-	+0.35/-0.17	+0.49/-0.24
A 400FT	-	-	+0.35/-0.17	+0.49/-0.24
A 500	-	-	+0.35/-0.17	+0.49/-0.24
A 600	-	-	+0.35/-0.17	+0.49/-0.24
A 700	-	-	+0.35/-0.17	+0.49/-0.24

Table 7: Criteria for voltage measurements

**Table 8: Preparation for capacity test (voltage values refer to the nominal temperature. In case of temperatures others than the nominal values see item 2.8)**

	Option 1	Option 2
Marathon LXL	2.27 Vpc ± 72 hours	2.40 Vpc ± 16 h (max. 48h) followed by 2.27 Vpc ± 8h
Marathon M/M-FT	2.27 Vpc ± 72 hours	2.40 Vpc ± 16 h (max. 48h) followed by 2.27 Vpc ± 8h
Sprinter P/P/P	2.27 Vpc ± 72 hours	2.40 Vpc ± 16 h (max. 48h) followed by 2.27 Vpc ± 8h
Sprinter S	2.27 Vpc ± 72 hours	2.40 Vpc ± 16 h (max. 48h) followed by 2.27 Vpc ± 8h
Powerfit S 200/S 300	2.27 Vpc ± 72 hours	2.40 Vpc ± 16 h (max. 48h) followed by 2.27 Vpc ± 8h
Powerfit S 500	2.27 Vpc ± 72 hours	2.40 Vpc ± 16 h (max. 48h) followed by 2.27 Vpc ± 8h
A 400FT	2.27 Vpc ± 72 hours	2.40 Vpc ± 16 h (max. 48h) followed by 2.27 Vpc ± 8h
A 500	2.30 Vpc ± 72 hours	2.40 Vpc ± 16 h (max. 48h) followed by 2.27 Vpc ± 8h
A 600	2.25 Vpc ± 72 hours	2.40 Vpc ± 16 h (max. 48h) followed by 2.25 Vpc ± 8h
A 700	2.25 Vpc ± 72 hours	2.40 Vpc ± 16 h (max. 48h) followed by 2.25 Vpc ± 8h

Table 8: Preparation for capacity test (voltage values refer to the nominal temperature. In case of temperatures others than the nominal values see item 2.8)

9.1.2. Marathon M/H-FT

Type	Nominal voltage [V]	C <sub>10</sub> [Ah] 1.75 V per cell	Constant current discharge [A], U <sub>d</sub> = 1.75 V per cell				Length max. [mm]	Width max. [mm]	Height max. [mm]	Weight approx. [kg]		
			0.5 h	1 h	3 h	5 h					10 h	
M12V20T	12	30	36.9	21.2	15.1	8.40	5.50	2.90	171	130	188	10.7
M12V40F	12	40	51.3	30.5	21.5	11.9	7.90	4.30	196	167	189	17.8
M12V45F	12	45	57.8	33.2	24.0	13.5	8.70	4.70	220	171	254	17.5
M12V70F	12	70	90.8	51.6	36.8	20.8	13.4	7.40	290	174	235	27.8
M12V90F	12	90	107	65.7	48.6	25.9	16.7	9.20	306	174	235	32.8
M6V190F	6	190	246	144	102	56.0	35.9	19.5	306	174	235	33.5
M6V200FT	6	200	220	135	100	55.2	36.3	20.2	361	132	250	34.0
M12V35FT	12	35	44.0	28.5	14.0	8.60	3.90	2.90	107	107	189	14.0
M12V50FT	12	47	61.0	34.3	20.0	10.5	6.80	4.70	290	107	231	18.0
M12V60FT	12	59	68.8	44.1	26.0	11.0	6.00	2.90	290	107	263	23.0
M12V90FT	12	86	108	64.0	48.4	24.9	15.9	8.70	395	105	270	31.0
M12V105FT	12	100	115	70.0	51.6	26.5	18.7	10.3	511	110	238	35.8
M12V125FT	12	121	141	88.1	65.3	37.2	23.4	12.4	559	124	263	47.8
M12V155FT	12	150	174	103	77.7	43.2	28.1	15.4	559	124	263	53.8
M12V180FT	12	180	202	119	87.5	50.8	33.1	18.1	559	125	318	60.3

All technical data refer to 25° C.

9.1.3. Sprinter P/XP

Type	Nominal voltage [V]	16 min.-power [W], U <sub>d</sub> = 1.80 V per cell	Capacity C <sub>20</sub> [Ah], U <sub>d</sub> = 1.80 V per cell	Length max. [mm]	Width max. [mm]	Height <sup>a</sup> max. [mm]	Weight approx. [kg]
P12V875	12	875	41	200	169	176	14.5
P12V1270	12	1270	51	233	169	191	19.5
P12V1575	12	1575	61	273	167	191	24.0
P12V2130	12	2130	86	360	173	227	33.0
P 6V1700	6	1700	122	273	167	191	26.0
P 6V2030	6	2030	178	360	172	227	32.5
XP 12V1600	12	1600	56.4	220	172	235	22.5
XP 12V2500	12	2500	69.5	262	172	239	27.7
XP 12V3000	12	3000	92.8	309	172	239	32.8
XP 6V2800	6	2870	195	309	172	241	32.6

These batteries are especially designed for high rate discharges. Further details depending on the discharge time and cut off voltage must be taken from the actual product brochure.

All technical data refer to 25° C.

<sup>a</sup> Includes installed connector

9.1.4. Sprinter S

Type	Nominal voltage [V]	C <sub>10</sub> [Ah] U <sub>d</sub> = 1.80 V per cell	Constant power [Watt per cell], U <sub>d</sub> = 1.87 V per cell				Length max. [mm]	Width max. [mm]	Height max. [mm]	Weight approx. [kg]		
			5 min	10 min	15 min	30 min					60 min	90 min
S12V120F	12	24	242	151	117	72	41	29	173	167	181	12.1
S18V170F	12	40	323	215	167	102	59	41	198	167	189	16.4
S12V285F	12	70	543	365	285	169	98	69	260	174	235	27.8
S12V300F	12	89	654	415	308	180	105	76	260	174	235	28.7
S12V370F	12	89	723	484	373	200	131	92	306	174	235	33.4
S12V500F	12	131	864	615	505	310	178	126	344	172	268	48.1
S6V740F	6	175	1446	970	746	458	262	184	306	174	235	33.4

All technical data refer to 25° C.

9.1.5. Powerfit S 200

Type	Nominal voltage [V]	C <sub>20</sub> [Ah] 1.75 V per cell	C <sub>100</sub> [Ah] 1.75 V per cell	C <sub>100</sub> [Ah] 1.80 V per cell	Length* [mm]	Width* [mm]	Height* [mm]	Weight approx. [kg]
S2006/12 S	6	1.17	1.11	0.71	97	24	57.5	0.28
S2006/4 S	6	4.40	4.17	2.69	70	47	106	0.69
S2006/7 S	6	6.06	6.48	4.18	151	34	100	1.28
S2006/12 S	6	11.7	11.1	7.16	151	51	100	1.85
S212/12 S	12	1.17	1.11	0.71	97	43	58	0.57
S212/23 S	12	2.25	2.13	1.37	178	35	66	1.0
S212/23 S	12	3.14	2.96	1.91	134	67	66.5	1.3
S212/4 S	12	3.91	3.70	2.38	90	70	107	1.6
S212/7 S	12	7.62	7.15	5.61	151	65	100	2.45
S212/12 S	12	11.7	11.1	7.16	151	98	101	3.8
S212/18 G5	12	17.6	16.6	10.7	181.5	77	167.5	5.7
S212/26 G5	12	25.4	24.0	15.4	164.5	175	125	8.7
S212/40 F6	12	38.8	37.2	22.0	197	165	170	13.2

All technical data refer to 20° C. Figures are also valid for other terminals.

\* ± 1mm \*\* ± 2mm

9.1.6. Powerfit S 300

Type	Nominal voltage [V]	C <sub>20</sub> [Ah] 1.75 V per cell	C <sub>100</sub> [Ah] 1.75 V per cell	C <sub>100</sub> [Ah] 1.80 V per cell	Length* [mm]	Width* [mm]	Height* [mm]	Weight approx. [kg]
S3006/12 S	6	1.2	1.13	0.78	97	25	56	0.30
S3006/4 S	6	4.0	3.80	2.62	70	47	106	0.85
S3006/7 S	6	7.0	6.55	4.58	151	34	100	1.30
S3006/12 S	6	12	11.4	7.86	151	50	100	2.05
S312/12 S	12	1.2	1.13	0.78	97	45	59	0.59
S312/23 S	12	2.3	2.19	1.50	178	34	65	0.94
S312/23 S	12	3.2	3.00	1.96	134	67	66	1.30
S312/4 S	12	4.0	3.80	2.62	90	70	106	1.67
S312/7 S	12	7.0	6.64	4.58	151	65	96	2.60
S312/12 S	12	12	11.4	7.86	151	98	106	4.03
S312/18 G5	12	18	16.1	11.1	181	76	166	6.15
S312/26 G5	12	26	24.7	17.0	166	175	125	9.40
S312/40 G5	12	40	37.9	26.2	196	165	171	14.3

All technical data refer to 20° C. Figures are also valid for other terminals.

\* ± 2mm \*\* ± 3mm

9.1.7. Powerfit S 500

Type	Nominal voltage [V]	C <sub>20</sub> [Ah] 1.75 V per cell	C <sub>100</sub> [Ah] 1.75 V per cell	C <sub>100</sub> [Ah] 1.80 V per cell	Length max. [mm]	Width max. [mm]	Height max. [mm]	Weight approx. [kg]
S512/25	12	25.0	24.0	15.8	168	127	174	9.50
S512/28	12	38.0	36.0	23.2	196	168	175	13.5
S512/50	12	51.0	48.0	32.5	234	169	190	18.5
S512/80	12	61.0	58.0	40.8	272	166	190	23.0
S512/92	12	92.0	87.0	54.4	359	172	226	30.0
S506/130	6	128	121	80.0	272	188	190	23.0
S506/185	6	185	174	116	359	171	226	31.5

All technical data refer to 20° C.



9.2.1. A 600

Type	Discharge time $t_d$		Capacity $C_n$ [Ah]		10 h		5 h		3 h		1 h		Nominal voltage [V]	DNR type designation	Length max. [mm]	Width max. [mm]	Height max. [mm]	Weight approx. [kg]
	10 min	30 min	$C_{10}$	$C_5$	$C_3$	$C_1$	$C_{10}$	$C_5$	$C_3$	$C_1$	$C_{10}$	$C_5$						
A612/100	53.0	80.0	98.0	132	143.5	165	244	190	282	28.5								
A612/150	1.85	2.67	3.40	4.70	5.00	6.00	6.55	98.4	98.4	3.60								
A606/200	3.83	5.50	6.80	8.70	10.0	12.0	181	176	157	5.00								
A602/225	7.00	9.50	12.0	15.0	16.5	20.0	210	175	181	14.1								
A602/280	11.3	18.5	20.0	28.7	29.0	32.0	210	175	181	19.0								
A602/315	16.8	25.5	31.0	40.8	44.5	50.0	278	175	196	23.5								
A602/415	19.3	29.0	42.0	51.9	57.5	65.0	353	175	196	32.0								
A602/500	27.6	42.5	52.0	68.4	74.5	85.0	404	244	276	35.0								
A602/560	29.5	44.5	53.0	72.9	81.0	90.0	284	267	237	35.0								
A602/750	30.5	45.0	54.0	75.3	85.0	100.0	513	189	223	37.0								
A602/1100	39.0	58.0	71.0	87.8	98.0	120.0	513	223	223	46.0								
A602/1510	53.6	81.0	96.0	138	152	180	518	274	244	64.5								
A602/1650C	57.1	85.5	100.0	143	155	180	548	115	275	40.0								
A602/2240	57.1	85.5	113	143	155	164	569	128	321	58.4								
A602/3300																		

All technical data refer to 20° C.

\* Includes installed connector  
 \* DIN 40 742  
 \*\* DIN 40 744

9.2.2. A 500

Type	Discharge time $t_d$		Capacity $C_n$ [Ah]		10 h		5 h		3 h		1 h		Nominal voltage [V]	DNR type designation	Length max. [mm]	Width max. [mm]	Height max. [mm]	Weight approx. [kg]
	10 min	30 min	$C_{10}$	$C_5$	$C_3$	$C_1$	$C_{10}$	$C_5$	$C_3$	$C_1$	$C_{10}$	$C_5$						
A502/10	4.80	6.40	7.10	9.00	9.50	10.0	52.9	50.5	98.4	0.70								
A504/2.5	1.40	1.95	2.30	3.00	3.15	3.3	90.5	34.5	64.4	0.50								
A506/1.2	0.50	0.68	0.80	1.05	1.1	1.00	97.3	28.5	55.6	0.33								
A508/3.5	1.40	1.95	2.30	3.00	3.15	3.3	135	34.8	64.4	0.70								
A508/4.2	1.10	1.75	2.50	3.78	3.95	4.00	52.0	62.3	102	0.80								
A506/6.5	2.80	3.50	4.00	4.80	5.30	6.3	152	34.5	98.4	1.30								
A508/10	4.80	6.40	7.10	9.00	9.50	10.0	152	50.5	98.4	2.10								
A512/1.2	0.50	0.68	0.80	1.05	1.1	1.00	178	34.1	64.4	1.0								
A512/2.5	0.80	1.10	1.50	1.80	1.85	1.9	97.5	49.5	54.9	0.65								
A512/3.5	1.40	1.95	2.30	3.00	3.15	3.3	135	68.0	64.4	1.50								
A512/6.5	2.80	3.50	4.00	4.80	5.30	6.3	152	85.5	98.4	2.80								
A512/10	4.80	6.40	7.10	9.00	9.50	10.0	152	98.0	98.4	4.00								
A512/15	7.00	9.00	10.6	13.8	14.5	15.0	181	76	167	6.00								
A512/20	7.80	11.45	14.4	18.6	20.5	22.0	167	176	128	9.60								
A512/30	11.4	16.3	20.1	24.8	26.5	27.0	303.0	197	132	18.0								
A512/40	14.1	19.5	24.0	28.5	34.0	36.0	40.0	210	175	14.8								
A512/65	19.3	27.6	35.7	42.9	48.5	50.0	261	278	175	20.8								
A512/90	22.1	30.9	37.1	48.6	52.0	56.0	60.0	353	175	19.0								
A512/120	22.5	33.8	40.9	53.7	58.5	62.0	65.0	353	175	20.8								
A512/165	33.1	47.5	59.0	69.0	75.5	80.0	115	286	230	40.0								
A512/115	37.8	56.5	67.0	84.0	85.0	104	115	286	230	40.0								
A512/120	44.5	62.0	74.0	89.7	96.0	102	120	513	189	223								
A512/140	50.5	71.5	85.4	105.3	113	119	140	513	223	223								
A512/200	68.5	101	120	151.8	164	173	200	518	274	47.0								
U <sub>1</sub> [V] (2 V cell)	1.6	1.6	1.65	1.70	1.70	1.80	1.75											
U <sub>1</sub> [V] (4 V block)	3.2	3.2	3.3	3.4	3.4	3.6	3.5											
U <sub>1</sub> [V] (8 V block)	4.8	4.8	4.95	5.1	5.1	5.4	5.25											
U <sub>1</sub> [V] (8 V block)	6.4	6.4	6.6	6.8	6.8	7.2	7.0											
U <sub>1</sub> [V] (12 V block)	9.6	9.6	9.9	10.2	10.2	10.8	10.5											

All technical data refer to 20° C.

9.2 GEL - Types  
 9.2.1. A 400/FT

Type	Discharge time $t_d$		Capacity $C_n$ [Ah]		10 h		5 h		3 h		1 h		Nominal voltage [V]	DNR type designation	Length max. [mm]	Width max. [mm]	Height max. [mm]	Weight approx. [kg]
	10 min	30 min	$C_{10}$	$C_5$	$C_3$	$C_1$	$C_{10}$	$C_5$	$C_3$	$C_1$	$C_{10}$	$C_5$						
A612/100	53.0	80.0	98.0	132	143.5	165	244	190	282	28.5								
A612/150	1.85	2.67	3.40	4.70	5.00	6.00	6.55	98.4	98.4	3.60								
A606/200	3.83	5.50	6.80	8.70	10.0	12.0	181	176	157	5.00								
A602/225	7.00	9.50	12.0	15.0	16.5	20.0	210	175	181	14.1								
A602/280	11.3	18.5	20.0	28.7	29.0	32.0	210	175	181	19.0								
A602/315	16.8	25.5	31.0	40.8	44.5	50.0	278	175	196	23.5								
A602/415	19.3	29.0	42.0	51.9	57.5	65.0	353	175	196	32.0								
A602/500	27.6	42.5	52.0	68.4	74.5	85.0	404	244	276	35.0								
A602/560	29.5	44.5	53.0	72.9	81.0	90.0	284	267	237	35.0								
A602/750	30.5	45.0	54.0	75.3	85.0	100.0	513	189	223	37.0								
A602/1100	39.0	58.0	71.0	87.8	98.0	120.0	513	223	223	46.0								
A602/1510	53.6	81.0	96.0	138	152	180	518	274	244	64.5								
A602/1650C	57.1	85.5	100.0	143	155	180	548	115	275	40.0								
A602/2240	57.1	85.5	113	143	155	164	569	128	321	58.4								
A602/3300																		

All technical data refer to 20° C.

All technical data refer to 20° C.

\* Includes installed connector  
 \* DIN 40 742  
 \*\* DIN 40 744

9.2.4. A 700

Type	Discharge time $t_d$		Capacity $C_n$ [Ah]		10 h		5 h		3 h		1 h		Nominal voltage [V]	DNR type designation	Length max. [mm]	Width max. [mm]	Height max. [mm]	Weight approx. [kg]
	10 min	30 min	$C_{10}$	$C_5$	$C_3$	$C_1$	$C_{10}$	$C_5$	$C_3$	$C_1$	$C_{10}$	$C_5$						
A706/21	7.00	10.2	12.2	16.5	19.0	21.0	115	176	268	8.2								
A706/42	14.1	20.5	24.4	33.0	38.0	42.0	115	178	268	16.1								
A706/63	21.1	31.7	36.6	48.5	57.0	63.0	196	178	272	18.3								
A706/84	28.5	41.0	48.8	66.0	76.5	84.0	196	178	272	18.3								
A706/105	35.3	51.0	61.0	82.8	95.5	105.0	282	178	272	24.5								
A706/128	42.5	61.5	73.2	99.3	114.5	126.0	282	178	272	26.2								
A706/140	42.1	69.5	85.3	117.0	131.0	140.0	285	232	327	36.3								
A706/175	52.8	86.5	106.0	146.4	163.5	175.0	285	232	327	36.7								
A706/210	63.3	104.0	128.0	175.5	198.0	210.0	285	232	327	42.9								
A706/245	74.0	121.5	149.0	204.9	229.0	245.0	250	232	327	35.5								
A706/280	84.5	139.0	170.0	234.0	261.5	280.0	250	232	327	37.5								
U <sub>1</sub> [V] (4 V block)	3.2	3.2	3.3	3.4	3.4	3.6	3.5											
U <sub>1</sub> [V] (8 V block)	4.8	4.8	4.95	5.1	5.1	5.4	5.4											

All technical data refer to 20° C.

9.2 GEL - Types  
 9.2.1. A 400/FT

Type	Discharge time $t_d$		Capacity $C_n$ [Ah]		10 h		5 h		3 h		1 h		Nominal voltage [V]	DNR type designation	Length max. [mm]	Width max. [mm]	Height max. [mm]	Weight approx. [kg]
	10 min	30 min	$C_{10}$	$C_5$	$C_3$	$C_1$	$C_{10}$	$C_5$	$C_3$	$C_1$	$C_{10}$	$C_5$						
A612/100	53.0	80.0	98.0	132	143.5	165	244	190	282	28.5								
A612/150	1.85	2.67	3.40	4.70	5.00	6.00	6.55	98.4	98.4	3.60								
A606/200	3.83	5.50	6.80	8.70	10.0	12.0	181	176	157	5.00								
A602/225	7.00	9.50	12.0	15.0	16.5	20.0	210	175	181	14.1								
A602/280	11.3	18.5	20.0	28.7	29.0	32.0	210	175	181	19.0								
A602/315	16.8	25.5	31.0	40.8	44.5	50.0	278	175	196	23.5								
A602/415	19.3	29.0	42.0	51.9	57.5	65.0	353	175	196	32.0								
A602/500	27.6	42.5	52.0	68.4	74.5	85.0	404	244	276	35.0								
A602/560	29.5	44.5	53.0	72.9	81.0	90.0	284	267	237	35.0								
A602/750	30.5	45.0	54.0	75.3	85.0	100.0	513	189	223	37.0								
A602/1100	39.0	58.0	71.0	87.8	98.0	120.0	513	223	223	46.0								
A602/1510	53.6	81.0	96.0	138	152	180	518	274	244	64.5								
A602/1650C	57.1	85.5	100.0	143	155	180	548	115	275	40.0								
A602/2240	57.1	85.5	113	143	155	164	569	128	321	58.4								
A602/3300																		

All technical data refer to 20° C.

All technical data refer to 20° C.


\* Includes installed connector  
 \* DIN 40 742  
 \*\* DIN 40 744

9.2.4. A 700

Type	Discharge time $t_d$		Capacity $C_n$ [Ah]		10 h		5 h		3 h		1 h		Nominal voltage [V]	DNR type designation	Length max. [mm]	Width max. [mm]	Height max. [mm]	Weight approx. [kg]
	10 min	30 min	$C_{10}$	$C_5$	$C_3$	$C_1$	$C_{10}$	$C_5$	$C_3$	$C_1$	$C_{10}$	$C_5$						
A706/21	7.00	10.2	12.2	16.5	19.0	21.0	115	176	268	8.2								
A706/42	14.1	20.5	24.4	33.0	38.0	42.0	115	178	268	16.1								
A706/63	21.1	31.7	36.6	48.5	57.0	63.0	196	178	272	18.3								
A706/84	28.5	41.0	48.8	66.0	76.5	8												

Industrial Batteries / Network Power  
Sonnenschein A400

»Outstanding price/quality ratio  
for long-term energy storage«



Industrial Batteries  
The powerful range of Network Power

Energy storage solutions for critical systems that require uninterrupted power supply. GNB® Industrial Power offers powerful batteries for your individual needs. The below table is only indicative and depends on customers' specific applications. For more information please ask a GNB sales representative.

Applica- tions	Battery ranges												
	Sonnenschein			Marathon			Alloyfit			Classic			
	A400	A700	A750	RA1	RA2	RA3	S	SP	SP	SP	SP	SP	SP
Telecom	•	•	•	•	•	•	•	•	•	•	•	•	•
UPS	•	•	•	•	•	•	•	•	•	•	•	•	•
Emergency lighting	•	•	•	•	•	•	•	•	•	•	•	•	•
Security	•	•	•	•	•	•	•	•	•	•	•	•	•
Energy	•	•	•	•	•	•	•	•	•	•	•	•	•
Railways	•	•	•	•	•	•	•	•	•	•	•	•	•
Preferential	•	•	•	•	•	•	•	•	•	•	•	•	•
Industrial	•	•	•	•	•	•	•	•	•	•	•	•	•

The GNB Network Power brand overview

**ABSOLYTE** **MARATHON**  
*Sprinter Powerfit*



**Classic**



- > VRLA batteries (Valve Regulated Lead Acid) in which the electrolyte is fixed in an absorbent glass mat (AGM)
  - > Excellent high current capability
  - > Very economical
  - > Maintenance-free (no topping up)
- > VRLA batteries (Valve Regulated Lead Acid) in which the electrolyte is fixed in a gel (dryfit technology)
  - > Highest reliability, even in non-optimal conditions
  - > Particularly suitable for cyclic applications
  - > Maintenance-free (no topping up)
- > Conventional lead-acid batteries with liquid electrolyte
  - > Extreme reliability, proven over decades
  - > Low maintenance

Further information about service is available on page 11

## Sonnenschein A400

Unmatched, high reliability dryfit Gel technology

The Sonnenschein A400 range is a reference for energy storage, with proven reliability in many installations worldwide. The success of A400 batteries comes from the superior dryfit technology, available in a wide range of models to provide a solution for every power need.

### Your benefits:

- > **dryfit Gel** – VRLA technology
- > **Lowest energy consumption** – saving costs
- > **Robust design** – resilient in harsh conditions
- > **Proof against deep discharge** – greater long-term energy delivery
- > **Completely recyclable** – low CO<sub>2</sub> footprint



### Specifications:

- Nominal capacity 5.50 - 180 Ah C<sub>20</sub>
- Exceptional energy storage capacity combined with long life
- Thick grid plates with high quality lead calcium alloy, for enhanced corrosion resistance and stability
- Very low gassing due to the internal gas recombination
- Design life: \*12 years and longer – Long Life\* according to IEC 60896-21:22
- UN38.3 classification
- Very low self-discharge rate

## Sonnenschein A400

Technical data


### Technical characteristics and data

Type	Part number	Nom. voltage V	Nom. capacity Ah	Max. load current A	Length (L) max. mm	Width (W) max. mm	Height up to top of case (H1) max. mm	Height up to top of terminals (H2) max. mm	Weight approx. PD	Internal resistance mΩ/mm	Short circuit current A	Terminal
A406/165 A	NGA4060165HSOCA	6	165	770	246	192	254	275	26.0	2.10	2800	A-Terminal
A406/165 F10	NGA4060165HSOFA	6	165	770	246	192	254	282	26.5	2.10	2800	F-M10
A412/5.5 SR	NGA4120505HSORA	12	5.50	80.0	152	65.5	94.5	98.4	2.50	138	93.0	SR-6.3
A412/8.5 SR	NGA4120805HSORA	12	8.50	80.0	152	98.0	94.5	98.4	3.60	96.0	150	SR-6.3
A412/12 SR	NGA412012HSORA	12	12.0	100	181	76	152	157	5.60	47.0	260	SR-6.3
A412/20 G5	NGA4120020HS0BA	12	20.0	200	167	176	126	126	9.00	25.0	460	G-M5
A412/32 G6	NGA4120032HS0BA	12	32.0	400	210	175	175	175	13.6	15.0	704	G-M6
A412/32 F10	NGA4120032HSOFA	12	32.0	400	210	175	175	181	14.1	15.0	704	F-M10
A412/50 A	NGA4120050HSOCA	12	50.0	440	278	175	190	190	18.5	10.0	1220	A-Terminal
A412/50 F10	NGA4120050HSOFA	12	50.0	440	278	175	190	196	19.0	10.0	1220	F-M10
A412/50 G6	NGA4120050HS0BA	12	50.0	440	278	175	190	190	18.5	10.0	1220	G-M6
A412/65 F10	NGA4120065HSOFA	12	65.0	440	353	175	190	196	23.5	9.90	1414	F-M10
A412/65 G6	NGA4120065HS0BA	12	65.0	440	353	175	190	230	33.0	8.60	1472	F-M10
A412/90 A	NGA4120090HSOCA	12	90.0	770	284	267	208	230	33.0	7.00	1733	A-Terminal
A412/90 F10	NGA4120090HSOFA	12	90.0	770	284	267	208	237	33.5	7.00	1733	F-M10
A412/100 A	NGA4120100HSOCA	12	100	770	513	189	195	223	36.5	6.90	1777	F-M10
A412/100 F10	NGA4120100HSOFA	12	100	770	513	189	195	223	37.0	6.90	1777	F-M10
A412/120 A	NGA4120120HSOCA	12	120	770	513	223	195	223	45.5	5.70	2116	A-Terminal
A412/120 F10	NGA4120120HSOFA	12	120	770	513	223	195	223	46.0	5.70	2116	F-M10
A412/180 A	NGA4120180HSOCA	12	180	770	518	274	216	238	64.0	3.80	3227	A-Terminal
A412/180 F10	NGA4120180HSOFA	12	180	770	518	274	216	244	64.5	3.80	3227	F-M10

Max. load with suitable matching contacts. A412/65 F10 with central discharging. \*12 for F10 terminals plus max. 24 mm for connector/cover.


### Container, approval, terminal and torque

- > Container: - 5.5 - 12 Ah = ABS
- 20 - 180 Ah = Polypropylene (PP)
- > Approval: - Underwriters Laboratories (UL), USA
- DIN/Gost/TUV, Russia




**Sonnenschein A400**  
Drawings


**A406/165 A**  
(A406/165 F10)\*




**A412/5.5 SR**




**A412/8.5 SR**




**A412/12 SR**




**A412/20 G5**




**A412/32 F10**  
(A412/32 G6)\*



**A412/50 A**  
(A412/50 G6,  
A412/50 F10)\*




**A412/65 F10**  
(A412/65 G6)\*




**Sonnenschein A400**  
Drawings


**A412/85 F10**




**A412/90 A**  
(A412/90 F10)\*




**A412/100 A**  
(A412/100 F10)\*



**A412/120 A**  
(A412/120 F10)\*



**A412/180 A**  
(A412/180 F10)\*



Not to scale  
\*Dimensions are also valid for other terminals.



**Sonnenschein A400**  
Constant current discharge

1.70 Vpc – Discharge in A at 20 °C

Type	Full power	5 min	10 min	15 min	20 min	30 min	45 min	1 h	1.5 h	2 h	3 h	4 h	5 h	6 h	8 h	10 h
A406/16SA	NGA4050165HSOCA	332	273	233	198	152	119	93.9	58.0	43.9	34.6	28.7	24.1	19.1	16.6	
A412/5SR	NGA4120505HSORA	14.2	10.9	8.8	7.17	5.48	4.26	3.35	2.18	1.58	1.23	1.02	0.70	0.50	0.40	
A412/5SR	NGA4120505HSORA	21.0	15.0	12.0	10.0	7.63	5.92	4.68	3.00	2.16	1.74	1.46	1.00	0.80	0.60	
A412/2SR	NGA4120012HSORA	20.0	21.0	18.0	15.0	10.0	8.00	6.77	3.99	2.91	2.33	1.96	1.40	1.20	2.00	
A412/2SR	NGA4120012HSORA	51.0	37.9	29.0	24.0	19.0	15.0	12.0	7.00	5.00	3.96	3.30	2.00	2.00	2.00	
A412/2SR	NGA4120012HSORA	84.0	61.0	50.0	42.0	32.0	25.0	20.0	12.0	8.50	7.00	5.80	3.90	3.70	3.70	
A412/5SR	NGA4120050HSOCA	122	94.0	77.0	64.0	49.0	39.0	31.0	18.9	13.5	10.7	8.92	6.00	5.00	5.00	
A412/5SR	NGA4120050HSOCA	148	111	89.0	73.0	57.0	43.0	41.0	24.0	17.2	13.7	11.4	7.70	6.50	6.50	
A412/5SR	NGA4120050HSOCA	206	164	137	113	87.0	66.0	53.0	33.0	24.3	18.9	16.2	11.0	9.00	9.00	
A412/10SA	NGA4120100HSOCA	213	171	141	117	89.0	67.0	53.0	34.0	25.1	19.3	17.0	11.4	10.0	10.0	
A412/12SA	NGA4120120HSOCA	250	200	160	136	109	90.0	70.0	40.0	29.3	23.3	19.5	13.2	12.0	12.0	
A412/18SA	NGA4120180HSOCA	336	287	234	193	156	120	95.0	64.0	45.9	36.3	30.3	20.2	18.0	18.0	

1.65 Vpc – Discharge in A at 20 °C

Type	Full power	5 min	10 min	15 min	20 min	30 min	45 min	1 h	1.5 h	2 h	3 h	4 h	5 h	6 h	8 h	10 h
A406/16SA	NGA4050165HSOCA	369	301	248	210	157	121	95.0	59.0	43.9	34.6	28.7	24.1	19.1	16.6	
A412/5SR	NGA4120505HSORA	15.5	10.8	8.71	7.33	5.57	4.34	3.40	2.19	1.56	1.23	1.00	0.70	0.50	0.40	
A412/5SR	NGA4120505HSORA	23.0	16.0	13.0	10.0	7.70	5.98	4.73	3.01	2.19	1.74	1.55	1.00	0.80	0.60	
A412/2SR	NGA4120012HSORA	30.0	22.0	17.0	14.0	11.0	9.00	6.80	4.00	2.92	2.34	2.00	1.40	1.20	2.00	
A412/2SR	NGA4120012HSORA	56.0	40.0	31.0	25.0	19.0	15.0	12.0	7.00	5.01	3.97	3.30	2.00	2.00	2.00	
A412/2SR	NGA4120012HSORA	94.0	65.0	52.0	43.0	33.0	25.0	20.0	12.0	8.50	7.01	5.80	3.90	3.70	3.70	
A412/5SA	NGA4120050HSOCA	133	99.0	79.0	66.0	50.0	39.0	31.0	19.0	13.6	10.7	8.90	6.00	5.00	5.00	
A412/5SA	NGA4120050HSOCA	161	114	91.0	75.0	57.0	42.0	24.0	17.3	13.7	11.5	7.70	6.50	6.50	6.50	
A412/5SA	NGA4120050HSOCA	210	159	134	110	84.0	65.0	52.0	32.0	22.8	17.9	14.9	10.0	8.00	8.00	
A412/10SA	NGA4120100HSOCA	225	172	142	118	88.0	67.0	53.0	33.0	24.4	18.9	16.3	11.0	9.00	9.00	
A412/12SA	NGA4120120HSOCA	232	178	146	120	90.0	68.0	54.0	34.0	25.3	19.5	17.0	11.4	10.0	10.0	
A412/18SA	NGA4120180HSOCA	311	217	169	142	111	91.0	71.0	41.0	29.4	23.4	19.6	13.2	12.0	12.0	
A412/18SA	NGA4120180HSOCA	399	305	250	212	159	122	98.0	63.9	48.0	36.4	30.4	20.2	18.0	18.0	

1.60 Vpc – Discharge in A at 20 °C

Type	Full power	5 min	10 min	15 min	20 min	30 min	45 min	1 h	1.5 h	2 h	3 h	4 h	5 h	6 h	8 h	10 h
A406/16SA	NGA4060165HSOCA	472	318	256	215	160	122	96.0	59.0	43.0	34.6	28.7	24.1	19.1	16.6	
A412/5SR	NGA4120505HSORA	16.1	10.9	8.88	7.45	5.64	4.37	3.42	2.19	1.56	1.23	1.00	0.70	0.50	0.40	
A412/5SR	NGA4120505HSORA	24.0	16.0	13.0	10.0	7.79	6.03	4.76	3.02	2.19	1.74	1.50	1.00	0.80	0.60	
A412/2SR	NGA4120012HSORA	31.0	23.0	17.0	14.0	11.0	9.00	6.82	4.01	2.92	2.34	2.00	1.40	1.20	2.00	
A412/2SR	NGA4120012HSORA	56.0	42.0	31.0	26.0	19.0	15.0	12.0	7.00	5.02	3.97	3.30	2.00	2.00	2.00	
A412/2SR	NGA4120012HSORA	101	68.0	54.0	44.0	33.0	25.0	20.0	12.0	8.91	7.01	5.80	3.90	3.70	3.70	
A412/5SA	NGA4120050HSOCA	144	101	81.0	67.0	51.0	40.0	31.0	19.5	13.6	10.7	8.90	6.00	5.00	5.00	
A412/5SA	NGA4120050HSOCA	170	116	92.0	76.0	58.0	48.0	23.0	19.3	13.7	11.5	7.70	6.50	6.50	6.50	
A412/5SA	NGA4120050HSOCA	229	166	137	113	85.0	66.0	52.0	32.0	22.8	17.9	14.9	10.0	8.00	8.00	
A412/10SA	NGA4120100HSOCA	245	177	145	116	89.0	68.0	54.0	34.0	24.5	18.0	16.3	11.0	9.00	9.00	
A412/12SA	NGA4120120HSOCA	253	183	149	121	91.0	69.0	54.0	34.0	25.4	19.5	17.0	11.4	10.0	10.0	
A412/18SA	NGA4120180HSOCA	333	228	175	146	112	91.0	73.0	41.0	29.4	23.4	19.6	13.2	12.0	12.0	
A412/18SA	NGA4120180HSOCA	439	322	258	217	162	123	98.0	64.0	48.0	36.4	30.4	20.2	18.0	18.0	

Discharge data are also valid for other terminals.

**Sonnenschein A400**  
Constant current discharge

1.85 Vpc – Discharge in A at 20 °C

Type	Full power	5 min	10 min	15 min	20 min	30 min	45 min	1 h	1.5 h	2 h	3 h	4 h	5 h	6 h	8 h	10 h
A406/16SA	NGA4060165HSOCA	198	163	143	131	115	98.0	82.0	53.0	41.0	32.4	27.0	18.1	15.9	15.9	
A412/5SR	NGA4120505HSORA	9.94	8.34	6.97	5.96	4.85	3.76	3.00	2.00	1.44	1.14	0.96	0.64	0.53	0.50	
A412/5SR	NGA4120505HSORA	15.0	12.0	10.0	8.00	5.90	4.30	2.93	2.07	1.66	1.39	0.96	0.82	0.60	0.60	
A412/2SR	NGA4120012HSORA	18.0	15.0	12.0	11.0	8.00	7.00	5.50	3.34	2.50	2.04	1.74	1.24	1.12	1.20	
A412/2SR	NGA4120012HSORA	33.0	25.0	22.0	20.0	17.0	14.0	11.0	6.00	4.71	3.76	3.16	2.13	1.85	1.85	
A412/2SR	NGA4120012HSORA	51.0	37.0	29.0	24.0	19.0	15.0	12.0	7.00	5.00	3.96	3.30	2.00	2.00	2.00	
A412/5SA	NGA4120050HSOCA	81.0	63.0	57.0	51.0	42.0	34.0	28.0	18.0	12.8	10.1	8.51	5.71	4.80	4.80	
A412/5SA	NGA4120050HSOCA	102	77.0	63.0	56.0	48.0	42.0	36.0	22.0	15.9	12.8	10.8	7.31	6.20	6.20	
A412/5SA	NGA4120050HSOCA	121	103	89.0	86.0	71.0	55.0	45.0	29.0	21.3	16.9	14.1	9.60	8.20	8.20	
A412/10SA	NGA4120100HSOCA	106	117	100	89.0	77.0	65.0	55.0	46.0	30.0	22.8	17.6	14.8	10.4	8.90	
A412/10SA	NGA4120100HSOCA	144	124	105	92.0	72.0	56.0	46.0	31.0	23.5	17.9	15.2	10.7	9.50	9.50	
A412/12SA	NGA4120120HSOCA	175	138	120	106	95.0	78.0	61.0	37.0	27.5	22.2	16.9	12.9	11.3	11.3	
A412/18SA	NGA4120180HSOCA	240	193	170	155	130	103	84.0	59.0	42.6	34.0	26.6	19.1	16.5	16.5	

1.80 Vpc – Discharge in A at 20 °C

Type	Full power	5 min	10 min	15 min	20 min	30 min	45 min	1 h	1.5 h	2 h	3 h	4 h	5 h	6 h	8 h	10 h
A406/16SA	NGA4060165HSOCA	213	211	180	158	132	109	88.0	56.0	43.0	33.9	28.2	18.8	16.5	16.5	
A412/5SR	NGA4120505HSORA	11.2	9.20	7.77	6.54	5.12	4.03	3.18	2.09	1.50	1.19	0.99	0.67	0.50	0.50	
A412/5SR	NGA4120505HSORA	17.0	14.0	11.0	9.00	7.38	5.89	4.51	2.93	2.13	1.70	1.43	0.99	0.80	0.80	
A412/2SR	NGA4120012HSORA	21.0	18.0	14.0	12.0	10.0	8.00	6.20	3.72	2.75	2.22	1.88	1.32	1.20	1.20	
A412/2SR	NGA4120012HSORA	36.0	27.0	23.0	21.0	18.0	15.0	12.0	7.00	4.89	3.88	3.25	2.19	2.00	2.00	
A412/2SR	NGA4120012HSORA	63.0	51.0	42.0	38.0	30.0	23.0	18.0	12.0	8.60	6.00	5.20	3.90	3.20	3.20	
A412/5SA	NGA4120050HSOCA	97.0	81.0	69.0	57.0	46.0	37.0	29.0	19.0	13.3	10.5	8.78	5.89	5.00	5.00	
A412/5SA	NGA4120050HSOCA	120	95.0	78.0	64.0	52.0	45.0	39.0	23.0	16.7	13.3	11.2	7.58	6.50	6.50	
A412/5SA	NGA4120050HSOCA	147	125	105	91.0	75.0	60.0	49.0	31.0	22.3	17.5	14.6	9.95	8.50	8.50	
A412/10SA	NGA4120100HSOCA	165	142	117	100	79.0	61.0	50.0	32.0	23.4	18.3	15.4	10.8	9.00	9.00	
A412/10SA	NGA4120100HSOCA	176	150	125	104	81.0	62.0	50.0	32.0	24.1	18.7	15.8	11.2	9.00	9.00	
A412/12SA	NGA4120120HSOCA	201	155	133	119	102	85.0	67.0	39.0	28.7	23.0	19.4	13.1	12.0	12.0	
A412/18SA	NGA4120180HSOCA	290	235	194	171	144	112	90.0	62.0	44.8	35.5	26.7	19.0	18.0	18.0	

1.75 Vpc – Discharge in A at 20 °C

Type	Full power	5 min	10 min	15 min	20 min	30 min	45 min	1 h	1.5 h	2 h	3 h	4 h	5 h	6 h	8 h	10 h
A406/16SA	NGA4060165HSOCA	290	246	210	180	143	115	92.0	58.0	43.7	34.4	28.5	19.1	16.6	16.6	
A412/5SR	NGA4120505HSORA	12.9	9.78	8.22	6.92	5.34	4.17	3.29	2.15	1.54	1.22	1.01	0.68	0.50	0.50	
A412/5SR	NGA4120505HSORA	18.0	15.0	12.0	10.0	7.54	5.82	4.62	2.98	2.16	1.73	1.45	1.00			

**Sonnenschein A400**  
Constant power discharge

1.70 Vpc – Discharge in W/block at 20 °C

Type	Full Charge	2 min	5 min	10 min	15 min	20 min	30 min	45 min	1 h	2 h	3 h		
A406/16SA	NGA4120016SHSOCA	1993	1913	1778	1636	1455	1230	1036	814	637	521	339	247
A412/5SSR	NGA412005SHSOBA	219	193	162	143	119	96.6	80.7	64.2	49.8	40.3	24.0	18.0
A412/8SSR	NGA412008SHSOBA	306	282	246	212	177	143	119	95.2	71.5	58.3	34.0	25.0
A412/12SSR	NGA412012SHSOBA	394	365	323	285	247	203	170	134	101	82.4	45.0	33.0
A412/20G5	NGA412020SHSOBA	741	657	555	494	423	320	277	216	166	135	78.0	56.0
A412/50A	NGA412050SHSOCA	1734	1514	1406	1234	1079	956	848	688	519	419	219	153
A412/65G6	NGA412065SHSOBA	2191	2008	1762	1570	1322	1099	916	722	541	436	270	194
A412/85F10	NGA412085SHSOFB	2076	1847	1637	1437	1244	1064	882	678	519	419	219	153
A412/100A	NGA4120100SHSOCA	2533	2388	2176	1950	1668	1367	1171	945	727	597	375	273
A412/120A	NGA4120120SHSOCA	2792	2604	2316	2090	1749	1413	1215	986	751	619	385	282
A412/150A	NGA4120150SHSOCA	3621	3501	3268	2957	2583	1820	1441	1190	1008	840	460	330
A412/180A	NGA4120180SHSOCA	4990	4742	4394	3929	3417	2975	2502	1944	1455	1184	697	517

1.65 Vpc – Discharge in W/block at 20 °C

Type	Full Charge	2 min	5 min	10 min	15 min	20 min	30 min	45 min	1 h	2 h	3 h		
A406/16SA	NGA4120016SHSOCA	2162	2035	1879	1724	1526	1278	1087	827	642	525	341	243
A412/5SSR	NGA412005SHSOBA	235	200	169	149	122	98.8	82.3	64.7	50.5	40.7	24.0	18.0
A412/8SSR	NGA412008SHSOBA	331	305	258	222	183	146	121	96.1	72.0	58.7	34.0	25.0
A412/12SSR	NGA412012SHSOBA	436	399	348	304	255	209	174	135	101	82.9	45.0	33.0
A412/20G5	NGA412020SHSOBA	799	700	543	511	438	338	282	218	167	136	78.0	56.0
A412/50A	NGA412050SHSOCA	1861	1683	1563	1363	1199	1031	861	681	511	411	211	151
A412/65G6	NGA412065SHSOBA	2191	1947	1747	1543	1308	1120	941	721	541	436	271	195
A412/85F10	NGA412085SHSOFB	2255	2159	1963	1770	1563	1325	1116	876	635	533	364	257
A412/100A	NGA4120100SHSOCA	2823	2697	2304	2067	1743	1414	1200	964	732	601	376	274
A412/120A	NGA4120120SHSOCA	3108	2827	2475	2216	1831	1459	1241	993	755	622	387	283
A412/150A	NGA4120150SHSOCA	4111	3798	3170	2842	2183	1756	1474	1205	1012	844	460	331
A412/180A	NGA4120180SHSOCA	5419	5099	4624	4162	3583	3073	2595	1974	1475	1188	700	518

1.60 Vpc – Discharge in W/block at 20 °C

Type	Full Charge	2 min	5 min	10 min	15 min	20 min	30 min	45 min	1 h	2 h	3 h		
A406/16SA	NGA4120016SHSOCA	2351	2202	1947	1820	1588	1307	1085	835	646	527	342	249
A412/5SSR	NGA412005SHSOBA	248	220	175	153	125	100	83.3	65.0	51.0	41.1	24.0	18.0
A412/8SSR	NGA412008SHSOBA	354	321	267	228	186	147	122	96.7	72.3	58.9	34.0	25.0
A412/12SSR	NGA412012SHSOBA	474	423	358	317	262	212	176	136	102	83.1	45.0	33.0
A412/20G5	NGA412020SHSOBA	874	760	610	521	446	343	285	219	167	136	80.0	56.0
A412/50A	NGA412050SHSOCA	1745	1543	1382	1191	1000	871	681	528	423	218	154	
A412/65G6	NGA412065SHSOBA	2003	1861	1617	1417	1199	1000	871	681	528	423	218	154
A412/85F10	NGA412085SHSOFB	2401	2200	2050	1867	1608	1357	1106	884	689	561	365	257
A412/100A	NGA4120100SHSOCA	3045	2754	2352	2156	1792	1444	1217	960	735	603	377	275
A412/120A	NGA4120120SHSOCA	4296	3842	3320	2779	2260	1791	1494	1210	1014	844	460	332
A412/150A	NGA4120150SHSOCA	5625	5305	4822	4380	3701	3130	2599	1993	1484	1203	702	519

Discharge data are also valid for other terminals.

**Sonnenschein A400**  
Constant power discharge

1.85 Vpc – Discharge in W/block at 20 °C

Type	Full Charge	2 min	5 min	10 min	15 min	20 min	30 min	45 min	1 h	2 h	3 h		
A406/16SA	NGA4120016SHSOCA	1310	1262	1171	1098	1005	875	797	689	543	458	293	222
A412/5SSR	NGA412005SHSOBA	153	140	120	106	95.0	79.5	63.7	53.4	44.3	36.4	22.0	18.0
A412/8SSR	NGA412008SHSOBA	216	200	176	159	141	117	101	84.4	64.8	53.7	31.0	22.0
A412/12SSR	NGA412012SHSOBA	251	239	219	203	184	156	140	114	89.4	74.0	39.0	29.0
A412/20G5	NGA412020SHSOBA	437	414	378	348	302	257	229	195	151	125	71.0	51.0
A412/50A	NGA412050SHSOCA	1169	1074	1002	949	878	785	699	590	458	375	193	139
A412/65G6	NGA412065SHSOBA	1440	1341	1221	1137	1025	867	759	635	481	395	239	175
A412/85F10	NGA412085SHSOFB	1311	1275	1230	1158	1071	952	865	761	591	494	324	233
A412/100A	NGA4120100SHSOCA	1645	1619	1493	1374	1243	1080	947	827	648	542	332	246
A412/120A	NGA4120120SHSOCA	1873	1792	1625	1482	1329	1144	1047	860	674	567	335	252
A412/150A	NGA4120150SHSOCA	2417	2253	1982	1773	1574	1384	1272	1109	914	745	410	300
A412/180A	NGA4120180SHSOCA	3474	3323	3112	2959	2679	2284	2010	1562	1214	1015	632	467

1.80 Vpc – Discharge in W/block at 20 °C

Type	Full Charge	2 min	5 min	10 min	15 min	20 min	30 min	45 min	1 h	2 h	3 h		
A406/16SA	NGA4120016SHSOCA	1622	1546	1414	1315	1184	1020	900	788	595	494	318	241
A412/5SSR	NGA412005SHSOBA	174	160	140	122	106	87.8	74.4	62.1	47.1	38.4	21.0	17.0
A412/8SSR	NGA412008SHSOBA	246	232	203	180	156	129	110	90.4	66.5	56.3	33.0	24.0
A412/12SSR	NGA412012SHSOBA	314	291	258	235	208	177	153	125	96.8	79.2	42.0	31.0
A412/20G5	NGA412020SHSOBA	565	520	477	421	358	291	251	208	159	131	71.0	55.0
A412/50A	NGA412050SHSOCA	1385	1269	1134	1040	969	862	769	625	482	400	210	151
A412/65G6	NGA412065SHSOBA	1701	1601	1429	1295	1158	976	854	690	516	420	260	190
A412/85F10	NGA412085SHSOFB	1667	1572	1463	1375	1276	1082	960	803	637	526	352	253
A412/100A	NGA4120100SHSOCA	1839	1706	1554	1394	1184	1061	880	691	573	360	267	
A412/120A	NGA4120120SHSOCA	2076	1906	1728	1644	1454	1235	1112	931	719	597	364	274
A412/150A	NGA4120150SHSOCA	2958	2667	2286	2026	1769	1496	1348	1146	911	802	446	336
A412/180A	NGA4120180SHSOCA	4109	3898	3559	3136	2694	2241	1756	1319	1104	867	507	357

1.75 Vpc – Discharge in W/block at 20 °C

Type	Full Charge	2 min	5 min	10 min	15 min	20 min	30 min	45 min	1 h	2 h	3 h		
A406/16SA	NGA4120016SHSOCA	1850	1780	1628	1493	1356	1146	940	796	622	512	337	247
A412/5SSR	NGA412005SHSOBA	196	178	155	134	114	93.1	78.3	63.4	48.8	39.6	21.0	17.0
A412/8SSR	NGA412008SHSOBA	278	258	226	198	171	138	116	93.6	70.5	57.6	34.0	25.0
A412/12SSR	NGA412012SHSOBA	354	331	295	262	233	192	163	131	98.3	81.0	45.0	33.0
A412/20G5	NGA412020SHSOBA	658	595	518	467	397	315	267	213	164	134	77.0	56.0
A412/50A	NGA412050SHSOCA	1598	1481	1383	1283	1146	1027	925	810	613	513	215	152
A412/65G6	NGA412065SHSOBA	1968	1830	1640	1447	1267	1054	846	714	533	431	270	193
A412/85F10	NGA412085SHSOFB	1908	1826	1674	1532	1421	1220	1033	830	664	544	360	264
A412/100A	NGA4120100SHSOCA	2201	2184	1984	1796	1564	1298	1128	927	716	590	375	272
A412/120A	NGA4120120SHSOCA	2498	2354	2139	1928	1635	1348	1175	972	742	612	343	260
A412/150A	NGA4120150SHSOCA	3453	3084	2563	2262	1940	1609	1387	1178	967	829	460	329
A412/180A	NGA4120180SHSOCA	4555	4307	3950	3659	3310	2821	2399	1878	1413	1156	695	515


Discharge data are also valid for other terminals.

**Battery Service – Energy Solutions**  
Keeping your business on the move

**GNB® is the Expert**

Who could do this job better than the professionals of a company with more than 100 years of experience in battery development, production and application?

Leave the responsibility for the maintenance of your batteries and chargers to the professionals: a GNB service contract provides you with exceptional economic advantages through time savings, cost savings and safety!



**Installation of Batteries and Systems for Network Power**


- > Development of complete turnkey solutions from the design concept to installation and commissioning.
- > Installation according to legal and safety regulations including CE certification by approved installation technicians.
- > Training and certification of external installation technicians according to CE regulations.

- ✦ **Inspection Contract**
- ✦ **Maintenance Contract**
- ✦ **Lifetime Warranty Contract**
- ✦ **Full Service Contract**

**„GNB Service – individualized, professional and all over Europe!“**



АЛАНГИНА С ОНДРО  
ДЯРНО С ОНДРО



Exide Technologies, with operations in more than 80 countries, is one of the world's largest producers and recyclers of lead-acid batteries. Exide Technologies provides a comprehensive and customized range of stored electrical energy solutions. Based on over 100 years of experience in the development of innovative technologies, Exide Technologies is an esteemed partner of OEMs and serves the spare parts market for industrial and transportation applications.

**GNB® INDUSTRIAL POWER** – A division of Exide Technologies – offers an extensive range of storage products and services, including solutions for telecommunication systems, railway applications, mining, photovoltaic (solar energy), uninterrupted power supply (UPS), electrical power generation and distribution, fork lifts and electric vehicles.

Exide Technologies takes pride in its commitment to a better environment. Its Total Battery Management programme, (an integrated approach to manufacturing, distributing and recycling of lead-acid batteries), has been developed to ensure a safe and responsible life cycle for all of its products.



**„The next Level of Energy Management“**

**GNB® INDUSTRIAL POWER** provides long lasting energy concepts that combine efficiency with flexibility.



**I. ОСНОВНИ ТЕХНИЧЕСКИ ХАРАКТЕРИСТИКИ**  
**НА ИНДУСТРИАЛНА АКУМУЛАТОРНА БАТЕРИЯ С ГЕЛ ЕЛЕКТРОЛИТ 220V/100Ah- СЕРИЯ DRYFIT A412/100A**

№	СПЕЦИФИКАЦИЯ	ТЕХНИЧЕСКИ ХАРАКТЕРИСТИКИ
1.	Производител:	Sonnenschein GmbH- Германия, една от фирмите в EXIDE Technologies
2.	Технология на производство:	dryfit GEL технология / VRLA (оловни- киселини с вентилно регулиране), газ- рекомбинационна система с клапанно регулиране за 99% рекомбинация
3.	Електролит:	свързан в гел структура
4.	Конструктивно изпълнение:	херметизирани 12V-блокове, по 6 клетки, предпазни работни вентилни, решетъчни гравитационно отляти плочи от безантимонови Pb-Ca-Sn сплави
5.	Клас по EUROBAT:	Long Life- над 12 г. срок на експлоатация при 20°C (80% капацитет в края)
6.	Степен на обслужване по DIN:	Напълно необслужваема акумулаторна батерия през целия експлоатационен срок, включително междуелементните кабелни конектори и аксесоари
7.	Предназначение:	Осигуряват поддържането на напрежение $\geq 1,80V/кл.$ към DC консуматорите при номин. товар $\geq 10$ часа, аварийен товар $\geq 5$ часа /16A за 5 часа; 32A за 2 часа
8.	Номинално напрежение на батерията:	220V
9.	Тип на батерията:	Sonnenschein A412/100 A
10.	Номинален капацитет (C <sub>10</sub> )	100Ah
11.	Номинално напрежение на блок:	12V
12.	Брой блокове в 220V- батерия:	18 блока (108 клетки)
13.	Вътрешно съпротивление:	6,9 mΩ / блок (съгл. IEC 896-2)
14.	Ток на късо съединение:	1800 (измерен съгл. IEC 896-2)
15.	2-часов разряден ток до 1,80V/клетка:	$\geq 32A$
16.	Габаритни размери / тегло на блок:	L513 × W189 × H195 (HВ223) мм / 39 кг

Стр. 1/3

17.	Полусни изводи:	A тип (конусни) с трайна маркировка на поляритет (+/-) и номер на блока
18.	Кабелни мостове и аксесоари за монтаж :	Електрически изолирани, с подходящо сечение за провеждане на I <sub>nom</sub> и I <sub>k.c</sub> (10s), необслужваеми през целия експл. срок, защитни капачки
19.	Зарядни характеристики:	IU по DIN 41773
20.	Подзарядно напрежение при 20°C:	2,27V/клетка в стенд-бай режим (13,62V/блок)
21.	Допустимо отклонение на U <sub>load</sub> :	+0,50V/ -0,25V на блок
22.	Вътрешна рекомбинация на H <sub>2</sub> и O <sub>2</sub> до H <sub>2</sub> O	Газ-рекомбинационна клапанно- регулирана система за 99% рекомбинация
23.	Газоотделяне (съгл. IEC 896-2, DIN 43539):	2ml/ клетка/ Ah за 30 дни (дължи се на почти 100% вътр. рекомбинация)
24.	Защита срещу дълбок разряд:	Съгл. DIN 43 539 T5
25.	Устойчивост на дълбок разряд:	До 0V в продължение на 4 седмици, без опасност от необратими увреждания
26.	Работен температурен диапазон:	Нормален: от -15 до +40 °C / Екстремален: от -30 до +50 °C
27.	Степен на саморазряд при 20 °C:	Изключително нисък (50% остатъчен капацитет след 24 мес. Съхранение)
28.	Корпус на акумулаторите:	Полипропилен (PP), негорим съгл. UL 94 VO
29.	Степен на рециклируемост:	100% рециклируеми
30.	Сертификат за качество:	ISO 9001
31.	Сертификат за екологично производство:	ISO 14001
32.	Европейски норми и стандарти за АБ:	EN 50272-2, IEC 896-2 DIN VDE 0510- ч. 2, IEC 60364-4-41, DIN 43539-1 T5
33.	Основни приложения:	Електрически централи, Подстанции, Телекомуникации, Аварийно осветление, UPS, Алармени и Пожарозвестителни системи и мн. др.
34.	Обем на доставката:	2 компл. АБ × 220V/100Ah (36 бр. акумулатори A412/100A); 2 компл. кабелни конектори и аксесоари за монтаж; сертификати за съответствие; сертификати за качество; 2 комплекта техническа документация- на бълг. и англ. език;
35.	Изисквания към акумулаторното помещение:	Няма специални изисквания към акумулаторното по отношение на: - пожаро и взривообезопасност; - киселинноустойчиви поди и стени; - принудителна вентилация (естествената е достатъчна). Препоръчителна околна температура- около 20°C±5°C (високите температури понижават експлоатационния срок, а ниските- капацитета на батерията).

**СТЕЛАЖ ЗА АКУМУЛАТОРНА БАТЕРИЯ 220V/100Ah**

СТЕЛАЖИТЕ са МЕТАЛНИ, СГЛОБЯЕМИ- производство на ALPNA GmbH – Италия.

- ПОКРИТИЕ:
- полнетиленово PE, нанесено чрез синтероване;
  - min. 400µm дебелина на покритието;
  - киселинно и алкално устойчиво;
  - висока механична здравина;
  - повърхностно съпротивление  $10^{14}$  Ohm;
  - специфично обемно съпротивление  $10^{13}$  Ohm.cm;
  - издържа на електрически пробив от 600kV/cm;
  - постоянна работна температура от  $-40^{\circ}\text{C}/+80^{\circ}\text{C}$ ;
  - кратковременна работна температура до  $+120^{\circ}\text{C}$ ;
- МАТЕРИАЛ: - профилирана стомана;
- ЦВЯТ: - черен
- КОНФИГУРАЦИЯ: - двутажен, едноредов, сглобяем стелаж (възможни са и други конфигурации според размерите на акумулаторното помещение)
- СЕРТИФИЦИРАНИ ПО: - DIN и ISO 9001
- ТИП НА СТЕЛАЖА: - 2E-PGU 1-18 H (за 18 блока- тип A412/100,0 A) / L 1800 x W 715 x H 632 (HB 855) mm

22.04.2015 год.  
гр. София

Изготвил:  
Иван Иванов  
/P-л Проектн/



# CERTIFICATE



## ISO 9001:2008

DEKRA Certification GmbH hereby certifies that the company

### EXIDE Technologies GmbH

**Scope of certification:**

Development, production and distribution of lead accumulators and batteries with system equipment

**Certified location:**

D-63654 Büdingen, Im Thiergarten  
D-37431 Bad Lauterberg, Odertal 35

has established and maintains a quality management system according to the above mentioned standard. The conformity was adduced with audit report no. A12081368.

This certificate is valid from 2012-12-05 to 2015-10-27

Certificate registration no.: 51109714/1  
Duplicate



DEKRA Certification GmbH  
Stuttgart, 2012-12-05



DAkkS

Deutsche  
Akkreditierungsstelle  
D-ZM-16029-01-01

Lack of fulfillment on conditions as set out in the Certification Agreement may render this certificate



# CERTIFICATE



## ISO 14001:2004

DEKRA Certification GmbH hereby certifies that the company  
**EXIDE Technologies GmbH**

**Scope of certification:**  
Development, production and distribution of lead accumulators  
and batteries with system equipment

**Certified location:**  
D-63654 Büdingen, Im Thiergarten  
D-37431 Bad Lauterberg, Odertal 35

has established and maintains an environmental management system according to the above  
mentioned standard. The conformity was adduced with audit report no. A12081368.

This certificate is valid from 2012-12-18 to 2015-12-17

Certificate registration no.: 170912103/1  
Duplicate

*Ueilag*



DEKRA Certification GmbH  
Stuttgart, 2012-12-05

Lack of fulfillment on conditions as set out in the Certification Agreement may render this certificate invalid



ВАРНО С  
РИГИНАЛА

*[Handwritten signature]*

# Contents

Foreword ..... 4

1. Introduction ..... 4

2. Main product features ..... 4

3. Functional description  
Switches and main parts ..... 5

4. Basic designs ..... 6

5. Operating mechanisms ..... 6

6. Earthing switch ..... 6

7. Fuse bases and recommended current limiting fuses ..... 7

8. Ordering codes ..... 8

9. Technical Specifications ..... 9

Accessories

10. Additional equipment for NAL/NALF switch disconnectors ..... 11


11. Example of switch arrangement ..... 13

12. Ordering information ..... 14

13. Operating mechanisms and optional accessories ..... 21


14. Motor drives ..... 22

15. Dimensional drawings ..... 24



Indoor switch disconnector type NAL with earthing switch type E

2 Switch disconnector type NAL



Medium voltage products

## Air insulated switch disconnectors type NAL, NALF, VersaRupter





ПЛАННА С ОМОНА

Power and productivity  
for a better world™

ABB

# Foreword

NAL switch disconnector production line



Switch disconnector type NAL 3

NAL-type switch disconnectors are based on a modular principle, which gives it a wide range of functionality. With a unique design that extinguishes electric arcs and enables high switching capacity, they represent an attractive solution as a key breaking element for applications in enclosed switchgear and transformer compact substations. In combination with type CEF current limiting fuses, NALF fuse switch disconnectors ensure control over the full range of overload and short-circuit currents.

The main areas of application of NAL/NALF switch disconnectors are as:

- Line switch disconnectors in medium-voltage networks,
- Switch disconnectors with fuses for the switching and protection of:
- Distribution transformers
- Motors

NAL/NALF switch disconnectors are manufactured according to global quality and environmental standards and certified by ISO 9001 and ISO 14001 certificates. In addition, they are 99.64 percent recyclable.

The NAL/NALF brand is well known around the world, and more than 600,000 switches have been produced so far. It has been undergoing continuous development to satisfy users' demands.

## 1. Introduction

The switch disconnector system NAL/NALF is based on a modular principle. The basic unit consists of a frame with insulators and current carrying parts. Two different types of operating mecha-

nisms, snap action mechanism type K or stored spring energy mechanism type A, can be mounted on the frame. Fuse bases type F, with or without fuse tripping mechanism, and an earthing switch type E/EB, suitable for both direct mounting and free standing components, complete the basic equipment of a switch disconnector. These modules can be easily configured according to customer expectations.

Accessories, such as shunt trip, under-voltage release, auxiliary switches, motor operation and various systems for manual operation can easily be added.

## 2. Main product features

A NAL disconnector (which interrupts load currents up to 1,250 A) and a small fault-current circuit combined with a fuse base (F) and current limiting fuses, (which break large short-circuit currents) create a NALF-type disconnector that provides protection against a majority of fault types in a modern electric network. Both NAL/NALF are designed in accordance with the requirements of the following standards: 60129, 60265, 60694, GOST 1516.3-96, GOST 17717-79, and CSA Standard No. C22.2, No. 193, and IEC 62271-105, all of which consider switches for general use and ensure there is safe switching coordination between a switch disconnector and a current limiting fuse.

Within the scope of the ANSI standard, NAL is known as VersaRupter and it meets the requirements of ANSI No. C37.20.4. The selected styles of NAL/NALF switch disconnector are listed as certified by the Canadian Standards Association (CSA). Some VersaRupter styles are UL listed prior to their release to comply with the relevant safety requirements required in regions of the United States.




Fig. 1 Switchboard with NAL switch disconnector




Fig. 2 Structure of panel with NAL switch disconnector




Fig. 3 NALF 36 KV fuse switch disconnector

# Switches and main parts

### 3. Functional description

To ensure correct operation for all relevant currents, the switch disconnector system NAL/NALF is equipped with a dual arc extinguishing system. As the current is being interrupted, the arc will be exposed to:

- a) A current independent air blast which automatically starts at the contact time during the interrupting process. This is achieved by designing the insulators on the opening side as cylinders with pistons. The pistons are connected to the mechanism in the same way as the moving contacts. The air blast therefore starts simultaneously with the contact movement (autoneumatic air blast).
- b) A current dependent gas blast which occurs when the walls of the arcing nozzles are exposed to the hot arc.

During this process, large volumes of gas are released and the arc is effectively cooled. The concentration of the developed gas therefore most important at high currents. The so-called Hart gas effect is a well balanced utilization of these two effects has resulted in an arc extinguishing system with high reliability for all relevant currents. Because of the autoneumatic air blast it will only be necessary to utilize the Hart gas effect for high currents. This gives an arcing system which can withstand a large number of operations without excessive wear. Consequently the NAL switches comply with the highest electrical performance classes E3 of IEC 60265-1 (for selected normal voltages only). In addition, voltage ratings are tested with a hundred operations under a lead rated current of 630 A, which is a very important feature of the product, distinguishing it from other apparatus of this type on the market.



Fig. 8 NALF




Fig. 4 Interruption




Fig. 5 Switch disconnector in open position




Fig. 6 Closing




Fig. 7 Switch disconnector in closed position




Fig. 9 Mechanism A



Fig. 10 Mechanism K



Fig. 11 Quick earthing switch type E

Fig. 12 Switch disconnector type NAL

### 4. Basic designs

#### NAL

The standard feature consists of chassis, insulators and current carrying parts with the following pole distance:

- 12 kV - pole distance 150 mm, 170 mm and 210 mm
- 17.5 kV - pole distance 170 mm and 210 mm
- 24 kV - pole distance 170 mm\*, 235 mm and 275 mm
- 36 kV - pole distance 360 mm

\* - with insulating barriers

Rated currents are:

- 400, 630 and 1250 A up to 24 kV
- 630/800/1000 A for 36 kV

#### NALF

Is delivered with the same pole distances as the standard feature. Fuse base type F is delivered for installation on both the opening and pivot sides, with or without automatic tripping.

A fuse base with six insulators can also be delivered separately with some form of signal indication when a fuse blows or for installation on the pivot side of the switch.

### 5. Mechanisms

#### Type A with two springs

The opening spring is always charged before the switch can be closed by means of a closing spring. This means the opening spring is always charged in a closed switch, which in turn can be tripped immediately by hand, electrically or by a fuse-link striker system.

#### Type K with one spring

Closing or opening the switch is performed by charging the spring past the dead centre.

A and K mechanisms may cooperate with motor drives.

### 6. Earthing switch

#### Quick earthing switch type E

This type of earthing switch is equipped with a quick spring mechanism. It can be mounted on the pivot side of the switch disconnector or on the fuse base when the latter is on the pivot side of the switch.

#### Quick earthing switch type EB

Designed to be an independent assembly for both sides of the disconnector.

#### Earthing switch type LCES

This type of switch is not equipped with a quick spring mechanism. It can be mounted on the pivot side of the switch disconnector or on the fuse base when the latter is on the pivot side of the switch.

Switch disconnector type NAL 5

Mechanical interlocking between the switch disconnector and earthing switch is installed directly on apparatus' shafts. The left hand shaft extension is required for mechanical interlock installation.




Fig. 12 Quick type earthing switch type E mounted on fuse base

**7. Fuse bases and recommended current limiting fuses**  
**Fuse base type F**  
 Variable with or without automatic tripping of the switch by the fuse-link striker system. The fuse base can be mounted on both sides (i.e. opening side or pivot side of the switch).  
**Recommended current limiting fuses for switch disconnector type NALF and fuse base with fuse tripping system**  
 ABB fuse types CEF and CEF-S are recommended for use with the NALF switch disconnector with fuse tripping system. These fuses are reference fuses as defined in IEC 62271-105. The selection of fuses to protect distribution transformers with appropriate assumptions about the working conditions and manner of selection are shown in the following tables.

Transformer rated voltage (kV)	Transformer rated output (kVA)														Fuse rated voltage (kV)							
	25	50	75	100	125	160	200	250	315	400	500	630	800	1000		1250	1600	2000				
3	16	25	25	40	40	50	63	80	100	125								3, 6/7, 2				
5	10	16	25	25	40	40	50	63	80	100	125								12			
6	16	16	25	25	40	40	50	63	80	100	125								17,5			
10	6	10	16	16	20	20	25	31,5	40	50	63	80	100	125					36			
12	6	10	16	16	20	20	25	31,5	40	50	63	80	100	125					36			
15	6	10	16	16	20	20	25	31,5	40	50	63	80	100	125					36			
20	6	6	10	10	16	16	20	25	31,5	40	50	63	80	100	125					36		
24	6	6	6	10	10	16	16	20	25	31,5	40	50	63	80	100	125					36	
30	6	6	6	6	10	10	16	16	20	25	31,5	40	50	63	80	100	125					36
36	6	6	6	6	10	10	16	16	20	25	31,5	40	50	63	80	100	125					36

Transformer rated voltage (kV)	Transformer rated output (kVA)														Fuse rated voltage (kV)							
	25	50	75	100	125	160	200	250	315	400	500	630	800	1000		1250	1600	2000				
3	16	25	40	50	63	80	100	125								12						
5	10	16	25	40	50	63	80	100	125								12					
6	16	16	25	40	50	63	80	100	125								12					
10	6	10	16	16	20	20	25	31,5	40	50	63	80	100	125					24			
12	6	10	16	16	20	20	25	31,5	40	50	63	80	100	125					24			
15	6	10	16	16	20	20	25	31,5	40	50	63	80	100	125					24			
20	6	6	10	10	16	16	20	25	31,5	40	50	63	80	100	125					24		
24	6	6	6	10	10	16	16	20	25	31,5	40	50	63	80	100	125					24	
30	6	6	6	6	10	10	16	16	20	25	31,5	40	50	63	80	100	125					24
36	6	6	6	6	10	10	16	16	20	25	31,5	40	50	63	80	100	125					24

The table above details the rated current of a particular fuse link for a given line voltage and transformer rating. For different criteria, the fuse selection must be recalculated. The fuse limits of the rated current of fuse are not mandatory for use with NALF/NALF switch disconnector without fuse tripping system. Rated current values of the corresponding fuses for these applications are given in the ABB catalogue table "Fuses".

ABB is a registered trademark of ABB Ltd. © 2000  
 IEC 60076-1, IEC 60076-2, IEC 60076-3, IEC 60076-4, IEC 60076-5, IEC 60076-6, IEC 60076-7, IEC 60076-8, IEC 60076-9, IEC 60076-10, IEC 60076-11, IEC 60076-12, IEC 60076-13, IEC 60076-14, IEC 60076-15, IEC 60076-16, IEC 60076-17, IEC 60076-18, IEC 60076-19, IEC 60076-20, IEC 60076-21, IEC 60076-22, IEC 60076-23, IEC 60076-24, IEC 60076-25, IEC 60076-26, IEC 60076-27, IEC 60076-28, IEC 60076-29, IEC 60076-30, IEC 60076-31, IEC 60076-32, IEC 60076-33, IEC 60076-34, IEC 60076-35, IEC 60076-36, IEC 60076-37, IEC 60076-38, IEC 60076-39, IEC 60076-40, IEC 60076-41, IEC 60076-42, IEC 60076-43, IEC 60076-44, IEC 60076-45, IEC 60076-46, IEC 60076-47, IEC 60076-48, IEC 60076-49, IEC 60076-50, IEC 60076-51, IEC 60076-52, IEC 60076-53, IEC 60076-54, IEC 60076-55, IEC 60076-56, IEC 60076-57, IEC 60076-58, IEC 60076-59, IEC 60076-60, IEC 60076-61, IEC 60076-62, IEC 60076-63, IEC 60076-64, IEC 60076-65, IEC 60076-66, IEC 60076-67, IEC 60076-68, IEC 60076-69, IEC 60076-70, IEC 60076-71, IEC 60076-72, IEC 60076-73, IEC 60076-74, IEC 60076-75, IEC 60076-76, IEC 60076-77, IEC 60076-78, IEC 60076-79, IEC 60076-80, IEC 60076-81, IEC 60076-82, IEC 60076-83, IEC 60076-84, IEC 60076-85, IEC 60076-86, IEC 60076-87, IEC 60076-88, IEC 60076-89, IEC 60076-90, IEC 60076-91, IEC 60076-92, IEC 60076-93, IEC 60076-94, IEC 60076-95, IEC 60076-96, IEC 60076-97, IEC 60076-98, IEC 60076-99, IEC 60076-100.

**8. Types Designation**

NAL	F	12	17	24	36	43	6	8	10	12	12.5	15	17	20	25	30	36	K	A	150	170	210	235	275	360	L	R	E	LCS	

Additional information needed when placing the order:

- 1 - the length of fuse link
- 2 - mounting side - pivot or opening
- 3 - for 36 kV only
- 4 - for 24 kV only
- 5 - for left hand operation shaft extension must be used
- 6 - for 24 kV insulation barriers are used
- 7 - the earthing switch is normally delivered without mechanical interlocking, which must be specified separately. For 36 kV, earthing switch is provided as self-standing only type EB.

General remarks for orders

- Normally, the switch disconnector is delivered with a fuse base for pivot side mounting. A fuse base for opening side mounting must be specified in the order.
- Closing or opening of the switch disconnector must be carried out by an operating coil. The coil must be ordered separately.
- For left-hand operation, a shaft extension must be used. The extension must be ordered separately.
- The earthing switch is normally delivered without mechanical interlocking. There is an additional charge for interlocking.
- The switch disconnector type NALF / NAL can be ordered at the same time, together with ABB current limiting fuse types CEF and CEF-S. Adequate ordering numbers for fuse links are available in the "Fuses" catalogue.

Ordering examples

- NAL 17-12K170LE  
Switch disconnector for 17.5 kV / 1250 A with latched snap action mechanism, pole distance 170 mm. The switch disconnector is left-hand operated and equipped with a quick-make earthing switch.
- NALF 24-6A235R  
Switch disconnector for 24 kV/630 A with stored spring energy mechanism type A, equipped with fuse base on the pivot side, with fuse-tripping device, pole distance 235 mm, right-hand operated.

9. Technical specification  
Switch disconnector type NAL  
The switch disconnector complies with IEC standards 60129, 60254 and 60894 concerning general purpose switches and IEC Standards 420 and 62271-105 regarding correct co-operation between switch disconnector and fuse.

TABLE I. Main data

	Un	12	17.5	24	36					
Rated voltage	Un	12	17.5	24	36					
Rated current	In	400	630	1250	400	630	800	800	800	
Max. rated current	I	400	630	1150	400	630	1150	630	800	1000
Max. rated making capacity	I <sub>mk</sub>	67	67	50	50	50	50	50	50	
Peak withstand current	I <sub>pk</sub>	82	82	82	82	82	82	82	66	66
Short time current 1 sec.	I <sub>st</sub>	31.5	31.5	31.5	31.5	31.5	31.5	31.5	25	25
Short time current 2 sec.	I <sub>st2</sub>	25	25	25	25	25	25	25	25	25
Short time current 3 sec.	I <sub>st3</sub>	20	20	20	16	16	16	16	16	16
Mainly active load breaking capacity <sup>1)</sup>	I	400	630	1250	400	630	1250	630	800	800
(test duty 1 and 2, IEC 60285-1 (IEC 265))										
Rated cable line charging breaking capacity	I	150	150	100 <sup>2)</sup>	100 <sup>2)</sup>	80	80	80	45	45
IEC 60285-1 (IEC 265)										
Mainly inductive breaking capacity cos φ = 0.15	I	16	16	16	16	16	16	16	16 <sup>3)</sup>	16 <sup>3)</sup>
Rated earth fault breaking capacity IEC 60265-1 (IEC 265)	I	150	150	70	70	75	75	75	50	50
Earth fault breaking capacity, fig. 6	I	150	150	70	70	75	75	75	50	50
Capacitive breaking capacity, fig. 7	I	90	90	40	40	31.5	31.5	31.5	50	50
Max. breaking capacity in co-operation with fuses IEC 62271-105 (IEC 420 1890-11)	I	1600	1600	1600	900	900	900	300 <sup>4)</sup>		
Max. fuse size <sup>5)</sup>	I <sub>n</sub>	125	125	125	80	80	80	40	40	40
Power frequency withstand voltage 50 Hz 1 min... - to earth and between poles	U <sub>1</sub>	42	45	60	55	55	70	80	80	88
Impulse withstand voltage 1.2/50 μs: - to earth and between poles - across isolating distance	U <sub>2</sub>	75	95	110	125	145	170	170	195	195
Pole distance	mm	150, 170, 210	170, 210	170 <sup>6)</sup> , 235, 275				80-100 Nm		
Max. operating torque at: - closing K/A mech. - opening K/A mech.	Nm	115-120 Nm		K mech. 120 Nm/A mech. 3 Nm						
Operating angle on the shaft	degrees	130								
Act time	ms	40 - 60								

<sup>1)</sup> IEC 420 1890-11  
<sup>2)</sup> At In = 630 A, 100 + CO  
<sup>3)</sup> Max. fuse size is ref. to time current characteristics for CEF  
<sup>4)</sup> Power factor = 0.1  
<sup>5)</sup> With reducing barriers  
<sup>6)</sup> At 18.2 kV

TABLE II. Technical data according to ANSI C 37.20.4 (Versafuapter)

Type name	VR8.25	VR15	VR17	VR27	VR38		
Rated voltage	kV	4.73	12-13.8	13.8	12-16.5	23.9-24.9	34.5
Rated maximum voltage	kV	8.25	15	15	17	27	38
Rated current	A	200/600/1200	200/600/1200	600/1200	200/600/1200	200/600/1200	600/800
Impulse test voltage	kV	75	95	95	110	125	150
Power frequency withstand voltage	kV	26	36	36	50	60	80
Pole spacing	mm/inch	210/8.25	170/6.69	235/9.25	275/10.8	360/14.1	
Momentary rating asymmetrical	kA eff./sec	40	40	61	40	40	40
Fault-closing rated current asymmetrical	kA eff.	40	40	61	40	40	40
Short time current symmetrical	kA eff./sec	25/3	25/3	40/3	25/3	25/3	25/2

TABLE III. Technical data according to ANSI C 37.20.4 (Versafuapter)

Type name	VR8.25	VR15	VR17	VR27	VR38		
Rated voltage	kV	4.73	12-13.8	13.8	12-16.5	23.9-24.9	34.5
Rated maximum voltage	kV	8.25	15	15	17	27	38
Rated current	A	200/600/1200	200/600/1200	600/1200	200/600/1200	200/600/1200	600/800
Impulse test voltage	kV	75	95	95	110	125	150
Power frequency withstand voltage	kV	26	36	36	50	60	80
Pole spacing	mm/inch	210/8.25	170/6.69	235/9.25	275/10.8	360/14.1	
Momentary rating asymmetrical	kA eff.	40	40	61	40	40	40
Fault-closing rated current asymmetrical	kA eff.	40	40	61	40	40	40
Short time current symmetrical	kA eff./sec	25/3	25/3	40/3	25/3	25/3	25/2

TABLE IV. Versarupter styles UA listed


Type name	VR8.25	VR15	VR17	VR27	VR38	
Rated voltage	kV	4.73	13.8	13.8	13.8	13.8
Rated maximum voltage	kV	8.25	15	15	15	15
Rated current	A	200/600	200/600	200/600	200/600	600/1200
Impulse test voltage	kV	75	95	95	95	95
Power frequency withstand voltage	kV	26	36	36	36	36
Pole spacing	mm/inch	150/5.9	170/6.69	170/6.69	235/9.25	235/9.25
Momentary rating asymmetrical	kA eff.	40	40	40	40	40
Fault-closing rated current asymmetrical	kA eff.	40	40	40	40	40
Short time current symmetrical	kA eff./sec	25/3	25/3	25/3	25/3	25/3



# Accessories


## 10. Additional equipment for NAL/NALF switch disconnectors

<p><b>Fig. 13</b> Auxiliary switch for blown fuse</p> 	
---	--

<p><b>Fig. 14</b> Shaft extension with joint link, 380/470 mm consists of:</p>  <p>a) Support bearing b) Connecting tube c) Extension bar d) Connecting kit</p>	
--	--

<p><b>Fig. 15</b> Shaft extension for left hand operation of switch.</p> 	
--	--

<p><b>Fig. 16</b> Interlocking operating levers for switch operation.</p> 	
---	---


<p><b>Fig. 18</b> Manual operation of HE consists of:</p>  <p>a) lower part b) upper part c) connection rod</p> <p>Please observe! The mechanism shaft does not pass through the switch from the mechanism on the right hand side to the left side. Instead a special extension shaft is needed for operation of the mechanism from the left hand side</p> <p>d) lower part for HE can be equipped with blocking coil for all standard voltages</p>	
--	--

<p><b>Fig. 19</b> Shunt trip coil can be mounted on all A mechanisms. This coil is available for the following voltages: 24, 48, 110, 220 V DC and 110, 220 V AC. It shall always be connected in series with an auxiliary switch, which disconnects the shunt trip coil when the switch is open.</p> 	
---	--

<p><b>Fig. 20</b> Mechanical interlocking between switch disconnector and earthing switch. At the earthing switch on the fuse base, the interlocking type (length) depends on the length of the fuse. Therefore, the fuse size must be stated. Mechanical interlocking can also be used for switch disconnector and EB earthing switch.</p> 	
---	--

<p><b>Fig. 21</b> Auxiliary switch can be mounted on all switch disconnectors, max. 4N0 and 4NC and on all earthing switches except LCES, max. 4N0 + 4NC + connection kit for assembling.</p> 	
---	--

### 11. Example of switch arrangement



*Handwritten signature*

Fig. 22 VersaRupter switch disconnector for 8.25 kV





Fig. 23 VersaRupter switch disconnector VR15 (61 kA)



### 12. Ordering information

Switch disconnector without operating mechanism

Type	Rated voltage [kV]	Rated current [A]	Pole spacing [mm]	Ordering number	Weight [kg]
NAL 12-4	12	400	150	1YMX054150M0001	25
NAL 12-4	12	400	170	1YMX064170M0001	25
NAL 12-4	12	400	210	1YMX054950M0001	25
NAL 12-6	12	630	150	1YMX05411M0001	25
NAL 12-6	12	630	170	1YMX064170M0002	25
NAL 12-6	12	630	210	1YMX054971M0001	25
NAL 12-12	12	1250	150	1YMX054152M0001	26
NAL 12-12	12	1250	170	1YMX064170M0003	26
NAL 12-12	12	1250	210	1YMX054852M0001	26
NAL 17-4	17.5	400	170	1YMX054153M0001	27
NAL 17-4	17.5	400	210	1YMX064210M0001	27
NAL 17-6	17.5	630	170	1YMX054144M0001	27
NAL 17-6	17.5	630	210	1YMX064210M0002	27
NAL 17-12	17.5	1250	170	1YMX054155M0001	28
NAL 17-12	17.5	1250	210	1YMX064210M0003	28
NAL 24-4	24	400	170	1YMX064171M0001	35
NAL 24-4	24	400	235	1YMX054456M0001	35
NAL 24-6	24	630	170	1YMX064171M0002	35
NAL 24-6	24	630	235	1YMX054471M0001	35
NAL 24-6	24	630	275	1YMX054467M0001	35
NAL 24-12	24	1250	170	1YMX064371M0003	36
NAL 24-12	24	1250	235	1YMX054458M0001	36
NAL 24-12	24	1250	275	1YMX054458M0001	36
NAL 36-6	36	630	360	1YMX054310M0001	62
NAL 36-8	36	800	360	1YMX054311M0001	62
NAL 36-10	36	1000	360	1YMX054312M0001	62

### Switch disconnector with operating mechanism (K)

Type	Rated voltage [kV]	Rated current [A]	Pole spacing [mm]	Ordering number	Weight [kg]
NAL 12-4K150R	12	400	150	1YMX054010M0001	30
NAL 12-4K170R	12	400	170	1YMX065170M0001	30
NAL 12-4K210R	12	400	210	1YMX054011M0001	30
NAL 12-6K150R	12	630	150	1YMX065170M0002	30
NAL 12-6K170R	12	630	170	1YMX065170M0003	30
NAL 12-6K210R	12	630	210	1YMX054012M0001	31
NAL 12-12K110R	12	1250	170	1YMX065170M0003	31
NAL 12-12K210R	12	1250	210	1YMX054912M0001	31
NAL 17-4K170R	17.5	400	170	1YMX054013M0001	32
NAL 17-4K210R	17.5	400	210	1YMX065210M0002	32
NAL 17-4K210R	17.5	400	210	1YMX065210M0002	32
NAL 17-6K210R	17.5	630	210	1YMX054014M0002	32
NAL 17-6K210R	17.5	630	210	1YMX065210M0006	32
NAL 17-12K170R	17.5	1250	170	1YMX054015M0001	33
NAL 17-12K24170R	17.5	1250	170	1YMX054015M0002	33
NAL 17-12K210R	17.5	1250	210	1YMX065210M0003	33
NAL 17-12K24210R	17.5	1250	210	1YMX065210M0004	33
NAL 24-4K170R	24	400	170	1YMX065171M0001	40
NAL 24-4K235R	24	400	235	1YMX054016M0001	40
NAL 24-6K170R	24	630	170	1YMX065171M0002	40
NAL 24-6K235R	24	630	235	1YMX054017M0001	40
NAL 24-12K170R	24	1250	170	1YMX065171M0003	40
NAL 24-12K235R	24	1250	235	1YMX054018M0001	41
NAL 24-12K275R	24	1250	275	1YMX054019M0001	41
NAL 36-6K360R	36	630	360	1YMX054313M0001	67
NAL 36-8K360R	36	800	360	1YMX054314M0001	67
NAL 36-10K360R	36	1000	360	1YMX054315M0001	67




Fig. 25 NAL 12-6 12 kV switch disconnecter with mechanism K

Switch disconnecter with fuse base on opening side, operating mechanism K, without fuse tripping

Type	Rated volt- age (kV)	Rated cur- rent (A)	Pole spacing (mm)	Ordering number	Weight (kg)
NALF 12-4K150R	12	400	150	1YMX054070M0001	39
NALF 12-4K170R	12	400	170	1YMX068170M0001	39
NALF 12-4K210R	12	400	210	1YMX08210M0001	39
NALF 12-6K150R	12	630	150	1YMX054070M0001	39
NALF 12-6K170R	12	630	170	1YMX068170M0001	39
NALF 12-6K210R	12	630	210	1YMX08210M0001	39
NALF 17-4K24 170R	17.5	400	170	1YMX054070M0001	42
NALF 17-4K24 210R	17.5	400	210	1YMX068210M0001	42
NALF 17-6K24 170R	17.5	630	170	1YMX054070M0001	42
NALF 17-6K24 210R	17.5	630	210	1YMX068210M0001	42
NALF 24-4K235R	24	400	170	1YMX068170M0001	51
NALF 24-4K235R	24	400	235	1YMX054070M0001	51
NALF 24-6K235R	24	630	170	1YMX068170M0001	51
NALF 24-6K235R	24	630	235	1YMX054070M0001	51
NALF 36-6K360R	36	630	360	1YMX054320M0001	68
NALF 36-6K360R	36	630	360	1YMX054320M0001	68

Switch disconnecter with operating mechanism (A)

Type	Rated volt- age (kV)	Rated cur- rent (A)	Pole spacing (mm)	Ordering number	Weight (kg)
NAL 12-4A150R	12	400	150	1YMX054040M0001	32
NAL 12-4A170R	12	400	170	1YMX067170M0001	32
NAL 12-4A210R	12	400	210	1YMX08170M0001	32
NAL 12-6A150R	12	630	150	1YMX054040M0001	32
NAL 12-6A170R	12	630	170	1YMX067170M0001	32
NAL 12-6A210R	12	630	210	1YMX08170M0001	32
NAL 12-12A170R	12	1250	170	1YMX054040M0001	33
NAL 12-12A210R	12	1250	210	1YMX054040M0001	33
NAL 17-4A170R	17.5	400	170	1YMX054040M0001	34
NAL 17-4A210R	17.5	400	210	1YMX067210M0001	34
NAL 17-6A170R	17.5	630	170	1YMX054040M0001	34
NAL 17-6A210R	17.5	630	210	1YMX067210M0001	34
NAL 17-8A210R	17.5	800	210	1YMX054040M0001	34
NAL 17-8A210R	17.5	800	210	1YMX067210M0001	34
NAL 17-12A170R	17.5	1250	170	1YMX054040M0001	35
NAL 17-12A210R	17.5	1250	210	1YMX054040M0001	35
NAL 24-4A235R	24	400	170	1YMX067170M0001	42
NAL 24-4A235R	24	400	235	1YMX054040M0001	42
NAL 24-6A170R	24	630	170	1YMX067170M0001	42
NAL 24-6A170R	24	630	235	1YMX054040M0001	42
NAL 24-6A235R	24	630	170	1YMX067170M0001	42
NAL 24-6A235R	24	630	235	1YMX054040M0001	42
NAL 24-12A170R	24	1250	170	1YMX054040M0001	43
NAL 24-12A235R	24	1250	235	1YMX054040M0001	43
NAL 36-6A360R	36	630	360	1YMX054318M0001	68
NAL 36-6A360R	36	630	360	1YMX054318M0001	68
NAL 36-10A350R	36	1000	360	1YMX054321M0001	68

Fig. 24 NALF 12-6 12 kV fuse switch disconnecter with mechanism A



Switch disconnecter with fuse base on opening side, operating mechanism K, without fuse tripping

Type	Rated volt- age (kV)	Rated cur- rent (A)	Pole spacing (mm)	Ordering number	Weight (kg)
NALF 12-4K150R	12	400	150	1YMX054070M0001	39
NALF 12-4K170R	12	400	170	1YMX068170M0001	39
NALF 12-4K210R	12	400	210	1YMX08210M0001	39
NALF 12-6K150R	12	630	150	1YMX054070M0001	39
NALF 12-6K170R	12	630	170	1YMX068170M0001	39
NALF 12-6K210R	12	630	210	1YMX08210M0001	39
NALF 17-4K24 170R	17.5	400	170	1YMX054070M0001	42
NALF 17-4K24 210R	17.5	400	210	1YMX068210M0001	42
NALF 17-6K24 170R	17.5	630	170	1YMX054070M0001	42
NALF 17-6K24 210R	17.5	630	210	1YMX068210M0001	42
NALF 24-4K235R	24	400	170	1YMX068170M0001	51
NALF 24-4K235R	24	400	235	1YMX054070M0001	51
NALF 24-6K235R	24	630	170	1YMX068170M0001	51
NALF 24-6K235R	24	630	235	1YMX054070M0001	51
NALF 36-6K360R	36	630	360	1YMX054320M0001	68
NALF 36-6K360R	36	630	360	1YMX054320M0001	68

Switch disconnecter with fuse base on pivot side, operating mechanism A, with fuse tripping

Type	Rated volt- age (kV)	Rated cur- rent (A)	Pole spacing (mm)	Ordering number	Weight (kg)
NALF 12-4A150R	12	400	150	1YMX054090M0001	41
NALF 12-4A170R	12	400	170	1YMX070170M0001	41
NALF 12-4A210R	12	400	210	1YMX085855M0001	41
NALF 12-6A150R	12	630	150	1YMX054090M0001	41
NALF 12-6A170R	12	630	170	1YMX070170M0001	41
NALF 12-6A210R	12	630	210	1YMX085855M0001	41
NALF 17-4A24 170R	17.5	400	170	1YMX054092M0001	44
NALF 17-4A24 210R	17.5	400	210	1YMX070210M0001	44
NALF 17-6A24 170R	17.5	630	170	1YMX054093M0001	44
NALF 17-6A24 210R	17.5	630	210	1YMX070210M0001	44
NALF 24-4A235R	24	400	170	1YMX070170M0001	53
NALF 24-4A235R	24	400	235	1YMX054094M0001	53
NALF 24-6A235R	24	630	170	1YMX070170M0001	53
NALF 24-6A235R	24	630	235	1YMX054095M0001	53
NALF 36-6A360R	36	630	360	1YMX054328M0001	70
NALF 36-6A360R	36	630	360	1YMX054330M0001	70




Fig. 26 NALF 36 kV fuse switch disconnector

16 Switch disconnecter type NAL

Switch disconnecter type NAL 15



ОПРЕДЕЛЕНА СИГНАЛА

*Handwritten signature*



Fuse base type F for spring mechanism type A with fuse tripping, mounted on pivot side

Type	Rated voltage [kV]	Rated current [A]	Pole spacing [mm]	Ordering number	Weight [kg]
F 12	12	400/630	150	1YMX054195M0001	7
F 12	12	400/630	170	1YMX064195M0001	7
F 12	12	400/630	210	1YMX064197M0001	7
F 12	12	400/630	210	1YMX054196M0001	7
F 17 for LCES	17	400/630	170	1YMX068338M0001	8
F 17 for LCES	17	400/630	210	1YMX068339M0001	8
F 17 for LCES	17	400/630	210	1YMX068336M0001	8
F 24	24	400/630	170	1YMX054197M0001	15
F 24	24	400/630	235	1YMX054197M0001	15
F 24 for LCES	24	400/630	235	1YMX054478M0001	13
F 24	24	400/630	275	1YMX054478M0001	13
F 24 for LCES	24	400/630	275	1YMX054335M0001	13
F 36	36	630/800	360	1YMX054337M0001	17

Fuse base type F for spring mechanism type A with fuse tripping, mounted on opening side

Type	Rated voltage [kV]	Rated current [A]	Pole spacing [mm]	Ordering number	Weight [kg]
F 12	12	400/630	150	1YMX054200M0001	7
F 12	12	400/630	170	1YMX064200M0001	7
F 12	12	400/630	210	1YMX054781M0001	7
F 12	12	400/630	210	1YMX054201M0001	8
F 17	17	400/630	170	1YMX064202M0001	8
F 17	17	400/630	210	1YMX064202M0001	15
F 24	24	400/630	235	1YMX054202M0001	13
F 24	24	400/630	275	1YMX054478M0001	13

Fuse base with six insulators for spring mechanism type A with fuse tripping

Type	Rated voltage [kV]	Rated current [A]	Pole spacing [mm]	Ordering number	Weight [kg]
EB 12	12	400/630/1250	150	1YMX054205M0001	16
EB 12	12	400/630/1250	170	1YMX064205M0001	16
EB 12	12	400/630/1250	210	1YMX054974M0001	17
EB 17	17	400/630/1250	170	1YMX064206M0001	20
EB 17	17	400/630/1250	210	1YMX064207M0001	22
EB 24	24	400/630/1250	235	1YMX054207M0001	24
EB 24	24	400/630/1250	275	1YMX054474M0001	22

Fuse base with six insulators and double fuses per phase

Type	Rated voltage [kV]	Rated current [A]	Pole spacing [mm]	Ordering number	Weight [kg]
EB 12	12	400/630/1250	150	1YMX0343555M0001	18
EB 12	12	400/630/1250	170	1YMX0343555M0001	19
EB 12	12	400/630/1250	210	1YMX0343555M0001	22
EB 17	17	400/630/1250	170	1YMX0343555M0001	24
EB 24	24	400/630/1250	235	1YMX0343555M0001	26

Fuse base type F for spring mechanism type K/A without fuse tripping, mounted on pivot side

Type	Rated voltage [kV]	Rated current [A]	Pole spacing [mm]	Ordering number	Weight [kg]
F 12	12	400/630	150	1YMX054181M0001	7
F 12	12	400/630	170	1YMX064181M0001	7
F 12	12	400/630	210	1YMX054980M0001	7
F 17 for LCES	17	400/630	170	1YMX054182M0001	8
F 17 for LCES	17	400/630	210	1YMX068338M0002	8
F 17 for LCES	17	400/630	210	1YMX068339M0001	8
F 24	24	400/630	170	1YMX054183M0001	13
F 24	24	400/630	235	1YMX054183M0001	13
F 24 for LCES	24	400/630	235	1YMX054478M0002	13
F 24	24	400/630	275	1YMX054478M0001	13
F 24 for LCES	24	400/630	275	1YMX054338M0004	13
F 36	36	630/800	360	1YMX054337M0001	17

Fuse base type F for spring mechanism type K/A without fuse tripping, mounted on opening side

Type	Rated voltage [kV]	Rated current [A]	Pole spacing [mm]	Ordering number	Weight [kg]
F 12	12	400/630	150	1YMX054190M0001	7
F 12	12	400/630	170	1YMX064190M0001	7
F 12	12	400/630	210	1YMX054981M0001	7
F 17	17	400/630	170	1YMX054191M0001	8
F 17	17	400/630	210	1YMX064191M0001	8
F 24	24	400/630	170	1YMX054193M0001	13
F 24	24	400/630	235	1YMX054193M0001	13
F 36	36	630/800	360	1YMX054337M0001	17

Fuse base with six insulators for spring mechanism type A

Type	Rated voltage [kV]	Rated current [A]	Pole spacing [mm]	Ordering number	Weight [kg]
F 12	12	400/630/1250	150	1YMX054185M0001	15.5
F 12	12	400/630/1250	170	1YMX064185M0001	16
F 12	12	400/630/1250	210	1YMX054972M0001	16.5
F 17	17	400/630/1250	170	1YMX054417M0001	19.5
F 17	17	400/630/1250	210	1YMX064187M0001	19.5
F 24	24	400/630/1250	235	1YMX054187M0001	21.5
F 24	24	400/630/1250	275	1YMX054477M0001	21.5
F 36	36	630/800	360	1YMX054477M0001	23.5

Earthing switch type E for NAL switch disconnector without mechanical interlocking

Type	Rated voltage [kV]	Rated current [A]	Pole spacing [mm]	Ordering number	Weight [kg]
E 12	12	400/630	150	1YMX054235M0001	7
E 12	12	400/630	170	1YMX064235M0001	7
E 12	12	400/630	210	1YMX054982M0001	7
E 12	12	400/630	210	1YMX054234M0001	7
E 12	12	1250	150	1YMX064235M0002	7
E 12	12	1250	170	1YMX054889M0001	7
E 12	12	1250	210	1YMX054236M0001	6
E 17	17	400/630	170	1YMX064236M0001	6
E 17	17	400/630	210	1YMX054236M0002	6
E 17	17	400/630	210	1YMX064237M0001	6
E 24	24	400/630	235	1YMX054237M0001	8
E 24	24	400/630	275	1YMX054483M0001	8
E 24	24	1250	170	1YMX064237M0002	8
E 24	24	1250	235	1YMX054219M0001	9
E 24	24	1250	275	1YMX054489M0001	9

Earthing switch type E for NAL switch disconnector without mechanical interlocking, mounted on fuse base

Type	Rated voltage [kV]	Rated current [A]	Pole spacing [mm]	Ordering number	Weight [kg]
E 12	12	400/630	150	1YMX054235M0001	7
E 12	12	400/630	170	1YMX064235M0001	7
E 12	12	400/630	210	1YMX054981M0001	7
E 12	12	400/630	210	1YMX054234M0001	7
E 17	17	400/630	170	1YMX064236M0001	6
E 17	17	400/630	210	1YMX064236M0001	6
E 17	17	400/630	210	1YMX064237M0001	6
E 24	24	400/630	235	1YMX054237M0001	8
E 24	24	400/630	275	1YMX054483M0001	8
E 24	24	1250	170	1YMX064237M0002	8
E 24	24	1250	235	1YMX054219M0001	9
E 24	24	1250	275	1YMX054489M0001	9

Earthing switch type LCES for NAL switch disconnector without mechanical interlocking

Type	Rated voltage [kV]	Rated current [A]	Pole spacing [mm]	Ordering number	Weight [kg]
LCES E12	12	400/630	150	1YMX068325M0001	7
LCES E12	12	400/630	170	1YMX068325M0002	7
LCES E12	12	400/630	210	1YMX068325M0003	7
LCES E12	12	1250	150	1YMX068325M0001	7
LCES E12	12	1250	170	1YMX068325M0012	7
LCES E12	12	1250	210	1YMX068325M0013	7
LCES E17	17	400/630	170	1YMX068325M0001	6
LCES E17	17	400/630	210	1YMX068325M0004	6
LCES E17	17	400/630	210	1YMX068325M0014	6
LCES E24	24	400/630	235	1YMX068325M0006	6
LCES E24	24	400/630	275	1YMX068325M0007	6
LCES E24	24	1250	235	1YMX068325M0016	6
LCES E24	24	1250	275	1YMX068325M0017	6

Earthing switch type LCES for NAL switch disconnector without mechanical interlocking, mounted on fuse base

Type	Rated voltage [kV]	Rated current [A]	Pole spacing [mm]	Ordering number	Weight [kg]
LCES EF12	12	400/630	150	1YMX068325M0021	7
LCES EF12	12	400/630	170	1YMX068325M0022	7
LCES EF12	12	400/630	210	1YMX068325M0023	7
LCES EF17	17	400/630	170	1YMX068325M0024	6
LCES EF17	17	400/630	210	1YMX068325M0025	6
LCES EF24	24	400/630	235	1YMX068325M0026	6
LCES EF24	24	400/630	275	1YMX068325M0027	6

Earthing switch type LCES freestanding

Type	Rated voltage [kV]	Rated current [A]	Pole spacing [mm]	Ordering number	Weight [kg]
LCES EB12	12	1250	150	1YMX068325M0031	17
LCES EB12	12	1250	170	1YMX068325M0032	17
LCES EB12	12	1250	210	1YMX068325M0033	17
LCES EB17	17	1250	170	1YMX068325M0034	18
LCES EB24	24	1250	235	1YMX068325M0035	19
LCES EB24	24	1250	275	1YMX068325M0036	24
LCES EB36	36	800	360	1YMX068325M0038	30
LCES EB36 on pivot side	36	800	360	1YMX068325M0039	30
LCES EB36 on pivot side NALF	36	800	360	1YMX068325M0040	30

13. Mechanisms and additional accessories for NAL and VersaRupter switch disconnectors

Description	Type	Ordering number	Weight [kg]
K-mechanism (Fig. 10)	K.12	1YMX054165M0001	5
K-mechanism	K.17	1YMX030665M0001	5
K-mechanism	K.24	1YMX054167M0001	5
Mechanism K	K.36	1YMX054340M0001	5
A-mechanism (Fig. 9)	A.12	1YMX054173M0001	7
A-mechanism	A.12	1YMX139725M0002	7
A-mechanism special version	A.17	1YMX054174M0001	7
A-mechanism	A.24	1YMX054175M0001	7
A-mechanism	A.36	1YMX051341M0001	7
Plastic cover for A mechanism		1YMX241351M0001	0.2

Hand operating mechanism type HE with accessories

Description/Type	Ordering number	Weight [kg]
Front bearing for HE, with cardanic joint (Fig. 18 a)	1YMX053233M0001	1.4
Front bearing for HE, without cardanic joint	1YMX053233M0002	0.8
Front bearing for HE for motor operation	1YMX0242248M0004	1.8
Bowl (part for HE (Fig. 18 b))	1YMX053362M0002	2.1
Operating handle for HE	1YMX053235M0001	2.1
Operating handle for HE armoured	1YMX053235M0004	2.1
Front bearing for HE, with blocking coil, 230 VAC (Fig. 18 d)	1YMX053393M0001	2.1
Front bearing for HE, with blocking coil, 110 VAC	1YMX053394M0001	2.1
Front bearing for HE, with blocking coil, 220 V DC	1YMX053395M0001	2.1
Front bearing for HE, with blocking coil, 110 V DC	1YMX053396M0001	2.1
Front bearing for HE, with blocking coil, 48 V DC	1YMX053397M0001	2.1
Front bearing for HE, with blocking coil, 24 V DC	1YMX053398M0001	2.1
Spare coils for blocking coil, 230 VAC	1YMX018958M0015	0.8
Spare coils for blocking coil, 110 VAC	1YMX018958M0014	0.8
Spare coils for blocking coil, 220 V DC	1YMX018958M0009	0.8
Spare coils for blocking coil, 110 V DC	1YMX018958M0007	0.8
Spare coils for blocking coil, 48 V DC	1YMX018958M0016	0.8
Spare coils for blocking coil, 24 V DC	1YMX018958M0017	0.8

Description/Type	Ordering number	Weight [kg]
Front bearing for HE, with blocking coil, 230 VAC	1YMX053398M0001	2.1
Spare coils for blocking coil, 230 VAC	1YMX018958M0015	0.8
Spare coils for blocking coil, 110 VAC	1YMX018958M0014	0.8
Spare coils for blocking coil, 220 V DC	1YMX018958M0009	0.8
Spare coils for blocking coil, 110 V DC	1YMX018958M0007	0.8
Spare coils for blocking coil, 48 V DC	1YMX018958M0016	0.8
Spare coils for blocking coil, 24 V DC	1YMX018958M0017	0.8
Front bearing for HE, with blocking coil, 230 VAC	1YMX053398M0001	2.1
Spare coils for blocking coil, 230 VAC	1YMX018958M0015	0.8
Spare coils for blocking coil, 110 VAC	1YMX018958M0014	0.8
Spare coils for blocking coil, 220 V DC	1YMX018958M0009	0.8
Spare coils for blocking coil, 110 V DC	1YMX018958M0007	0.8
Spare coils for blocking coil, 48 V DC	1YMX018958M0016	0.8
Spare coils for blocking coil, 24 V DC	1YMX018958M0017	0.8

Mechanical interlocking for earthing switch<sup>1)</sup> (Fig. 20)

Description/Type	Ordering number	Weight [kg]
Connecting Rod 3/4" L = 1300 mm isolated	1YMX000012M0001	2.1
Connecting Rod 3/4" L = 2000 mm isolated	1YMX000012M0002	3.1
Connecting Rod 3/4" L = 1300 mm isolated strength <sup>1)</sup>	1YMX000012M0003	2.9
Connecting Rod 3/4" L = 2000 mm isolated strength <sup>1)</sup>	1YMX000012M0004	4.2
Connecting Rod 3/4" L = 688 mm isolated C2 <sup>1)</sup>	1YMX000012M0005	1.2
Connecting Rod 3/4" L = 738 mm isolated C2 <sup>2)</sup>	1YMX000012M0006	1.3
Connecting Rod 3/4" L = 1300 mm isolated strength C2 <sup>1)</sup>	1YMX000012M0007	2.9
Connecting Rod 3/4" L = 2000 mm isolated strength C2 <sup>1)</sup>	1YMX000012M0008	4.2
Connecting Rod 3/4" L = 1300 mm strength <sup>1)</sup>	1YMX000004M0003	2.7
Connecting Rod 3/4" L = 2000 mm strength <sup>1)</sup>	1YMX000004M0004	4.0
Connecting Rod 3/4" L = 1300 mm strength C2 <sup>1)</sup>	1YMX000004M0007	2.7
Connecting Rod 3/4" L = 2000 mm strength C2 <sup>1)</sup>	1YMX000004M0008	4.0

Description/Type	Ordering number	Weight [kg]
Crank arm (Fig. 16)	1YMX053235M0001	1.7
Shaft extension 470 mm (Fig. 14 c)	1YMX053348M0001	1.4
Shaft extension 380 mm (Fig. 14 c)	1YMX053348M0001	1.4
Joint kit for shaft extension (Fig. 14 b, d)	1YMX053350M0001	0.2
Support bearing (Fig. 14 a)	1YMX053350M0001	0.2
for NAL/NALF 12	1YMX053351M0001	1.8
for NAL/NALF 17/24	1YMX053352M0001	1.8
for NAL/NALF 36	1YMX053353M0001	1.9
for NAL 12 with E 12	1YMX053354M0001	2.2
for NAL 17/24 with E 17/24	1YMX053355M0001	2.8
for F 12 with E 12	1YMX053356M0001	1.3
for F 17/24 with E 17/24	1YMX053356M0001	1.4
Components for transmission 80° <sup>a)</sup> (Fig. 27)	1YMX053393M0002	2.1
bowl gear (Fig. 27 a)	1YMX053393M0002	2.1
rod connector (Fig. 27 b)	1YMX053393M0001	0.7
rod connector (Fig. 27 c)	1YMX053393M0001	0.7
Transmission 80° complete (Fig. 27 a, b, c)	1YMX000012M0006	4.0
Test fuse, adjustable length J, 6/40 kV with starter pan (Fig. 17)	1YMX000042M0001	1.2

<sup>1)</sup> Recommended for motor drive UEMCA0A and switch disconnector type NAL/NALF  
<sup>2)</sup> 24...38 kV  
<sup>a)</sup> Zinc plated  
<sup>b)</sup> For these items use strength connecting rod only




Fig. 27 Transmission 80° complete  
 8 switch disconnector type NAL 21

Shunt trip for A mechanism<sup>1)</sup> (including firing parts) (Fig. 19)

Description/Type	Ordering number	Weight [kg]
Coil 220 VAC without auxiliary switch	1YMX054275M0001	2.5
Coil 110 VAC without auxiliary switch	1YMX054276M0001	3.1
Coil 125 VAC without auxiliary switch	1YMX054277M0001	5.7
Coil 220 VDC without auxiliary switch	1YMX054278M0001	5.0
Coil 110 VDC without auxiliary switch	1YMX054279M0001	6.4
Coil 125 VDC without auxiliary switch	1YMX054280M0001	6.4
Coil 220 VDC without auxiliary switch	1YMX054281M0001	6.3
Coil 110 VDC without auxiliary switch	1YMX054282M0001	7.0
Coil 125 VDC without auxiliary switch	1YMX054283M0001	6.5
Coil 24 VDC without auxiliary switch	1YMX054283M0001	7.3
Coil 24 VDC without auxiliary switch	1YMX343986M0002	5.4
Coil 24 VDC without auxiliary switch	1YMX343986M0001	3.3
Coil 24 VDC without auxiliary switch	1YMX343986M0003	9.4
Coil 24 VDC without auxiliary switch	1YMX343986M0004	7.6

<sup>1)</sup> In connection with shunt trip, auxiliary switch that breaks shunt trip circuit, must be used.

Spare coil for shunt trip for A mech

Description/Type	Ordering number	Weight [kg]
Coil 220 VAC	1YMX054250M0001	0.6
Coil 125 VAC	1YMX054251M0001	0.6
Coil 220 VDC	1YMX054252M0001	0.6
Coil 110 VDC	1YMX054253M0001	0.6
Coil 125 VDC	1YMX054253M0002	0.6
Coil 48 VDC	1YMX054254M0001	0.6
Coil 24 VDC	1YMX054255M0001	0.6

14. Motor drives

Motor drives enable the remote opening and closing of switch disconnectors while at the same time they are prepared for the possibility of an emergency manual maneuver. A variety of models offers a selection of appropriate drive configurations. Drives type UEMCA0A1 and A2 are designed to be installed on the front wall of the panel (left or right side). They can open and close switch disconnector mechanisms A and K, and are connected to the shaft of the switch disconnector by coupling ties

14. Motor drives

Motor drives enable the remote opening and closing of switch disconnectors while at the same time they are prepared for the possibility of an emergency manual maneuver. A variety of models offers a selection of appropriate drive configurations. Drives type UEMCA0A1 and A2 are designed to be installed on the front wall of the panel (left or right side). They can open and close switch disconnector mechanisms A and K, and are connected to the shaft of the switch disconnector by coupling ties

The UEMCA0A series is not recommended for NAL 36 - 36 kV with A mechanism. Standard drive for NAL/F (Fig. 29) can be mounted directly on the shaft or switch disconnector or on the side wall of the panel, it cooperates with spring mechanisms A and K. To mount the standard drive for NAL/F on the shaft of the disconnector, suitable supports brackets are needed (Fig. 28). The correct choice of brackets depends on the type of disconnector, drive and motor assembly as is shown in the table below.


Standard drive for NAL/F (Fig. 29) can be mounted directly on the shaft or switch disconnector or on the side wall of the panel, it cooperates with spring mechanisms A and K. To mount the standard drive for NAL/F on the shaft of the disconnector, suitable supports brackets are needed (Fig. 28). The correct choice of brackets depends on the type of disconnector, drive and motor assembly as is shown in the table below.

Standard drive for NAL/F (Fig. 29) can be mounted directly on the shaft or switch disconnector or on the side wall of the panel, it cooperates with spring mechanisms A and K. To mount the standard drive for NAL/F on the shaft of the disconnector, suitable supports brackets are needed (Fig. 28). The correct choice of brackets depends on the type of disconnector, drive and motor assembly as is shown in the table below.



15. Dimensional drawings


Switch disconnecter type NAL 12, 17.5 and 24 kV with mechanism



Type	A	A1	A2	A3	B	H	H1	H2	K	K1	M	N	P	R	S	U	V
NAL 12-AVK P=150	166	320	362	394	90	422	428	510	310	63	412	122	164	150	375	350	75
NAL 12-AVK P=170	166	320	362	394	90	422	428	510	310	63	452	122	184	170	375	390	75
NAL 12-AVK P=210	166	320	362	394	90	422	428	510	310	63	532	122	184	210	375	470	75
NAL 17.5-AVK P=170	225	418	511	511	98	534	577	600	441	87	452	122	164	170	500	395	90
NAL 17.5-AVK P=210	225	418	511	511	98	534	577	600	441	87	522	122	164	210	500	475	90
NAL 24-AVK P=235	225	375	418	511	98	534	577	600	441	87	582	186	202	235	500	525	90
NAL 24-AVK P=275	225	375	418	511	98	534	577	600	441	87	662	186	202	275	500	605	90

\*1250 A: dimension A + 2 mm

Switch disconnecter type NAL 24 kV with mechanism and insulation barriers



24 Switch disconnecter type NAL




Fig. 28 Space brackets for mounting of standard motor drive for NAL/F

Spring mech. type A NAL/NALF	12 17.5 24 36					
	L	P	L	P	L	P
Part name	Space bracket 39 mm					
Part number	1YMX000044M0001					
Mounting side	Space bracket 55 mm					
Part name	Space bracket 85 mm					
Part number	1YMX000044M0002					
Mounting side	Space bracket 105 mm					
Part name	Space bracket 105 mm					
Part number	1YMX000044M0004					
Mounting side	Space bracket 39*					
Part name	Space bracket 39*					
Part number	1YMX000044M0001*					
Mounting side	Space bracket 39*					
Part name	Space bracket 105 mm					
Part number	1YMX000044M0004					

The motor unit is mechanically disconnected after each operation, which presents an opportunity to manually operate the switch disconnecter. The drive can be operated locally via the buttons on the control box (Fig. 31) or remotely using radio control. The control system is then supplied in a separate order.



Fig. 30 K3 motor drive




Fig. 31 Operating box




Fig. 32 Control unit

Fig. 29 Dimensional drawing for NAL/F

Type	24	48	60	110/125	220
Ordering number	1YMX000042M0001	1YMX000042M0002	1YMX000042M0003	1YMX000042M0004	1YMX000042M0005
Operating voltage, AC	17-26	34-52	42-66	77-117	154-242
Operating voltage, DC	22-28	43-57	54-72	99-150	198-264
Normal current during operation	3	3	0.8	0.8	0.4
Maximum current during operation	6	6	4	4	1.2
Power consumption	70	70	70	70	70
Operating time	-4	-4	-8	-8	-4
Signaling time	0.5-2.0	1.0-4.0	0.5-2.0	0.5-2.0	0.5-2.0
Operating temperature	-40...+55	-40...+55	-40...+55	-40...+55	-40...+55
Weight	6	6	6	6	6


Switch disconnecter type NAL 23

Fuse switch disconnector type NALF 12 kV with mechanism




1YMK43378

Fuse switch disconnector type NALF 24 kV with mechanism and insulation barriers



1YMK43377


Fuse switch disconnector type NALF 17.5 kV with mechanism



1YMK43375

Switch disconnector type NAL 25


Fuse switch disconnector type NALF 24 kV with mechanism



1YMK43379

26 Switch disconnector type NAL


Fuse switch disconnector type NALF 12, 17.5 and 24 kV  
Fuse base with 6 insulators and double fuses per phase




Fuses	H5		A5		A7		P
	length						
3.6/7.2	192	462	173	430	170	430	150
12	292	562	273	430	170	430	170
	292	562	292	430	210	430	170
17.5	442	704	243	500	210	500	170
	292	562	243	500	170	430	170
24	442	706	243	500	235	500	235
	442	706	243	500	275	500	275

1YMKX43587

Earthing switch with making capacity type E12




Earthing switch with making capacity type E12 mounted on NAL12



Earthing switch with making capacity type E12 mounted on fuse base F12

Type	M1	M2	S
E12	681	428	350
E12	721	468	390
E12	801	548	470

Earthing switch with making capacity type E17.5




Earthing switch with making type E17.5 mounted on NAL17.5

E17.5	M1	M2	S
P=170	721	468	395
P=210	801	548	475

1YMKX43801

Earthing switch with making type E17.5 mounted on fuse base F17.5

Earthing switch with making capacity type E24/EL24 P=170 with insulation barriers




Earthing switch with making type E24/EL24 mounted on NAL24 P=170

Type	M1	M2	M3
E24 P=170	800	166	174
EL24 P=170	721	114	139

1YMKX88374

Earthing switch with making type E24/EL24 mounted on fuse base F24 P=170

Earthing switch with making capacity type E24




Earthing switch with making capacity type E24 mounted on NAL24



E24	M1	M2	S
P=235	933	598	525
P=275	1013	678	605

1YMKX43802

Earthing switch with making capacity type E24 mounted on fuse base F24




Earthing switch with making capacity type E 12, E 17.5 and E 24 mounted on fuse base with 6 insulators



1YMX343538

Type	M2	M3	K3	M1	M2	N2	N3	P	S	W
E12 P=150	208	393	100	681	429	112	139	150	350	60
E12 P=170	208	393	100	721	468	112	139	170	390	60
E12 P=210	208	393	100	801	548	112	139	210	470	60
E17.5 P=170	208	432	100	721	468	112	139	170	395	60
E17.5 P=210	208	432	100	801	548	112	139	210	395	60
E24 P=235	351	575	100	933	596	161	174	235	525	120
E24 P=275	351	575	100	1013	678	161	174	275	605	120

Separately mounted earthing switch with making capacity type EB




Type	A	H	K	R	U
EB12	245	231	115	200	46
EB17.5	310	245	90	175	21

Other measurements see figure 1YMX343538 above


Switch disconnector type NAL 29

Earthing switch type LCES 12 kV




Type	M1	M2	S
E 12 P=150	691	428	350
E 12 P=170	721	468	390
E 12 P=210	801	548	470

Earthing switch type LCES 17.5 kV




Type	M1	M2	S
E 17 P=170	721	468	395
E 17 P=210	801	548	475

Earthing switch type LCES 24 kV




Type	M1	M2	S
E 24 P=235	933	598	525
E 24 P=275	1013	678	605


30 Switch disconnector type NAL




Earthing switch types LCES EF12 mounted on fuse base F12




Earthing switch types LCES E12 mounted on NAL 12




Earthing switch types LCES EF17 mounted on fuse base F17



Earthing switch types LCES E17 mounted on NAL 12




Earthing switch types LCES EF24 mounted on fuse base F24





Earthing switch types LCES E24 mounted on NAL 24




Separately mounted earthing switch type LCES EB36




Standard hand operating mechanism HE



Front bearing for HE




Bevel gear for HE




Bevel gear base for HE

Operating angle 180°




1YMX080350



1YMX040223


Arrangement of HE with switch disconnector with 90° angle



Switch disconnector type NAL 31




Fuse switch disconnector with earthing switch NALF 12 150 RE - example of arrangement



1YMX04063

Fuses kV	A	M1	M2	M3	K2	R1
7.2	4-100	848	772	1083	722	275
	125-200	948	872	1163	822	375
12	4-100	948	872	1163	822	375
	125-200	1098	1022	1313	872	525

NAL 36 KV



1YMX241285


End knife position after opening

Switch disconnector type NAL





## Въздушно изолирани разединители тип NAL и NALF



Триполюсните мощностни разединители **NAL**, производство на ABB, са предназначени за изключване на веригата под товар. Комбинацията на **NAL** с предпазители (**NALF**) осигурява и защита от късо съединение. Всеки тип може да бъде доставен в три варианта, за номинален ток: 400 А, 630 А и 1250 А

### Приложение:

- в разпределителните мрежи за комутиране на електропроводи и трансформатори
- за комутиране на двигатели
- за комутиране на кондензатори

### Предимства:

- Облекчена кинематика
- Възможност за моторно задвижване и дистанционно командване
- Висока надеждност: основен ремонт на разединителя се прави чак след 1000 механични цикъла или след 500 изключвания под товар при работен ток равен на половината от обявения.
- Компактност и удобство за инсталиране в КТП, намалени междуфазни разстояния:
- При разединител за номинално напрежение  $U_n=10$  kV разстоянието между полюсите е 150 mm, 170 mm или 210 mm
- При разединител за номинално напрежение  $U_n=20$  kV разстоянието между полюсите е 170 mm, 235 mm или 275 mm
- Мощностните разединители тип NAL и NALF са оборудвани с двойна дъгогасителна система

ВЪРНО  
ОРИГИНАЛ

